

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K008**

School: P.S. 8 - BROOKLYN, 37 HICKS STREET, BROOKLYN, NY, 11201

InspectionId	Inspection Type	Time In	Last Edited
1620105	ELECTRICAL	2011-02-09 08:27AM	2011-02-15 03:36PM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Most Systems & Components. Years: Under Construction Systems: All Basement. Years: Under Construction Systems: Fluorescent Lights. Years: Approximately 1995 Systems: Motor Starters. Years: 2007 Systems: Molded Case Panels. Years: Approximately 1990 Systems: Fused Disconnect Switch Panel. Years: 1993 Systems: Smart Board. Years: 2006 Type of Service: Below Ground

**Priority Condition**

No condition recorded

**Inspection**

Question	Response
<b>ELECTRICAL</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance	1st floor
<b>HOUSE LIGHTING</b>	
Instance on 1st floor	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st floor	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on 1st floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st floor	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on 1st floor	Under construction
<b>PROJECTION SYSTEM</b>	
Instance on 1st floor	Does not exist
<b>THEATER LIGHTING SYSTEM</b>	
Instance on 1st floor	Inspected
<b>Dimming System</b>	
Instance on 1st floor	Does not exist
<b>Theater Lighting</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K008**

Question	Response
<b>AUDITORIUM</b>	
<b>THEATER LIGHTING SYSTEM</b>	
<b>Theater Lighting</b>	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	
	Under construction
<b>CAFETERIA</b>	
	Inspected
Instance	Basement
<b>LIGHTING</b>	
Instance on Basement	Under construction
<b>LOCAL SOUND SYSTEM</b>	
Instance on Basement	Under construction
<b>CITY FIRE ALARM SYSTEM</b>	
	Inspected
Condition	5- Poor
Deficiency	NOT OPERATIONAL
Deficiency Location/Instance	Next To General Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
	Inspected
<b>LIGHTING</b>	
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
	Inspected
<b>Pendant Mounted</b>	
	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
	Does not exist
<b>Surface Mounted</b>	
	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
	Does not exist
<b>Lighting Fixture - Incandescent</b>	
	Inspected
<b>Pendant Mounted</b>	
	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K008**

Question	Response
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Pendant Mounted</b>	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	17
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SMART BOARD</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>COMPUTER LAB</b>	Does not exist
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Under construction
<b>EMERGENCY LIGHTING</b>	Under construction
<b>EXIT LIGHT</b>	Under construction
<b>EXIT/EMERGENCY LIGHT</b>	Does not exist
<b>FIRE ALARM SYSTEM</b>	Under construction
<b>GROUNDING SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	Does not exist
<b>INTERCOM SYSTEM</b>	Does not exist
<b>KITCHEN/WARMING PANTRY</b>	Inspected
Instance	Basement
<b>LIGHTING</b>	
Instance on Basement	Under construction
<b>LAN</b>	Under construction
<b>LIBRARY</b>	Inspected
Instance	Room 204
Has LAN/Modem access	Yes
<b>LIGHTING</b>	
Instance on Room 204	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 204	Inspected
<b>Pendant Mounted</b>	
Instance on Room 204	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K008**

<b>Question</b>	<b>Response</b>
<b>LIBRARY</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 204	Does not exist
<b>Surface Mounted</b>	
Instance on Room 204	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 204	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 204	Does not exist
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room 204	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>SMART BOARD</b>	
Instance on Room 204	Does not exist
<b>LIGHTING - SECURITY LIGHTS</b>	Under construction
<b>LIGHTNING PROTECTION</b>	Does not exist
<b>LOCKER ROOM</b>	Does not exist
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>MULTIPURPOSE ROOM</b>	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>FUSED DISCONNECT SWITCH TYPE</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>FUSED KNIFE SWITCH TYPE</b>	Does not exist
<b>FUSED TOGGLE SWITCH TYPE</b>	Does not exist
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD ID IS MISSING
Deficiency Location/Instance	All floors corridors & Boiler room
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>PUBLIC ADDRESS SYSTEM</b>	Under construction
<b>SCIENCE DEMO ROOM</b>	Does not exist
<b>SCIENCE LAB</b>	Does not exist
<b>SCIENCE PREP ROOM</b>	Does not exist
<b>SECURITY</b>	Under construction
<b>SERVICE SWITCH</b>	Under construction
<b>SWIMMING POOL</b>	Does not exist
<b>SWITCHBOARD</b>	Under construction
<b>TELEPHONE</b>	Inspected
<b>PBX/INTERCOM</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K008**

<b>Question</b>	<b>Response</b>
<b>TELEPHONE</b>	
<b>PBX/INTERCOM</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>STANDARD</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>TOILET ROOM - STAFF</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TRANSFORMER</b>	Does not exist
<b>TV SYSTEM</b>	Under construction