

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K035**

School: **I.S. 35 - BROOKLYN, 272 MCDONOUGH STREET, BROOKLYN, NY, 11233**

InspectionId	Inspection Type	Time In	Last Edited
2140026	ELECTRICAL	2010-11-02 08:43AM	2011-05-09 05:50AM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Security CCTV System Years: 2010 Systems: Smart Boards Years: 2009 Systems: Scoreboard in Basement GYM Years: 2009 Systems: Telephone System Years: 2007 Systems: Motor-starters (partially)- Years: 2008. Systems: Emergency & Exit light (partially - battery back-up) Years: 2002 Systems: Electrical panel-boards, motor-starters for Boiler Equipment Years: 1999 Systems: Security (exterior) lighting (partially) Years: 1999, 2008 Systems: LAN System Years: 2003 Systems: Emergency lighting System (Service Switch, Panel-boards) Years: 1996 Systems: Intrusion Alarm System Years: 1994 Systems: Interior Lighting Years: 1998 Systems: Intrusion Alarm System Years: 1993
Type of Service	Below Ground

**Priority Condition**

Condition Description	Component Affected	Location Description	Person(s) Notified
Water penetration into Electrical meter room.	Electrical Service Equipment	Basement - Electrical meter room	Luis Seda, Fireman

**Inspection**

Question	Response
<b>ELECTRICAL</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance	Basement
<b>HOUSE LIGHTING</b>	
Instance on Basement	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement	Inspected
<b>Pendant Mounted</b>	
Instance on Basement	Does not exist
<b>Recessed Mounted</b>	
Instance on Basement	Does not exist
<b>Surface Mounted</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K035**

Question	Response
<b>AUDITORIUM</b>	
<b>HOUSE LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement	Inspected
<b>Pendant Mounted</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Basement	Does not exist
<b>Surface Mounted</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>LOCAL SOUND SYSTEM</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>PROJECTION SYSTEM</b>	
Instance on Basement	Does not exist
<b>THEATER LIGHTING SYSTEM</b>	
Instance on Basement	Inspected
<b>Dimming System</b>	
Instance on Basement	Does not exist
<b>Theater Lighting</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	24
Quantity Uom	EACH

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K035**

Question	Response
<b>AUDITORIUM</b>	
<b>THEATER LIGHTING SYSTEM</b>	
<b>Theater Lighting</b>	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	
Condition	Inspected
Deficiency	3- Fair
<b>CAFETERIA</b>	
Instance	Inspected
Instance	Basement - Students
Instance	Basement - Room B15 (Teachers)
<b>LIGHTING</b>	
Instance on Basement - Students	Inspected
Instance on Basement - Room B15 (Teachers)	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement - Students	Inspected
Instance on Basement - Room B15 (Teachers)	Inspected
<b>Pendant Mounted</b>	
Instance on Basement - Students	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Basement - Room B15 (Teachers)	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Basement - Students	Does not exist
Instance on Basement - Room B15 (Teachers)	Does not exist
<b>Surface Mounted</b>	
Instance on Basement - Students	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Basement - Room B15 (Teachers)	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Basement - Students	Does not exist
Instance on Basement - Room B15 (Teachers)	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement - Students	Does not exist
Instance on Basement - Room B15 (Teachers)	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on Basement - Students	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Basement - Room B15 (Teachers)	Does not exist
<b>CITY FIRE ALARM SYSTEM</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K035**

<b>Question</b>	<b>Response</b>
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	Inspected
<b>LIGHTING</b>	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SMART BOARD</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>COMPUTER LAB</b>	Inspected
Instance	Room 119
Has LAN/Modem access	Yes
Power Panel?	No
<b>LIGHTING</b>	
Instance on Room 119	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 119	Inspected
<b>Pendant Mounted</b>	
Instance on Room 119	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K035**

<b>Question</b>	<b>Response</b>
<b>COMPUTER LAB</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Recessed Mounted</b>	
Instance on Room 119	Does not exist
<b>Surface Mounted</b>	
Instance on Room 119	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 119	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 119	Does not exist
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room 119	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	Inspected
<b>BATTERY PACK</b>	Inspected
Condition	3- Fair
Deficiency	BATTERY NOT OPERATIONAL
Deficiency Location/Instance	Basement corridor - next to room B16
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BATTERY
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Non Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	Inspected
<b>BATTERY PACK</b>	Inspected
Condition	3- Fair
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	3rd floor - Exit 3/4
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Non Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Corridor - 2nd floor, next to room 210, Auditorium
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K035**

<b>Question</b>	<b>Response</b>
<b>EXIT/EMERGENCY LIGHT</b>	Does not exist
<b>FIRE ALARM SYSTEM</b>	Inspected
<b>AREA SMOKE DETECTOR</b>	Does not exist
<b>BELL/HORN</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>DUCT SMOKE DETECTOR</b>	Does not exist
<b>ELEVATOR RECALL</b>	Does not exist
<b>FAN SHUTDOWN CONTROL</b>	Does not exist
<b>FIRE ALARM DIGITAL COMMUNICATOR</b>	Does not exist
<b>FUSED CUTOFF PANEL</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>HEAT DETECTOR</b>	Does not exist
<b>MAGNETIC DOOR HOLDER CONTACTOR</b>	Does not exist
<b>MAIN PANEL</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Does not exist
<b>Fire Alarm Control Panel (Standard)</b>	Inspected
Instance	Boiler room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	FACB
Capacity/Size	6 circuits
Installation Year	1966
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	113,000
Quantity Uom	S.F.
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MANUAL PULL STATION</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>REMOTE ANNUNCIATOR</b>	Inspected
<b>Display Monitor</b>	Does not exist
<b>Panel</b>	Does not exist
<b>Printer</b>	Does not exist
<b>Punch Register</b>	Inspected
Condition	5- Poor
Deficiency	REGISTER NOT OPERATIONAL
Deficiency Location/Instance	Custodian Office - Room B17
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SPRINKLER FLOW/AIR PRESSURE SWITCH</b>	Inspected
Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K035**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>SPRINKLER FLOW/AIR PRESSURE SWITCH</b>	
Deficiency	No deficiencies recorded
<b>STROBE</b>	Does not exist
<b>SUB-PANEL</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Does not exist
<b>Fire Alarm Control Panel (Standard)</b>	Inspected
Instance	Boiler room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Punch Register Control Panel
Capacity/Size	2 circuits
Installation Year	1966
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Boiler room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	No ID
Capacity/Size	2 circuits
Installation Year	1966
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PANEL ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>TAMPER FLOW SWITCH/CHAIN</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GROUNDING SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K035**

<b>Question</b>	<b>Response</b>
<b>GYMNASIUM</b>	
Instance	Basement
Instance	2nd floor
<b>LIGHTING</b>	
Instance on Basement	Inspected
Instance on 2nd floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement	Does not exist
Instance on 2nd floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Basement	Inspected
Instance on 2nd floor	Inspected
<b>Pendant Mounted</b>	
Instance on Basement	Does not exist
Instance on 2nd floor	Does not exist
<b>Recessed Mounted</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on Basement	Does not exist
Instance on 2nd floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement	Does not exist
Instance on 2nd floor	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd floor	Does not exist
<b>SCOREBOARD</b>	
Instance on Basement	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on 2nd floor	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K035**

<b>Question</b>	<b>Response</b>
<b>GYMNASIUM</b>	
<b>THEATER LIGHTING SYSTEM</b>	
Instance on Basement	Does not exist
Instance on 2nd floor	Does not exist
<b>INTERCOM SYSTEM</b>	Does not exist
<b>KITCHEN/WARMING PANTRY</b>	Inspected
Instance	Basement - Room B9
<b>LIGHTING</b>	
Instance on Basement - Room B9	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement - Room B9	Inspected
<b>Pendant Mounted</b>	
Instance on Basement - Room B9	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Basement - Room B9	Does not exist
<b>Surface Mounted</b>	
Instance on Basement - Room B9	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on Basement - Room B9	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement - Room B9	Does not exist
<b>LAN</b>	Inspected
<b>LOCAL DISTRIBUTION FRAME (I/LDF)</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>MAIN EQUIPMENT RACK (MDF)</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>LIBRARY</b>	Inspected
Instance	Room 112
Has LAN/Modem access	Yes
Instance	Room 328
Has LAN/Modem access	Yes
<b>LIGHTING</b>	
Instance on Room 112	Inspected
Instance on Room 328	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 112	Inspected
Instance on Room 328	Inspected
<b>Pendant Mounted</b>	
Instance on Room 112	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 328	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 112	Does not exist
Instance on Room 328	Does not exist
<b>Surface Mounted</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K035**

Question	Response
<b>LIBRARY</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Instance on Room 112	Does not exist
Instance on Room 328	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 112	Does not exist
Instance on Room 328	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 112	Does not exist
Instance on Room 328	Does not exist
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room 112	Does not exist
Instance on Room 328	Does not exist
<b>SMART BOARD</b>	
Instance on Room 112	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 328	Does not exist
<b>LIGHTING - SECURITY LIGHTS</b>	
Condition	Inspected
Replacement Quantity	3- Fair
Replacement Uom	16
Deficiency	EACH
Deficiency Location/Instance	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	Main Entrance
Quantity Uom	2
Potential Action	EACH
Urgency of Action	REPLACE-UPGRADE
Purpose of Action	PRIORITY 1
Violations	LEVEL 3
Deficiency	No violations recorded
Deficiency Location/Instance	LIGHTING FIXTURE PHOTOCCELL NOT OPERATIONAL
Deficiency Quantity	Perimeter lighting
Quantity Uom	4
Potential Action	EACH
Urgency of Action	REPLACE
Purpose of Action	PRIORITY 4
Violations	LEVEL 3
Violations	No violations recorded
<b>LIGHTNING PROTECTION</b>	
	Does not exist
<b>LOCKER ROOM</b>	
Instance on Room inside 2nd floor GYM	Inspected
Alternative Use	Yes
<b>LIGHTING</b>	
Instance on Room inside 2nd floor GYM	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room inside 2nd floor GYM	Inspected
<b>Pendant Mounted</b>	
Instance on Room inside 2nd floor GYM	Does not exist
<b>Recessed Mounted</b>	
Instance on Room inside 2nd floor GYM	Does not exist
<b>Surface Mounted</b>	
Instance on Room inside 2nd floor GYM	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K035**

Question	Response
<b>LOCKER ROOM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on Room inside 2nd floor GYM	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room inside 2nd floor GYM	Inspected
<b>Pendant Mounted</b>	
Instance on Room inside 2nd floor GYM	Does not exist
<b>Recessed Mounted</b>	
Instance on Room inside 2nd floor GYM	Does not exist
<b>Surface Mounted</b>	
Instance on Room inside 2nd floor GYM	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Mechanical spaces
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MULTIPURPOSE ROOM</b>	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>FUSED DISCONNECT SWITCH TYPE</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Boiler room, FAN rooms.
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>FUSED KNIFE SWITCH TYPE</b>	Does not exist
<b>FUSED TOGGLE SWITCH TYPE</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Electrical meter room
Deficiency Quantity	1
Quantity Uom	EACH

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K035**

<b>Question</b>	<b>Response</b>
<b>PANEL BOARD</b>	
<b>FUSED TOGGLE SWITCH TYPE</b>	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	
Inspected	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Corridors, Gyms, Kitchen, Auditorium.
Deficiency Quantity	22
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>PUBLIC ADDRESS SYSTEM</b>	
Inspected	Inspected
Instance	General Office - Room 115
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Casey
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Corridors, Offices, Classrooms.
Deficiency Quantity	35
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	General Office - Room 115
Deficiency Quantity	113,000
Quantity Uom	S.F.
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SCIENCE DEMO ROOM</b>	
Does not exist	Does not exist
<b>SCIENCE LAB</b>	
Instance on Room 201	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Room 201	Does not exist
<b>EMERGENCY SHUT-OFF POWER</b>	
Instance on Room 201	Does not exist
<b>LIGHTING</b>	
Instance on Room 201	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 201	Inspected
<b>Pendant Mounted</b>	
Instance on Room 201	Inspected
Instance Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K035**

Question	Response
<b>SCIENCE LAB</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 201	Does not exist
<b>Surface Mounted</b>	
Instance on Room 201	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 201	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 201	Does not exist
<b>POWER SUPPLY</b>	
Instance on Room 201	Does not exist
<b>PROJECTION SYSTEM</b>	
Instance on Room 201	Does not exist
<b>SMART BOARD</b>	
Instance on Room 201	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>SCIENCE PREP ROOM</b>	Does not exist
<b>SECURITY</b>	Inspected
<b>INTRUSION ALARM</b>	Inspected
<b>Central Control Panel</b>	Inspected
Instance	Custodian Office - Room B17
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista 40
Deficiency	No deficiencies recorded
<b>Infrared Sensor</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Ultrasonic Sensor</b>	Does not exist
<b>IPDVS/CCTV SYSTEM</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>SERVICE SWITCH</b>	Inspected
Instance	Electrical meter room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Gallagher Switchboard Co.
EquipmentId	Main Service Switch

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K035**

<b>Question</b>	<b>Response</b>
<b>SERVICE SWITCH</b>	
Capacity/Size	1600 Amps.
Source of Capacity/Size	Fuse Size
Installation Year	1966
Source of Installation Year	Documented
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCH NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SWIMMING POOL</b>	Does not exist
<b>SWITCHBOARD</b>	Inspected
Water Penetration In Electrical Room?	Yes
Number of Spares	0
<b>AIR CIRCUIT BREAKER TYPE</b>	Does not exist
<b>FUSED DISCONNECT SWITCH TYPE</b>	Inspected
Instance	Electrical meter room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Gallagher Switchboard Co.
EquipmentId	MDP#1, MDP#2, MDP#3
Capacity/Size	1600 Amps total, 3 sections
Source of Capacity/Size	Service Switch Fuse Size
Installation Year	1966
Source of Installation Year	Documented
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>FUSED KNIFE SWITCH TYPE</b>	Does not exist
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	Does not exist
<b>TELEPHONE</b>	Inspected
<b>PBX/INTERCOM</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>STANDARD</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K035**

<b>Question</b>	<b>Response</b>
<b>TELEPHONE</b>	
<b>STANDARD</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>TOILET ROOM - STAFF</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TRANSFORMER</b>	Does not exist
<b>TV SYSTEM</b>	Inspected
Cable System Exist?	Yes
Operational?	Yes
Master Antenna System Exist?	No
<b>MAIN EQUIPMENT RACK</b>	Does not exist