

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K068

School: **I.S. 68 - BROOKLYN, 956 EAST 82 STREET, BROOKLYN, NY, 11236**

InspectionId	Inspection Type	Time In	Last Edited
1294118	ELECTRICAL	2009-05-07 10:50AM	2009-05-29 04:28PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Gym scoreboard Years: 2008 Systems: Lighting in Library Years: 2007 Systems: Fire alarm Sub panel Years: 2006 Systems: CCTV Years: 2006 Systems: Exterior security lights Years: 2003 Systems: Local sound, projection system in Auditorium, Cafeteria Years: 2002 Systems: LAN, Emergency Exit lighting (partially) Years: 2002 Systems: Telephone/ PBX- Intercom/ Standard Years: 2001 Systems: Intrusion alarm Years: 1997-1998 Systems: Switch board for Emergency/ Exit lighting Years: 2002 Systems: Lighting (partial) and other misc. work for Science, Demo and Prep room. Room 304, 302, 204 Years: 2005

Priority Condition

No condition recorded

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	1st Floor
House Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	24
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K068

Question	Response
AUDITORIUM	
House Lighting	
Lighting Fixture - Incandescent	
Recessed Mounted	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Local Sound System	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Projection System	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Theater Lighting System	
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Inspected
Instance Condition	5- Poor
Deficiency	DIMMING RACK NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Theater Lighting	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	103
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
AUXILIARY SIGNAL/BELL SYSTEM	
	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K068

Question	Response
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	3- Fair
Replacement Quantity	154,000
Replacement Uom	S.F.
Deficiency	INDICATOR PANEL NOT OPERATIONAL
Deficiency Location/Instance	Boiler room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE PANEL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
CAFETERIA	
	Inspected
Instance	Basement (students)
Instance	Basement (Teachers)
Lighting	
Instance on Basement (students)	Inspected
Instance on Basement (Teachers)	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement (students)	Inspected
Instance on Basement (Teachers)	Inspected
Pendant Mounted	
Instance on Basement (students)	Does not exist
Instance on Basement (Teachers)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Basement (students)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	80
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Basement (Teachers)	Does not exist
Surface Mounted	
Instance on Basement (students)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Basement (Teachers)	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K068

Question	Response
CAFETERIA	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Basement (students)	Does not exist
Instance on Basement (Teachers)	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement (students)	Does not exist
Instance on Basement (Teachers)	Does not exist
Local Sound System	
Instance on Basement (students)	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Basement (Teachers)	Does not exist
CAFETERIA/MULTIPURPOSE ROOM	Does not exist
CITY FIRE ALARM SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1,330
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Does not exist	
Surface Mounted	
Inspected	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	194
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K068

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
	Does not exist
Lighting Fixture - Incandescent	
Pendant Mounted	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	104
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	22
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	178
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
COMPUTER LAB	
Instance	Room 316
Has LAN/Modem access	Yes
Power Panel?	No
Instance	Room 230
Has LAN/Modem access	Yes
Power Panel?	Yes
Lighting	
Instance on Room 316	Inspected
Instance on Room 230	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 316	Inspected
Instance on Room 230	Inspected
Pendant Mounted	
Instance on Room 316	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K068

Question	Response
COMPUTER LAB	
Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Deficiency Quantity	27
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 230	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	27
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room 316	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 230	Does not exist
Surface Mounted	
Instance on Room 316	Does not exist
Instance on Room 230	Does not exist
Lighting Fixture - HID	
Instance on Room 316	Does not exist
Instance on Room 230	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 316	Does not exist
Instance on Room 230	Does not exist
Raceway With Receptacles	
Instance on Room 316	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 230	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
ELECTRIC SERVICE SWITCH	
Instance	Inspected
Instance	Electrical room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co.
Model	Royal Switchboard Co
EquipmentId	Main SW BD 1

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K068

Question	Response
ELECTRIC SERVICE SWITCH	
Capacity/Size	1200 Amps
Installation Year	1963
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Electrical room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co
Model	Royal Switchboard Co
EquipmentId	Main SW BD 2
Capacity/Size	2000 Amps
Installation Year	1963
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Electrical room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Connected To Emergency Generator System	Does not exist
Connected To Emergency Light/Exit Light Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Relay Test Switch	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Does not exist
Connected To Emergency Generator System	Does not exist
Connected To Emergency Light/Exit Light Panel	Inspected
Condition	3- Fair
Deficiency	FIXTURE POORLY MOUNTED
Deficiency Location/Instance	Basement corridor by stair E
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K068

Question	Response
EXIT LIGHT	
Connected To Emergency Light/Exit Light Panel	
Violations	No violations recorded
FIRE ALARM SYSTEM	Inspected
Replacement Quantity	154,000
Replacement Uom	S.F.
Area Smoke Detector	Does not exist
Bell/Horn	Inspected
Condition	4- Between Fair and Poor
Deficiency	BELL/HORN NOT OPERATIONAL
Deficiency Location/Instance	gym, outside Room 242, by Room 316
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Duct Smoke Detector	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Elevator Recall	Does not exist
Fan Shutdown Control	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not exist
Fused Cutout Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Heat Detector	Does not exist
Magnetic Door Holder Contactor	Does not exist
Main Panel	Inspected
Bell At Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Does not exist
Fire Alarm Control Panel (Standard)	Inspected
Instance	Boiler room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Fire Alarm
Capacity/Size	6 gong bell circuits
Installation Year	1963
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Manual Pull Station	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K068

Question	Response
FIRE ALARM SYSTEM	
Remote Annunciator	
Display Monitor	Does not exist
Panel	Does not exist
Printer	Does not exist
Punch Register	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Sprinkler Flow/Air Pressure Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Strobe	Does not exist
Sub-Panel	Inspected
Bell At Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Boiler room
Instance Condition	5- Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	EST-2
EquipmentId	Smoke Alarm Control Panel
Capacity/Size	4 zones connected
Installation Year	2006
Deficiency	PANEL NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fire Alarm Control Panel (Standard)	Inspected
Instance	Boiler room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Sprinkler Alarm Panel
Capacity/Size	2 circuits
Installation Year	1963
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Boiler room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Register Control Board
Capacity/Size	2 circuits

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K068

Question	Response
FIRE ALARM SYSTEM	
Sub-Panel	
Fire Alarm Control Panel (Standard)	
Installation Year	1963
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Tamper Flow Switch/Chain	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	
Condition	Inspected
Instance	1st Floor (Boys)
Instance	1st Floor (Girls)
Lighting	
Instance on 1st Floor (Boys)	Inspected
Instance on 1st Floor (Girls)	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor (Boys)	Does not exist
Instance on 1st Floor (Girls)	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor (Boys)	Inspected
Instance on 1st Floor (Girls)	Inspected
Pendant Mounted	
Instance on 1st Floor (Boys)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 1st Floor (Girls)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K068

Question	Response
GYMNASIUM	
Lighting	
Lighting Fixture - HID	
Pendant Mounted	
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 1st Floor (Boys)	Does not exist
Instance on 1st Floor (Girls)	Does not exist
Surface Mounted	
Instance on 1st Floor (Boys)	Does not exist
Instance on 1st Floor (Girls)	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor (Boys)	Does not exist
Instance on 1st Floor (Girls)	Does not exist
Local Sound System	
Instance on 1st Floor (Boys)	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 1st Floor (Girls)	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Scoreboard	
Instance on 1st Floor (Boys)	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on 1st Floor (Girls)	Does not exist
Theater Lighting System	
Instance on 1st Floor (Boys)	Does not exist
Instance on 1st Floor (Girls)	Does not exist
INTERCOM SYSTEM	
	Does not exist
KITCHEN/WARMING PANTRY	
	Inspected
Lighting	
	Inspected
Lighting Fixture - Fluorescent	
	Does not exist
Lighting Fixture - HID	
	Does not exist
Lighting Fixture - Incandescent	
	Inspected
Pendant Mounted	
	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K068

Question	Response
KITCHEN/WARMING PANTRY	
Lighting	
Lighting Fixture - Incandescent	
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	65
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	Does not exist
LAN	Inspected
Local Distribution Frame (I/LDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	Room 232
Has LAN/Modem access	Yes
Lighting	
Instance on Room 232	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 232	Inspected
Pendant Mounted	
Instance on Room 232	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 232	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 232	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room 232	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 232	Does not exist
Raceway With Receptacles	
Instance on Room 232	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K068

Question	Response
LIGHTING - EXTERIOR SECURITY	Inspected
Condition	2- Between Good and Fair
Replacement Quantity	33
Replacement Uom	EACH
Deficiency	LIGHTING FIXTURE PHOTOCCELL NOT OPERATIONAL
Deficiency Location/Instance	walls facing E82 st, E 81 st and playground.
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
LIGHTNING PROTECTION	Does not exist
LOCKER ROOM/SHOWER ROOM	Inspected
Instance	Room 146(Boys)
Alternative Use	Yes
Instance	Room 160 (Girls)
Alternative Use	Yes
Lighting	
Instance on Room 146(Boys)	Not required
Instance on Room 160 (Girls)	Not required
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Fan Room above Auditorium, Girls' gym, Room B-19
Deficiency Quantity	28
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Boiler room, Fan room above Auditorium, Room B-45, B-17
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Electrical room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K068

Question	Response
PANEL BOARD	
Molded Case Circuit Breaker Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	All corridors (including basement), gym, RoomB-8,B-6, Room 212
Deficiency Quantity	28
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	
Replacement Quantity	Inspected
Replacement Uom	154,000
Instance	S.F.
Instance Condition	General office
Instance Quantity	3- Fair
Instance Quantity Uom	1
Model	EACH
Deficiency	Standard system Corporation
Deficiency Location/Instance	CLOCK NOT OPERATIONAL
Deficiency Quantity	classrooms, corridors, offices etc
Quantity Uom	12
Potential Action	EACH
Urgency of Action	REPLACE
Purpose of Action	PRIORITY 3
Violations	LEVEL 2
Deficiency	No violations recorded
Deficiency Location/Instance	SPEAKER NOT OPERATIONAL
Deficiency Quantity	Room- 109
Quantity Uom	1
Potential Action	EACH
Urgency of Action	REPLACE
Purpose of Action	PRIORITY 5
Violations	LEVEL 2
Deficiency	No violations recorded
SCIENCE DEMO ROOM	
Instance	Inspected
Has LAN/Modem access	Room 104, 204, 301
Power Panel?	Yes
Alternative Use	No
Instance	Yes
Has LAN/Modem access	Room 201
Power Panel?	Yes
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on Room 104, 204, 301	Does not exist
Instance on Room 201	Does not exist
Emergency Shut-Off Power	
Instance on Room 104, 204, 301	Does not exist
Instance on Room 201	Does not exist
Lighting	
Instance on Room 104, 204, 301	Not required
Instance on Room 201	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 201	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K068

Question	Response
SCIENCE DEMO ROOM	
Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Instance on Room 201	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room 201	Does not exist
Surface Mounted	
Instance on Room 201	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Room 201	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 201	Does not exist
Power Supply	
Instance on Room 104, 204, 301	Does not exist
Instance on Room 201	Does not exist
SCIENCE LAB	
Instance	Room 304
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	Room 101
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on Room 304	Does not exist
Instance on Room 101	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 304	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 101	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded

NYC Department of Education
 Building Condition Assessment Survey 2008-2009

Electrical Inspection

K068

Question	Response
SCIENCE LAB	
Lighting	
Instance on Room 304	Inspected
Instance on Room 101	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 304	Inspected
Instance on Room 101	Inspected
Pendant Mounted	
Instance on Room 304	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	23
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 101	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	32
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room 304	Does not exist
Instance on Room 101	Does not exist
Surface Mounted	
Instance on Room 304	Does not exist
Instance on Room 101	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Room 304	Does not exist
Instance on Room 101	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 304	Inspected
Instance on Room 101	Does not exist
Pendant Mounted	
Instance on Room 304	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 304	Does not exist
Surface Mounted	

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K068

Question	Response
SCIENCE LAB	
Lighting	
Lighting Fixture - Incandescent	
Surface Mounted	
Instance on Room 304	Does not exist
Power Supply	
Instance on Room 304	Inspected
Instance on Room 101	Does not exist
Instructor Unit	
Instance on Room 304	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 304	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Student Unit	
Instance on Room 304	Does not exist
SCIENCE PREP ROOM	
Instance	Inspected
Has LAN/Modem access	Room 302
Power Panel?	Yes
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on Room 302	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 302	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Lighting	
Instance on Room 302	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 302	Inspected
Pendant Mounted	
Instance on Room 302	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 302	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on Room 302	Does not exist
Lighting Fixture - HID	
Instance on Room 302	Does not exist
Lighting Fixture - Incandescent	

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K068

Question	Response
SCIENCE PREP ROOM	
Lighting	
Lighting Fixture - Incandescent	
Instance on Room 302	Does not exist
Power Supply	
Instance on Room 302	Does not exist
SECURITY	Inspected
Replacement Quantity	154,000
Replacement Uom	S.F.
Intrusion Alarm	Inspected
Central Control Panel	Inspected
Instance	Custodian office
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Ademco/ Vista 128B
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	Does not exist
IPDVS/CCTV System	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
SWIMMING POOL	Does not exist
SWITCHBOARD	Inspected
Air Circuit Breaker Type	Does not exist
Fused Disconnect Switch Type	Inspected
Instance	Electrical room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co
EquipmentId	Main Switch Board -1
Capacity/Size	812 Amps total, 3 section
Installation Year	1963
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical room
Instance Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K068

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	General Electric
EquipmentId	DPEM-IS68
Capacity/Size	400 Amps total, 1 section
Installation Year	2002
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Does not exist
TELEPHONE	
PBX/Intercom	Inspected
Condition	2- Between Good and Fair
Deficiency	TELEPHONE MISSING
Deficiency Location/Instance	Teachers' Cafeteria, Auditorium -Stage
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL TELEPHONE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Standard	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K068

Question	Response
TOILET ROOM - STAFF	
Lighting	
Lighting Fixture - Incandescent	
Surface Mounted	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	22
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable Service	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Main Equipment Rack	Does not exist
Master Antenna System	Does not exist