

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

School: **I.S. 68 - BROOKLYN, 956 EAST 82 STREET, BROOKLYN, NY, 11236**

InspectionId	Inspection Type	Time In	Last Edited
2140072	ELECTRICAL	2011-01-11 08:37AM	2011-05-09 05:50AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	<p>Systems: Fluorescent light fixtures in some Classrooms, Offices, Staff Toilets and Locker Rooms</p> <p>Years: 2010</p> <p>Systems: Auditorium - Stage Lighting, Dimming System, Local Sound System, Projection System</p> <p>Years: 2010</p> <p>Systems: Panel-boards in Kitchen, Auditorium</p> <p>Years: 2010</p> <p>Systems: Scoreboard in GYM</p> <p>Years: 2008</p> <p>Systems: Electrical installation in Library (Lighting, Receptacles)</p> <p>Years: 2007</p> <p>Systems: AC System in Auditorium - FAN Shutdown control (FA sub-panel, Duct Smoke Detectors)</p> <p>Years: 2006</p> <p>Systems: Security CCTV System</p> <p>Years: 2006</p> <p>Systems: Electrical installation in Science Rooms (partially - Room 204, 302, 304)</p> <p>Years: 2005</p> <p>Systems: Security (exterior) lighting</p> <p>Years: 2003</p> <p>Systems: LAN System</p> <p>Years: 2002</p> <p>Systems: Telephone System</p> <p>Years: 2002</p> <p>Systems: Emergency Lighting Panel, Emergency & Exit Light Fixtures (Battery pack).</p> <p>Years: 2002</p> <p>Systems: Intrusion Alarm System</p> <p>Years: 2000</p> <p>Systems: Fluorescent Lighting in Student's Toilet, Stairs (Partially)</p> <p>Years: 1995</p> <p>Type of Service: Below Ground</p>

Priority Condition

Condition Description	Component Affected	Location Description	Person(s) Notified
Public Address Speakers not operational	PA System	Basement - Student Cafeteria.	Bernard Young, Fireman

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	1st floor
HOUSE LIGHTING	
Instance on 1st floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on 1st floor	Does not exist
Lighting Fixture - HID	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

Question	Response
AUDITORIUM	
HOUSE LIGHTING	
Lighting Fixture - HID	
Instance on 1st floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	23
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
LOCAL SOUND SYSTEM	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
PROJECTION SYSTEM	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	No deficiencies recorded
THEATER LIGHTING SYSTEM	
Instance on 1st floor	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

Question	Response
AUDITORIUM	
THEATER LIGHTING SYSTEM	
Dimming System	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA	
Instance	Basement - Student Cafeteria
Instance	Room B54 - Teachers Cafeteria
LIGHTING	
Instance on Basement - Student Cafeteria	Inspected
Instance on Room B54 - Teachers Cafeteria	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement - Student Cafeteria	Inspected
Instance on Room B54 - Teachers Cafeteria	Inspected
Pendant Mounted	
Instance on Basement - Student Cafeteria	Does not exist
Instance on Room B54 - Teachers Cafeteria	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Basement - Student Cafeteria	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	80
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room B54 - Teachers Cafeteria	Does not exist
Surface Mounted	
Instance on Basement - Student Cafeteria	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room B54 - Teachers Cafeteria	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	8
Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

Question	Response
CAFETERIA	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Basement - Student Cafeteria	Does not exist
Instance on Room B54 - Teachers Cafeteria	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement - Student Cafeteria	Does not exist
Instance on Room B54 - Teachers Cafeteria	Does not exist
LOCAL SOUND SYSTEM	
Instance on Basement - Student Cafeteria	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room B54 - Teachers Cafeteria	Does not exist
CITY FIRE ALARM SYSTEM	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
	Inspected
LIGHTING	
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Pendant Mounted	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1,150
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	52
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Inspected	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	150
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	
Inspected	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	65
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Inspected	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	24
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Inspected	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	60
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SMART BOARD	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
SMART BOARD	
Condition	1- Good
Deficiency	No deficiencies recorded
COMPUTER LAB	
Instance	Inspected
Instance	Room 230
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room 316
Has LAN/Modem access	Yes
Power Panel?	No
LIGHTING	
Instance on Room 230	Inspected
Instance on Room 316	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 230	Inspected
Instance on Room 316	Inspected
Pendant Mounted	
Instance on Room 230	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	27
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 316	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	27
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room 230	Does not exist
Instance on Room 316	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on Room 230	Does not exist
Instance on Room 316	Does not exist
Lighting Fixture - HID	
Instance on Room 230	Does not exist
Instance on Room 316	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

Question	Response
COMPUTER LAB	
LIGHTING	
Lighting Fixture - Incandescent	
Instance on Room 230	Does not exist
Instance on Room 316	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 230	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 316	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
BATTERY PACK	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
BATTERY PACK	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
AREA SMOKE DETECTOR	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
BELL/HORN	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
DUCT SMOKE DETECTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
ELEVATOR RECALL	Does not exist
FAN SHUTDOWN CONTROL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
FIRE ALARM DIGITAL COMMUNICATOR	Does not exist
FUSED CUTOFF PANEL	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
HEAT DETECTOR	Does not exist
MAGNETIC DOOR HOLDER CONTACTOR	Does not exist
MAIN PANEL	Inspected
Bell At Panel	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

Question	Response
FIRE ALARM SYSTEM	
MAIN PANEL	
Bell At Panel	
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Does not exist
Fire Alarm Control Panel (Standard)	Inspected
Instance	Boiler room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Fire Alarm
Capacity/Size	6 circuits
Installation Year	1963
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	154,000
Quantity Uom	S.F.
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MANUAL PULL STATION	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
REMOTE ANNUNCIATOR	Inspected
Display Monitor	Does not exist
Panel	Does not exist
Printer	Does not exist
Punch Register	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
SPRINKLER FLOW/AIR PRESSURE SWITCH	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
STROBE	Does not exist
SUB-PANEL	Inspected
Bell At Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Boiler Room
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards
Model	EST-2
EquipmentId	Smoke Alarm Control Panel
Capacity/Size	4 zone
Installation Year	2006
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Inspected
Instance	Auditorium - Stage

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

Question	Response
FIRE ALARM SYSTEM	
SUB-PANEL	
Fire Alarm Control Panel (Standard)	
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Smoke Detector System
Capacity/Size	4 circuits
Installation Year	1963
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Sprinkler Alarm Board
Capacity/Size	2 circuits
Installation Year	1963
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Register Control Board
Capacity/Size	2 circuits
Installation Year	1963
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TAMPER FLOW SWITCH/CHAIN	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

Question	Response
GYMNASIUM	Inspected
Instance	1st floor
LIGHTING	
Instance on 1st floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st floor	Does not exist
Lighting Fixture - HID	
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 1st floor	Does not exist
Surface Mounted	
Instance on 1st floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 1st floor	Does not exist
Surface Mounted	
Instance on 1st floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 1st floor	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SCOREBOARD	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
THEATER LIGHTING SYSTEM	
Instance on 1st floor	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

Question	Response
INTERCOM SYSTEM	Does not exist
KITCHEN/WARMING PANTRY	Inspected
Instance	Basement
LIGHTING	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Does not exist
Lighting Fixture - HID	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Does not exist
Recessed Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	62
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on Basement	Does not exist
LAN	Inspected
LOCAL DISTRIBUTION FRAME (I/LDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MAIN EQUIPMENT RACK (MDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	Room 232
Has LAN/Modem access	Yes
LIGHTING	
Instance on Room 232	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 232	Inspected
Pendant Mounted	
Instance on Room 232	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 232	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 232	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room 232	Does not exist
Lighting Fixture - Incandescent	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

Question	Response
LIBRARY	
LIGHTING	
Lighting Fixture - Incandescent	
Instance on Room 232	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 232	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
SMART BOARD	
Instance on Room 232	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
LIGHTING - SECURITY LIGHTS	
	Inspected
Condition	2- Between Good and Fair
Replacement Quantity	33
Replacement Uom	EACH
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Roof light fixtures
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
LIGHTNING PROTECTION	
	Does not exist
LOCKER ROOM	
Instance on Room 146 (Boys)	Inspected
Alternative Use	Yes
Instance on Room 160 (Girls)	Inspected
Alternative Use	Yes
LIGHTING	
Instance on Room 146 (Boys)	Inspected
Instance on Room 160 (Girls)	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 146 (Boys)	Inspected
Instance on Room 160 (Girls)	Inspected
Pendant Mounted	
Instance on Room 146 (Boys)	Does not exist
Instance on Room 160 (Girls)	Does not exist
Recessed Mounted	
Instance on Room 146 (Boys)	Does not exist
Instance on Room 160 (Girls)	Does not exist
Surface Mounted	
Instance on Room 146 (Boys)	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 160 (Girls)	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room 146 (Boys)	Does not exist
Instance on Room 160 (Girls)	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 146 (Boys)	Inspected
Instance on Room 160 (Girls)	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

Question	Response
LOCKER ROOM	
LIGHTING	
Lighting Fixture - Incandescent	
Pendant Mounted	
Instance on Room 146 (Boys)	Does not exist
Instance on Room 160 (Girls)	Does not exist
Recessed Mounted	
Instance on Room 146 (Boys)	Does not exist
Instance on Room 160 (Girls)	Does not exist
Surface Mounted	
Instance on Room 146 (Boys)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 160 (Girls)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	26
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Mechanical spaces
Deficiency Quantity	35
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
FUSED DISCONNECT SWITCH TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Mechanical spaces
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED KNIFE SWITCH TYPE	Does not exist
FUSED TOGGLE SWITCH TYPE	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

Question	Response
PANEL BOARD	
FUSED TOGGLE SWITCH TYPE	
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Room B35
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MOLDED CASE CIRCUIT BREAKER TYPE	
Condition	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Corridors, GYM, Cafeteria, Mechanical spaces.
Deficiency Quantity	24
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	
Condition	Inspected
Instance	Room 135 - Main Office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Standard System Corp.
Deficiency	SPEAKER NOT OPERATIONAL
Deficiency Location/Instance	Basement - Student Cafeteria
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Room 135 - Main Office
Deficiency Quantity	154,000
Quantity Uom	S.F.
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SCIENCE DEMO ROOM	
Instance on Room 104	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 204	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 301	Inspected
Has LAN/Modem access	Yes
Power Panel?	No

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

Question	Response
SCIENCE DEMO ROOM	
Alternative Use	No
Instance on Room 201	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 104	Does not exist
Instance on Room 204	Does not exist
Instance on Room 301	Does not exist
Instance on Room 201	Does not exist
EMERGENCY SHUT-OFF POWER	
Instance on Room 104	Does not exist
Instance on Room 204	Does not exist
Instance on Room 301	Does not exist
Instance on Room 201	Does not exist
LIGHTING	
Instance on Room 104	Inspected
Instance on Room 204	Inspected
Instance on Room 301	Inspected
Instance on Room 201	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 104	Inspected
Instance on Room 204	Inspected
Instance on Room 301	Inspected
Instance on Room 201	Inspected
Pendant Mounted	
Instance on Room 104	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	21
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 204	Does not exist
Instance on Room 301	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	22
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 201	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

Question	Response
SCIENCE DEMO ROOM	
LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room 104	Does not exist
Instance on Room 204	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 301	Does not exist
Instance on Room 201	Does not exist
Surface Mounted	
Instance on Room 104	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 204	Does not exist
Instance on Room 301	Does not exist
Instance on Room 201	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Room 104	Does not exist
Instance on Room 204	Does not exist
Instance on Room 301	Does not exist
Instance on Room 201	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 104	Does not exist
Instance on Room 204	Does not exist
Instance on Room 301	Does not exist
Instance on Room 201	Does not exist
POWER SUPPLY	
Instance on Room 104	Does not exist
Instance on Room 204	Does not exist
Instance on Room 301	Does not exist
Instance on Room 201	Does not exist
PROJECTION SYSTEM	
Instance on Room 104	Does not exist
Instance on Room 204	Does not exist
Instance on Room 301	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

Question	Response
SCIENCE DEMO ROOM	
PROJECTION SYSTEM	
Instance on Room 201	Does not exist
SMART BOARD	
Instance on Room 104	Does not exist
Instance on Room 204	Does not exist
Instance on Room 301	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 201	Does not exist
SCIENCE LAB	
Instance on Room 101	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 304	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 101	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 304	Does not exist
EMERGENCY SHUT-OFF POWER	
Instance on Room 101	Does not exist
Instance on Room 304	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Room 101	Inspected
Instance on Room 304	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 101	Inspected
Instance on Room 304	Inspected
Pendant Mounted	
Instance on Room 101	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	32
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 304	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	24
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

Question	Response
SCIENCE LAB	
LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Violations	No violations recorded
Recessed Mounted	
Instance on Room 101	Does not exist
Instance on Room 304	Does not exist
Surface Mounted	
Instance on Room 101	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 304	Does not exist
Lighting Fixture - HID	
Instance on Room 101	Does not exist
Instance on Room 304	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 101	Does not exist
Instance on Room 304	Inspected
Pendant Mounted	
Instance on Room 304	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 304	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on Room 304	Does not exist
POWER SUPPLY	
Instance on Room 101	Does not exist
Instance on Room 304	Inspected
Instructor Unit	
Instance on Room 304	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 304	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Student Unit	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

Question	Response
SCIENCE LAB	
POWER SUPPLY	
Student Unit	
Instance on Room 304	Does not exist
PROJECTION SYSTEM	
Instance on Room 101	Does not exist
Instance on Room 304	Does not exist
SMART BOARD	
Instance on Room 101	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 304	Does not exist
SCIENCE PREP ROOM	
Instance on Room 102	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	Yes
Instance on Room 302	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 102	Does not exist
Instance on Room 302	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room 102	Does not exist
Instance on Room 302	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Room 102	Inspected
Instance on Room 302	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 102	Inspected
Instance on Room 302	Inspected
Pendant Mounted	
Instance on Room 102	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 302	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 102	Does not exist
Instance on Room 302	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

Question	Response
SCIENCE PREP ROOM	
LIGHTING	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on Room 102	Does not exist
Instance on Room 302	Does not exist
Lighting Fixture - HID	
Instance on Room 102	Does not exist
Instance on Room 302	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 102	Does not exist
Instance on Room 302	Does not exist
POWER SUPPLY	
Instance on Room 102	Does not exist
Instance on Room 302	Does not exist
SECURITY	Inspected
INTRUSION ALARM	Inspected
Central Control Panel	Inspected
Instance	Custodian Office
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista 50P
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	Inspected
Condition	3- Fair
Deficiency	SENSOR NOT IN USE
Deficiency Location/Instance	Room 345
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

Question	Response
SECURITY	
IPDVS/CCTV SYSTEM	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SERVICE SWITCH	Inspected
Instance	Room B35
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co.
EquipmentId	Main SWBD 1
Capacity/Size	1200 Amps
Source of Capacity/Size	Nameplate
Installation Year	1963
Source of Installation Year	Documented
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Room B35
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co.
EquipmentId	Main SWBD 2
Capacity/Size	2000 Amps.
Source of Capacity/Size	Nameplate
Installation Year	1963
Source of Installation Year	Documented
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SWIMMING POOL	Does not exist
SWITCHBOARD	Inspected
Water Penetration In Electrical Room?	No
Number of Spares	0
AIR CIRCUIT BREAKER TYPE	Does not exist
FUSED DISCONNECT SWITCH TYPE	Inspected
Instance	Room B35
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co.
EquipmentId	Main Sw Bd 1
Capacity/Size	1200 Amps total, 3 sections
Source of Capacity/Size	Service Switch Size
Installation Year	1963
Source of Installation Year	Documented
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

Question	Response
SWITCHBOARD	
FUSED DISCONNECT SWITCH TYPE	
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Room B17
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co.
EquipmentId	Main 2
Capacity/Size	2000 Amps total, 2 sections
Source of Capacity/Size	Service Switch Size
Installation Year	1963
Source of Installation Year	Documented
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED KNIFE SWITCH TYPE	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	Does not exist
TELEPHONE	Inspected
PBX/INTERCOM	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
STANDARD	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	1- Good

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K068

Question	Response
TOILET ROOM - STAFF	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TOILET ROOM - STUDENT	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable System Exist?	Yes
Operational?	Yes
Master Antenna System Exist?	No
MAIN EQUIPMENT RACK	Does not exist