

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K078**

School: **I.S. 78 - BROOKLYN, 1420 EAST 68 STREET, BROOKLYN, NY, 11234**

InspectionId	Inspection Type	Time In	Last Edited
2190036	ELECTRICAL	2011-01-19 08:15AM	2011-05-09 05:50AM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	<p>Systems: Pendant and Surface Fluorescent Fixtures in Auditorium Years: 2009</p> <p>Systems: Theater Lighting System   Dimming System Years: 2008-2009</p> <p>Systems: Theater Lighting System   Theater Lighting System Years: 2008-2009</p> <p>Systems: Surface Fluorescent Fixtures in Kitchen Years: 2000</p> <p>Systems: Pendant Fluorescent Fixtures in Computer Lab - Rooms 200, 335 Years: 2000</p> <p>Systems: Raceway with Receptacles in Compute Lab Room 137 Years: 2007</p> <p>Systems: Science Lab Room 226 / Partial Years: 2007</p> <p>Systems: Science Prep Room 224 / Partial Years: 2007</p> <p>Systems: LAN   Main Distribution Frame / Partial Years: 2009</p> <p>Systems: LAN   I / Local Distribution Frame Years: 2009</p> <p>Systems: Public Address System / Partial Years: 2000-2001</p> <p>Systems: Security   IPDVS / CCTV System Years: 2007</p> <p>Systems: Security   Intrusion Alarm Years: 2000-2001</p> <p>Systems: Telephone System Years: 2003-2004</p> <p>Systems: Recessed Fluorescent Lighting 1st Floor Corridor Years: 2000</p> <p>Systems: Partial Fused Disconnect Panel Boards Years: 1990 and 1999</p> <p>Type of Service Below Ground</p>

**Priority Condition**

Condition Description	Component Affected	Location Description	Person(s) Notified
Fire Alarm Sub-Panel Not - Operational	Fire Alarm system	Auditorium Stage Area	James Morton, Custodian

**Inspection**

Question	Response
<b>ELECTRICAL</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance	1st Floor
<b>HOUSE LIGHTING</b>	
Instance on 1st Floor	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K078**

Question	Response
<b>AUDITORIUM</b>	
<b>HOUSE LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	72
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on 1st Floor	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on 1st Floor	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>PROJECTION SYSTEM</b>	
Instance on 1st Floor	Does not exist
<b>THEATER LIGHTING SYSTEM</b>	
Instance on 1st Floor	Inspected
<b>Dimming System</b>	
Instance on 1st Floor	Inspected
Instance Condition	5- Poor
Deficiency	DIMMING RACK NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K078**

Question	Response
<b>AUDITORIUM</b>	
<b>THEATER LIGHTING SYSTEM</b>	
<b>Theater Lighting</b>	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>CAFETERIA</b>	
Instance	Students - Basement
Instance	Teachers - Room B44
<b>LIGHTING</b>	
Instance on Students - Basement	Inspected
Instance on Teachers - Room B44	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Students - Basement	Inspected
Instance on Teachers - Room B44	Inspected
<b>Pendant Mounted</b>	
Instance on Students - Basement	Does not exist
Instance on Teachers - Room B44	Does not exist
<b>Recessed Mounted</b>	
Instance on Students - Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	80
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Teachers - Room B44	Does not exist
<b>Surface Mounted</b>	
Instance on Students - Basement	Does not exist
Instance on Teachers - Room B44	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	28
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
Instance on Students - Basement	Does not exist
Instance on Teachers - Room B44	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Students - Basement	Does not exist
Instance on Teachers - Room B44	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on Students - Basement	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K078**

<b>Question</b>	<b>Response</b>
<b>CAFETERIA</b>	
<b>LOCAL SOUND SYSTEM</b>	
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Teachers - Room B44	Does not exist
<b>CITY FIRE ALARM SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	Inspected
<b>LIGHTING</b>	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1,207
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	124
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K078**

Question	Response
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Pendant Mounted</b>	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	35
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	28
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	76
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SMART BOARD</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>COMPUTER LAB</b>	Inspected
Instance	Room 137
Has LAN/Modem access	Yes
Power Panel?	No
Instance	Rooms 200, 335
Has LAN/Modem access	Yes
Power Panel?	Yes
<b>LIGHTING</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K078**

<b>Question</b>	<b>Response</b>
<b>COMPUTER LAB</b>	
<b>LIGHTING</b>	
Instance on Room 137	Inspected
Instance on Rooms 200, 335	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 137	Inspected
Instance on Rooms 200, 335	Inspected
<b>Pendant Mounted</b>	
Instance on Room 137	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	24
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Rooms 200, 335	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 137	Does not exist
Instance on Rooms 200, 335	Does not exist
<b>Surface Mounted</b>	
Instance on Room 137	Does not exist
Instance on Rooms 200, 335	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 137	Does not exist
Instance on Rooms 200, 335	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 137	Does not exist
Instance on Rooms 200, 335	Does not exist
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room 137	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Rooms 200, 335	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	
	Does not exist
<b>EMERGENCY GENERATOR SET</b>	
	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	
	Inspected
<b>BATTERY PACK</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	
	Inspected
<b>BATTERY PACK</b>	
	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K078**

<b>Question</b>	<b>Response</b>
<b>EXIT LIGHT</b>	
<b>Non Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EXIT/EMERGENCY LIGHT</b>	Does not exist
<b>FIRE ALARM SYSTEM</b>	Inspected
<b>AREA SMOKE DETECTOR</b>	Does not exist
<b>BELL/HORN</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>DUCT SMOKE DETECTOR</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>ELEVATOR RECALL</b>	Does not exist
<b>FAN SHUTDOWN CONTROL</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>FIRE ALARM DIGITAL COMMUNICATOR</b>	Does not exist
<b>FUSED CUTOOUT PANEL</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>HEAT DETECTOR</b>	Does not exist
<b>MAGNETIC DOOR HOLDER CONTACTOR</b>	Does not exist
<b>MAIN PANEL</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Does not exist
<b>Fire Alarm Control Panel (Standard)</b>	Inspected
Instance	Boiler Room - Basement
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Fire Alarm
Capacity/Size	6 circuits
Installation Year	1964
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	156,000
Quantity Uom	S.F.
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MANUAL PULL STATION</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>REMOTE ANNUNCIATOR</b>	Inspected
<b>Display Monitor</b>	Does not exist
<b>Panel</b>	Does not exist
<b>Printer</b>	Does not exist
<b>Punch Register</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K078**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>SPRINKLER FLOW/AIR PRESSURE SWITCH</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>STROBE</b>	Does not exist
<b>SUB-PANEL</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Inspected
Instance	Boiler Room - Basement
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Cerberus Pyrotronics
Model	MXL -IQ
EquipmentId	AC SMOKE AND FIRE PANEL
Capacity/Size	4 zones
Installation Year	1996
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Standard)</b>	Inspected
Instance	Boiler Room - Basement
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Register Control Board
Capacity/Size	1 circuit
Installation Year	1964
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Auditorium - Stage Area
Instance Condition	5- Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Smoke Detection System
Capacity/Size	4 circuits
Installation Year	1964
Source of Installation Year	Documented
Deficiency	PANEL NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Instance	Boiler Room - Basement
Instance Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K078**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>SUB-PANEL</b>	
<b>Fire Alarm Control Panel (Standard)</b>	
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Sprinkler Alarm
Capacity/Size	2 circuits
Installation Year	1964
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>TAMPER FLOW SWITCH/CHAIN</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GROUNDING SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	Inspected
Instance	Boys - 1st Floor
Instance	Girls - 1st Floor
<b>LIGHTING</b>	
Instance on Boys - 1st Floor	Inspected
Instance on Girls - 1st Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Boys - 1st Floor	Does not exist
Instance on Girls - 1st Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Boys - 1st Floor	Does not exist
Instance on Girls - 1st Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Boys - 1st Floor	Inspected
Instance on Girls - 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on Boys - 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K078**

<b>Question</b>	<b>Response</b>
<b>GYMNASIUM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Pendant Mounted</b>	
Instance on Girls - 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Boys - 1st Floor	Does not exist
Instance on Girls - 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on Boys - 1st Floor	Does not exist
Instance on Girls - 1st Floor	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on Boys - 1st Floor	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Girls - 1st Floor	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SCOREBOARD</b>	
Instance on Boys - 1st Floor	Does not exist
Instance on Girls - 1st Floor	Does not exist
<b>THEATER LIGHTING SYSTEM</b>	
Instance on Boys - 1st Floor	Does not exist
Instance on Girls - 1st Floor	Does not exist
<b>INTERCOM SYSTEM</b>	
	Does not exist
<b>KITCHEN/WARMING PANTRY</b>	
Instance	Inspected
	Basement
<b>LIGHTING</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K078**

<b>Question</b>	<b>Response</b>
<b>KITCHEN/WARMING PANTRY</b>	
<b>LIGHTING</b>	
Instance on Basement	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement	Inspected
<b>Pendant Mounted</b>	
Instance on Basement	Does not exist
<b>Recessed Mounted</b>	
Instance on Basement	Does not exist
<b>Surface Mounted</b>	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement	Does not exist
<b>LAN</b>	Inspected
<b>LOCAL DISTRIBUTION FRAME (I/LDF)</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>MAIN EQUIPMENT RACK (MDF)</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>LIBRARY</b>	Inspected
Instance	Room 236
Has LAN/Modem access	Yes
<b>LIGHTING</b>	
Instance on Room 236	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 236	Inspected
<b>Pendant Mounted</b>	
Instance on Room 236	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	40
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 236	Does not exist
<b>Surface Mounted</b>	
Instance on Room 236	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 236	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 236	Does not exist
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room 236	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>SMART BOARD</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K078**

<b>Question</b>	<b>Response</b>
<b>LIBRARY</b>	
<b>SMART BOARD</b>	
Instance on Room 236	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>LIGHTING - SECURITY LIGHTS</b>	
	Inaccessible
<b>LIGHTNING PROTECTION</b>	
	Does not exist
<b>LOCKER ROOM</b>	
Instance on Boys - 1st Floor	Inspected
Alternative Use	No
Instance on Girls - 1st Floor	Inspected
Alternative Use	No
<b>LIGHTING</b>	
Instance on Boys - 1st Floor	Inspected
Instance on Girls - 1st Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Boys - 1st Floor	Does not exist
Instance on Girls - 1st Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Boys - 1st Floor	Does not exist
Instance on Girls - 1st Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Boys - 1st Floor	Inspected
Instance on Girls - 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on Boys - 1st Floor	Does not exist
Instance on Girls - 1st Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on Boys - 1st Floor	Does not exist
Instance on Girls - 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on Boys - 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	28
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Girls - 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	26
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K078**

Question	Response
<b>LOCKER ROOM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Surface Mounted</b>	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	4- Between Fair and Poor
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Mechanical Spaces, Boiler Room
Deficiency Quantity	19
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	MOTOR STARTER NOT OPERATIONAL
Deficiency Location/Instance	Boiler room - Starters for House and Toilet Exhaust
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	MOTOR STARTER PUSH BUTTON NOT OPERATIONAL
Deficiency Location/Instance	Boiler room - Roof Fan Disconnect
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MULTIPURPOSE ROOM</b>	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>FUSED DISCONNECT SWITCH TYPE</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Mechanical spaces in Basement, Boiler Room
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>FUSED KNIFE SWITCH TYPE</b>	Does not exist
<b>FUSED TOGGLE SWITCH TYPE</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K078**

Question	Response
<b>PANEL BOARD</b>	
<b>FUSED TOGGLE SWITCH TYPE</b>	
Deficiency Location/Instance	Electrical Room B26
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	
Condition	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	1st, 2rd, 3rd Floor Corridors, Kitchen, Cafeteria, Gymnasium
Deficiency Quantity	19
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>PUBLIC ADDRESS SYSTEM</b>	
Instance	Inspected
Instance	General Office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Rauland FAX 250 Amplifier, Power Supply, Tuner MCX 300, MIXER AP461
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Classrooms, Corridors, Administrative Spaces
Deficiency Quantity	75
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SCIENCE DEMO ROOM</b>	
Instance on Room 114	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 118	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Rooms 222,318, 322	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Room 114	Does not exist
Instance on Room 118	Does not exist
Instance on Rooms 222,318, 322	Does not exist
<b>EMERGENCY SHUT-OFF POWER</b>	
Instance on Room 114	Does not exist
Instance on Room 118	Does not exist
Instance on Rooms 222,318, 322	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K078**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>LIGHTING</b>	
Instance on Room 114	Inspected
Instance on Room 118	Inspected
Instance on Rooms 222,318, 322	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 114	Inspected
Instance on Room 118	Inspected
Instance on Rooms 222,318, 322	Inspected
<b>Pendant Mounted</b>	
Instance on Room 114	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	27
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 118	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	27
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Rooms 222,318, 322	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	81
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 114	Does not exist
Instance on Room 118	Does not exist
Instance on Rooms 222,318, 322	Does not exist
<b>Surface Mounted</b>	
Instance on Room 114	Does not exist
Instance on Room 118	Does not exist
Instance on Rooms 222,318, 322	Does not exist
<b>Lighting Fixture - HID</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K078**

Question	Response
<b>SCIENCE DEMO ROOM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - HID</b>	
Instance on Room 114	Does not exist
Instance on Room 118	Does not exist
Instance on Rooms 222,318, 322	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 114	Does not exist
Instance on Room 118	Does not exist
Instance on Rooms 222,318, 322	Does not exist
<b>POWER SUPPLY</b>	
Instance on Room 114	Does not exist
Instance on Room 118	Does not exist
Instance on Rooms 222,318, 322	Does not exist
<b>PROJECTION SYSTEM</b>	
Instance on Room 114	Does not exist
Instance on Room 118	Does not exist
Instance on Rooms 222,318, 322	Does not exist
<b>SMART BOARD</b>	
Instance on Room 114	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 118	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Rooms 222,318, 322	Does not exist
<b>SCIENCE LAB</b>	
Instance on Room 226	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Room 226	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>EMERGENCY SHUT-OFF POWER</b>	
Instance on Room 226	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>LIGHTING</b>	
Instance on Room 226	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 226	Inspected
<b>Pendant Mounted</b>	
Instance on Room 226	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	27
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K078**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Recessed Mounted</b>	
Instance on Room 226	Does not exist
<b>Surface Mounted</b>	
Instance on Room 226	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 226	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 226	Does not exist
<b>POWER SUPPLY</b>	
Instance on Room 226	Inspected
<b>Instructor Unit</b>	
Instance on Room 226	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Meter Demonstration Unit</b>	
Instance on Room 226	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Student Unit</b>	
Instance on Room 226	Does not exist
<b>PROJECTION SYSTEM</b>	
Instance on Room 226	Does not exist
<b>SMART BOARD</b>	
Instance on Room 226	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>SCIENCE PREP ROOM</b>	
Instance on Room 116	Inspected
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	Yes
Instance on Room 224	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 320	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	Yes
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Room 116	Does not exist
Instance on Room 224	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 320	Does not exist
<b>EMERGENCY SHUT-OFF POWER</b>	
Instance on Room 116	Does not exist
Instance on Room 224	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 320	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K078**

<b>Question</b>	<b>Response</b>
<b>SCIENCE PREP ROOM</b>	
<b>LIGHTING</b>	
Instance on Room 116	Inspected
Instance on Room 224	Inspected
Instance on Room 320	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 116	Inspected
Instance on Room 224	Inspected
Instance on Room 320	Inspected
<b>Pendant Mounted</b>	
Instance on Room 116	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 224	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 320	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 116	Does not exist
Instance on Room 224	Does not exist
Instance on Room 320	Does not exist
<b>Surface Mounted</b>	
Instance on Room 116	Does not exist
Instance on Room 224	Does not exist
Instance on Room 320	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 116	Does not exist
Instance on Room 224	Does not exist
Instance on Room 320	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 116	Does not exist
Instance on Room 224	Does not exist
Instance on Room 320	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K078**

<b>Question</b>	<b>Response</b>
<b>SCIENCE PREP ROOM</b>	
<b>POWER SUPPLY</b>	
Instance on Room 116	Does not exist
Instance on Room 224	Does not exist
Instance on Room 320	Does not exist
<b>SECURITY</b>	
<b>INTRUSION ALARM</b>	
<b>Central Control Panel</b>	Inspected
Instance	Custodian Office
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	ADEMCO 4140XMPT
Deficiency	No deficiencies recorded
<b>Infrared Sensor</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Ultrasonic Sensor</b>	Inspected
Condition	3- Fair
Deficiency	SENSOR NOT IN USE
Deficiency Location/Instance	Exit - Stair Case D - Basement
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>IPDVS/CCTV SYSTEM</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>SERVICE SWITCH</b>	
Instance	Electrical Equipment Room - B26
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lexington Electric Products Co.
EquipmentId	Switchboard #1
Capacity/Size	1600 Amps
Source of Capacity/Size	Nameplate
Installation Year	1964
Source of Installation Year	Documented
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K078**

<b>Question</b>	<b>Response</b>
<b>SERVICE SWITCH</b>	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Equipment Room - B26
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lexington Electric Products Co.
EquipmentId	Switchboard #2
Capacity/Size	1600 Amps
Source of Capacity/Size	Nameplate
Installation Year	1964
Source of Installation Year	Documented
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SWIMMING POOL</b>	Does not exist
<b>SWITCHBOARD</b>	Inspected
Water Penetration In Electrical Room?	No
Number of Spares	0
<b>AIR CIRCUIT BREAKER TYPE</b>	Does not exist
<b>FUSED DISCONNECT SWITCH TYPE</b>	Inspected
Instance	Electrical Equipment Room - B26
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lexington Electric Products Co.
EquipmentId	Main Switchboard BD 1
Capacity/Size	1600 Amps total, 2 sections
Source of Capacity/Size	Service Switch Size
Installation Year	1964
Source of Installation Year	Documented
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Equipment Room - B08
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lexington Electric Products Co.
EquipmentId	Main SW BD 2

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K078**

<b>Question</b>	<b>Response</b>
<b>SWITCHBOARD</b>	
<b>FUSED DISCONNECT SWITCH TYPE</b>	
Capacity/Size	1600 Amps total, 2 sections
Source of Capacity/Size	Service Switch Size
Installation Year	1964
Source of Installation Year	Documented
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>FUSED KNIFE SWITCH TYPE</b>	Does not exist
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	Does not exist
<b>TELEPHONE</b>	Inspected
<b>PBX/INTERCOM</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>STANDARD</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>TOILET ROOM - STAFF</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K078**

<b>Question</b>	<b>Response</b>
<b>TOILET ROOM - STUDENT</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	23
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>TRANSFORMER</b>	Does not exist
<b>TV SYSTEM</b>	Inspected
Cable System Exist?	Yes
Operational?	Yes
Master Antenna System Exist?	No
<b>MAIN EQUIPMENT RACK</b>	Does not exist