

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K166

School: **I.S. 166 - BROOKLYN, 800 VAN SICKLEN AVENUE, BROOKLYN, NY, 11204**

InspectionId	Inspection Type	Time In	Last Edited
1251155	ELECTRICAL	2009-06-02 08:43AM	2009-06-10 10:35AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	<p>Systems: LAN / Partial, Telephone / Intercom, Exit lights / Partial, Public Address Systems, Exit lights / Battery Packs, Local Sound Systems in Cafeteria and Gymnasium / Closed Circuit TV</p> <p>Years: 2008</p> <p>Systems: Emergency Exit Light Battery Packs/ Partial</p> <p>Years: 2005</p> <p>Systems: Local Sound System in Auditorium</p> <p>Years: Under Construction</p> <p>Systems: Electrical Service, Panel Boards / Partial, Electrical Switchboards / Partial</p> <p>Years: 2007</p> <p>Systems: Intrusion Alarm</p> <p>Years: 2001</p> <p>Systems: Projection System, Electrical Switchboard for Oil Burner in Boiler Room</p> <p>Years: 2003</p> <p>Systems: Emerging and Exit Lights Panel</p> <p>Years: 2000</p> <p>Systems: Passenger Elevator</p> <p>Years: Under Construction</p>

Priority Condition

No condition recorded

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	First Floor
House Lighting	
Instance on First Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on First Floor	Does not exist
Lighting Fixture - HID	
Instance on First Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on First Floor	Inspected
Pendant Mounted	
Instance on First Floor	Does not exist
Recessed Mounted	
Instance on First Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	59
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K166

Question	Response
AUDITORIUM	
House Lighting	
Lighting Fixture - Incandescent	
Recessed Mounted	
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	INSTALL NEW LAMP
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on First Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Local Sound System	
Instance on First Floor	Under construction
Projection System	
Instance on First Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Theater Lighting System	
Instance on First Floor	Inspected
Dimming System	
Instance on First Floor	Inspected
Instance Condition	3- Fair
Deficiency	DIMMING RACK BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Theater Lighting	
Instance on First Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	Inspected
Replacement Quantity	3- Fair
Replacement Uom	143,000
Deficiency	S.F.
Deficiency	No deficiencies recorded
CAFETERIA	
Instance	Inspected
Instance	Basement
Lighting	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K166

Question	Response
CAFETERIA	
Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Instance on Basement	Does not exist
Recessed Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
Local Sound System	
Instance on Basement	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
CAFETERIA/MULTIPURPOSE ROOM	Does not exist
CITY FIRE ALARM SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1,015
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	33
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K166

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Does not exist	
Lighting Fixture - Incandescent	
Inspected	
Pendant Mounted	
Inspected	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	25
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Inspected	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	36
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Inspected	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	61
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	13
Quantity Uom	EACH
Potential Action	INSTALL NEW LAMP
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K166

Question	Response
COMPUTER LAB	Inspected
Instance	Room 204
Has LAN/Modem access	Yes
Power Panel?	Yes
Lighting	
Instance on Room 204	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 204	Inspected
Pendant Mounted	
Instance on Room 204	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	27
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room 204	Does not exist
Surface Mounted	
Instance on Room 204	Does not exist
Lighting Fixture - HID	
Instance on Room 204	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 204	Does not exist
Raceway With Receptacles	
Instance on Room 204	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
ELECTRIC SERVICE SWITCH	Inspected
Instance	Electrical Equipment Room
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Galaxy Switchgear Industries, LLC
Model	Galaxy Switchgear Industries, LLC
EquipmentId	N/A
Capacity/Size	2000 Amps
Installation Year	2007
Deficiency	SWITCH ID IS MISSING
Deficiency Location/Instance	Electrical Equipment Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected

NYC Department of Education
Building Condition Assessment Survey 2008-2009

Electrical Inspection

K166

Question	Response
EMERGENCY LIGHTING	
Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Connected To Emergency Generator System	Does not exist
Connected To Emergency Light/Exit Light Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Relay Test Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Connected To Emergency Generator System	Does not exist
Connected To Emergency Light/Exit Light Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
FIRE ALARM SYSTEM	Inspected
Replacement Quantity	143,000
Replacement Uom	S.F.
Area Smoke Detector	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Bell/Horn	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Duct Smoke Detector	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Elevator Recall	Under construction
Fan Shutdown Control	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not exist
Fused Cutout Panel	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Heat Detector	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Magnetic Door Holder Contactor	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Main Panel	Inspected
Bell At Panel	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Lobby
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K166

Question	Response
FIRE ALARM SYSTEM	
Main Panel	
Fire Alarm Control Panel (Electronic)	
Manufacturer	Notifier
Model	N/A
EquipmentId	Interior Fire Alarm Systems
Capacity/Size	26 zones
Installation Year	2008
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	
	Does not exist
Manual Pull Station	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Remote Annunciator	
	Inspected
Display Monitor	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Panel	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Printer	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Punch Register	
	Does not exist
Sprinkler Flow/Air Pressure Switch	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Strobe	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Sub-Panel	
	Does not exist
Tamper Flow Switch/Chain	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	
	Inspected
Instance	First Floor
Lighting	
Instance on First Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on First Floor	Does not exist
Lighting Fixture - HID	
Instance on First Floor	Inspected
Pendant Mounted	
Instance on First Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K166

Question	Response
GYMNASIUM	
Lighting	
Lighting Fixture - HID	
Recessed Mounted	
Instance on First Floor	Does not exist
Surface Mounted	
Instance on First Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on First Floor	Does not exist
Local Sound System	
Instance on First Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Scoreboard	
Instance on First Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Theater Lighting System	
Instance on First Floor	Does not exist
INTERCOM SYSTEM	
Elevator	Inspected
Holding Area	Under construction
Holding Area	Does not exist
KITCHEN/WARMING PANTRY	
Lighting	Inspected
Lighting Fixture - Fluorescent	
Pendant Mounted	
Does not exist	Does not exist
Recessed Mounted	
Condition	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Condition	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Does not exist	Does not exist
Lighting Fixture - Incandescent	
Does not exist	Does not exist
LAN	
Inspected	Inspected
Local Distribution Frame (I/LDF)	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	NOT OPERATIONAL
Deficiency Location/Instance	Rooms 120, 201
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Main Equipment Rack (MDF)	
Inspected	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
LIBRARY	
Inspected	Inspected
Instance	Room 232
Has LAN/Modem access	Yes
Lighting	
Instance on Room 232	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 232	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K166

Question	Response
LIBRARY	
Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Instance on Room 232	Does not exist
Recessed Mounted	
Instance on Room 232	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 232	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room 232	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 232	Inspected
Pendant Mounted	
Instance on Room 232	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 232	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 232	Does not exist
Raceway With Receptacles	
Instance on Room 232	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
LIGHTING - EXTERIOR SECURITY	Inaccessible
LIGHTNING PROTECTION	Does not exist
LOCKER ROOM/SHOWER ROOM	Inspected
Instance	Boys (B46) and Girls (B54) / Basement
Alternative Use	Yes
Lighting	
Instance on Boys (B46) and Girls (B54) / Basement	Not required
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Auditorium
Deficiency Quantity	1
Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K166

Question	Response
PANEL BOARD	
Fused Toggle Switch Type	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Molded Case Circuit Breaker Type	Inspected
Condition	1- Good
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Custodian Office, Corridors
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	Inspected
Replacement Quantity	143,000
Replacement Uom	S.F.
Instance	General Office
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	DUKANE 250
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Inspected
Instance	Rooms 105, 106,108,109,205
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Emergency Gas Shut-Off Valve	
Instance on Rooms 105, 106,108,109,205	Does not exist
Emergency Shut-Off Power	
Instance on Rooms 105, 106,108,109,205	Does not exist
Lighting	
Instance on Rooms 105, 106,108,109,205	Not required
Power Supply	
Instance on Rooms 105, 106,108,109,205	Does not exist
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	Inspected
Instance	Room 207
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	Yes
Emergency Gas Shut-Off Valve	
Instance on Room 207	Does not exist
Emergency Shut-Off Power	
Instance on Room 207	Does not exist
Lighting	
Instance on Room 207	Not required
Power Supply	
Instance on Room 207	Does not exist
SECURITY	Inspected
Replacement Quantity	143,000
Replacement Uom	S.F.

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K166

Question	Response
SECURITY	
Intrusion Alarm	Inspected
Central Control Panel	Inspected
Instance	Custodian Office
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	ADEMCO - VISTA 128B
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	Does not exist
IPDVS/CCTV System	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
SWIMMING POOL	Does not exist
SWITCHBOARD	Inspected
Air Circuit Breaker Type	Does not exist
Fused Disconnect Switch Type	Inspected
Instance	Electrical Equipment Room
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Galaxy Switchgear Industries, LLC
EquipmentId	N/A
Capacity/Size	2000 Amps total, 4 sections
Installation Year	2007
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Equipment Room
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K166

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	
Manufacturer	General Electric/ Spectra Series
EquipmentId	DPEM JHS166
Capacity/Size	400 Amps total, 1 section
Installation Year	2007
Deficiency	No deficiencies recorded
Fused Knife Switch Type	
	Does not exist
Molded Case Circuit Breaker Type	
	Inspected
Instance	Boiler Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lincoln Electric
EquipmentId	Oil Burner Panel
Capacity/Size	400 Amps total, 1 section
Installation Year	2003
Deficiency	No deficiencies recorded
TELEPHONE	
	Inspected
PBX/Intercom	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Standard	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	
	Inspected
Lighting	
	Inspected
Lighting Fixture - Fluorescent	
	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
	Does not exist
Lighting Fixture - Incandescent	
	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TOILET ROOM - STUDENT	
	Inspected
Lighting	
	Inspected
Lighting Fixture - Fluorescent	
	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K166

Question	Response
TOILET ROOM - STUDENT	
Lighting	
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	17
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable Service	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Main Equipment Rack	Does not exist
Master Antenna System	Inspected
Condition	3- Fair
Deficiency	ANTENNA NOT IN USE
Deficiency Location/Instance	Roof
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded