

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K166

School: I.S. 166 - BROOKLYN, 800 VAN SICLEN AVENUE, BROOKLYN, NY, 11204

InspectionId	Inspection Type	Time In	Last Edited
1650041	MECHANICAL	2010-11-22 09:05AM	2011-05-02 10:01AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Domestic Water Gas fired water heater. Years: 2010 Systems: DX split system for the Elevator Machine Room in the Penthouse. Years: 2009 Systems: DX split system for the recording studio Room 322. Years: 2007 Systems: Elevator, non-auditorium handicap lift. Years: 2009 Systems: Climate Control System Years: 2006 Systems: Steam Condensate Return Pumping System. Years: 2006 Systems: F & T Steam Drip Traps Years: 2006 Systems: Terminal Unit Thermostatic Traps Years: 2006 Systems: DX split system for the MDF Room Years: 2004
Are there fuel tanks?	Yes
Total # of above ground tanks	2
Total capacity of all above ground tanks in gal.	15,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0

Priority Condition

No condition recorded

Inspection

Question	Response
MECHANICAL	
AIR CONDITIONING	Inspected
CHILLED WATER SYSTEM	Does not exist
CONDENSER WATER PIPING	Does not exist
CONDENSER WATER PUMP	Does not exist
COOLING COILS IN DUCTWORK	Does not exist
COOLING TOWER	Does not exist
DX SPLIT SYSTEM	Inspected
Indoor Unit	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Outdoor Unit	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
PACKAGED / ROOFTOP UNIT	Does not exist
PACKAGED TERMINAL A/C	Does not exist
REFRIGERANT PIPING	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
RETURN FAN	Does not exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Inspected
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K166

Question	Response
CENTRAL ACID WASTE NEUTRALIZING TANK	
Deficiency	NOT IN USE
Deficiency Location/Instance	Basement
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
CLIMATE CONTROL SYSTEM	Inspected
DDC SYSTEM	Does not exist
ELECTRIC SYSTEM	Does not exist
HYBRID SYSTEM	Does not exist
PNEUMATIC SYSTEM	Inspected
Instance	Throughout school
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	No deficiencies recorded
COMPACTOR	Does not exist
CONVEYING	Inspected
ASH HOIST	Inspected
Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Location/Instance	Basement store room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
DUMBWAITERS	Does not exist
ELEVATORS	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
ESCALATORS	Does not exist
Non-auditorium Handicap Lift - Stair	Does not exist
Non-auditorium Handicap Lift - Vertical	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
SIDEWALK ELEVATOR	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
DOMESTIC WATER SYSTEM	Inspected
DOMESTIC COLD WATER SYSTEM	Inspected
Gravity System	Does not exist
Pressure Booster System	Does not exist
Water Service	Inspected
Service Piping (Water Main)	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Water Main - Double Check Valve	Does not exist
Water Main - RPZ	Does not exist
DOMESTIC HOT WATER SYSTEM	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K166

Question	Response
DOMESTIC WATER SYSTEM	
DOMESTIC HOT WATER SYSTEM	
Domestic Hot Water Circulating Pump	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Domestic Hot Water Remote Storage Tank	Does not exist
Domestic Water Heat Exchanger	Does not exist
Electric Domestic Water Heater	Does not exist
Gas Fired Domestic Water Heater	Inspected
Instance	Basement boiler room mezzanine
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Rheem
EquipmentId	N/A
Capacity/Size	N/A
Installation Year	2010
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not exist
DOMESTIC WATER DISTRIBUTION PIPING	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
HOUSE TRAP	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
INTERIOR FLOOR DRAIN	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
INTERIOR STORM PIPING	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
SEWAGE / WASTE PIPING	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
SEWAGE EJECTOR PUMP	Does not exist
SUMP PUMP	Inspected
Condition	3- Fair
Deficiency	BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Basement Boiler Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
VENT PIPING	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not exist
FIXTURES	Inspected
STAFF AND OTHER	Inspected
Janitor Sink	Inspected
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K166

Question	Response
FIXTURES	
STAFF AND OTHER	
Janitor Sink	
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
STUDENT	
Drinking Fountain	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Locker Room Shower	Inspected
Instance on Girls Room B54	Inspected
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Alternative Use	Yes
Deficiency	NOT IN USE
Deficiency Location/Instance	Girls Room B54
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Sink And Fountain Combo Unit	Does not exist
Toilet	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not exist
GAS SERVICE	Inspected
CO/GAS LEAK DETECTION	Does not exist
GAS DISTRIBUTION PIPING	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GAS METER ROOM EXHAUST FAN	Does not exist
GAS METER ROOM VENT	Does not exist
GAS PRESSURE BOOSTER	Does not exist
HEATING	Inspected
BASEBOARD/FIN TUBE	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K166

Question	Response
HEATING	
HEATING COILS IN DUCTWORK	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
HYDRONIC HEATING	Does not exist
RADIATOR / CONVECTOR	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
STEAM HEATING	Inspected
F&T/Steam Drip Trap	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	Inspected
Condition	3- Fair
Deficiency	BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Basement Boiler Room
Deficiency Quantity	300
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Steam Condensate Return Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Steam Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Terminal Unit Thermostatic Trap	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
STEAM SUPPLIED BY EXTERNAL SOURCES	Does not exist
UNIT HEATER/CABINET HEATER	Inspected
Condition	3- Fair
Deficiency	BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Basement
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
HEATING PLANT	Inspected
Replacement Quantity	13,509
Replacement Uom	MBH
Instance	Basement Boiler Room B38
Burner Type	Oil
Heating Plant Oil Number	4
BOILER AUXILIARIES	
Instance on Basement Boiler Room B38	Inspected
Boiler Auxiliary Piping	
Instance on Basement Boiler Room B38	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K166

Question	Response
HEATING PLANT	
BOILER AUXILIARIES	
Boiler Auxiliary Piping	
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Basement Boiler Room B38	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement Boiler Room B38	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Basement Boiler Room B38	Does not exist
Boiler Flue Exhaust	
Instance on Basement Boiler Room B38	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement Boiler Room B38	Does not exist
Boiler Room Steam And Condensate Piping	
Instance on Basement Boiler Room B38	Inspected
Instance Condition	3- Fair
Deficiency	BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Basement Boiler Room B38
Deficiency Quantity	300
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Boiler Safety Valve	
Instance on Basement Boiler Room B38	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
BOILER SYSTEM	
Instance on Basement Boiler Room B38	Inspected
Coal-fired Boiler	
Instance on Basement Boiler Room B38	Does not exist
Hot Water Boiler	
Instance on Basement Boiler Room B38	Does not exist
Modular Boiler	
Instance on Basement Boiler Room B38	Does not exist
Steam Boiler	
Instance on Basement Boiler Room B38	Inspected
Instance	Basement Boiler Room B38
Instance Condition	3- Fair
Instance Quantity	4,503
Instance Quantity Uom	MBH
Manufacturer	Fitzgibbons
EquipmentId	45385-1
Capacity/Size	50 GPH
Installation Year	1956
Source of Installation Year	Documented

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K166

Question	Response
HEATING PLANT	
BOILER SYSTEM	
Steam Boiler	
Deficiency	BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PLUGGED TUBES
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Basement Boiler Room B38
Instance Condition	3- Fair
Instance Quantity	4,503
Instance Quantity Uom	MBH
Manufacturer	Fitzgibbons
EquipmentId	45385-3
Capacity/Size	50 GPH
Installation Year	1956
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PLUGGED TUBES
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Basement Boiler Room B38
Instance Condition	3- Fair
Instance Quantity	4,503
Instance Quantity Uom	MBH
Manufacturer	Fitzgibbons
EquipmentId	45385-3
Capacity/Size	50 GPH
Installation Year	1956
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PLUGGED TUBES

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K166

Question	Response
HEATING PLANT	
BOILER SYSTEM	
Steam Boiler	
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUEL SYSTEMS	
Instance on Basement Boiler Room B38	Inspected
Boiler Fresh Air Louver/Damper	
Instance on Basement Boiler Room B38	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement Boiler Room B38	Inspected
Instance Condition	3- Fair
Deficiency	OIL BURNER:BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Basement Boiler Room B38
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fuel Oil Storage/Supply System	
Instance on Basement Boiler Room B38	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Gas Trains And Vent At The Boiler	
Instance on Basement Boiler Room B38	Does not exist
IDF (ENCLOSED ROOMS)	
Instance	Room 215
A/C EQUIPMENT	
Instance on Room 215	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
VENTILATION EQUIPMENT	
Instance on Room 215	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
KITCHEN	
Instance	Basement Kitchen
CO DETECTOR	
Instance on Basement Kitchen	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	DETECTOR MISSING
Deficiency Location/Instance	Basement Kitchen
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K166

Question	Response
KITCHEN	
GAS SYSTEM	
Instance on Basement Kitchen	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
GREASE TRAP	
Instance on Basement Kitchen	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	DEFECTIVE/CLOGGED
Deficiency Location/Instance	Basement Kitchen / 3 of 3
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
HOOD	
Instance on Basement Kitchen	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Location/Instance	Basement Kitchen / old dishwasher hood
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
HOOD EXHAUST DUCTWORK	
Instance on Basement Kitchen	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
HOOD EXHAUST FAN	
Instance on Basement Kitchen	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
HOOD FIRE SUPPRESSION SYSTEM	
Instance on Basement Kitchen	Does not exist
HOT WATER TEMPERATURE BOOSTER	
Instance on Basement Kitchen	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Location/Instance	Basement
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
KITCHEN SINK	
Instance on Basement Kitchen	Inspected
Instance Condition	3- Fair
Deficiency	MISSING INDIRECT WASTE
Deficiency Location/Instance	Basement Kitchen
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	INSTALL

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K166

Question	Response
KITCHEN	
KITCHEN SINK	
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Basement Kitchen / 1 of 3 sinks two drains are leaking and the legs are not supporting the sink.
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
MDF ROOM	Inspected
Instance	Room 228 A & B
A/C EQUIPMENT	
Instance on Room 228 A & B	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
VENTILATION EQUIPMENT	
Instance on Room 228 A & B	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	
Instance on Rooms 105, 106, 108, 109, 205.	Inspected
Alternative Use	Yes
ACID WASTE NEUTRALIZING TANK	
Instance on Rooms 105, 106, 108, 109, 205.	Does not exist
EMERGENCY SHOWER	
Instance on Rooms 105, 106, 108, 109, 205.	Does not exist
EYE WASH	
Instance on Rooms 105, 106, 108, 109, 205.	Does not exist
FIXED LABORATORY HOOD	
Instance on Rooms 105, 106, 108, 109, 205.	Does not exist
LABORATORY SINK	
Instance on Rooms 105, 106, 108, 109, 205.	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Location/Instance	Rooms 105, 106, 108, 109, 205 / Water is shut off and basins covered for 5 of 5 sinks. .
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
PORTABLE LABORATORY HOOD	
Instance on Rooms 105, 106, 108, 109, 205.	Does not exist
SCIENCE LAB	
Does not exist	
SCIENCE PREP ROOM	
Instance on Room 207	Inspected
Alternative Use	Yes
ACID WASTE NEUTRALIZING TANK	
Instance on Room 207	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K166

Question	Response
SCIENCE PREP ROOM	
EMERGENCY SHOWER	
Instance on Room 207	Does not exist
EYE WASH	
Instance on Room 207	Does not exist
FIXED LABORATORY HOOD	
Instance on Room 207	Does not exist
HOOD EXHAUST DUCTWORK	
Instance on Room 207	Does not exist
HOOD EXHAUST FAN	
Instance on Room 207	Does not exist
LABORATORY SINK	
Instance on Room 207	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Location/Instance	Room 207 / Water is shut off.
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
MAKE-UP AIR UNIT	
Instance on Room 207	Does not exist
PORTABLE LABORATORY HOOD	
Instance on Room 207	Does not exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
DELUGE VALVE	Does not exist
FIRE BOOSTER PUMP ASSEMBLY	Does not exist
ROOF TANK	Does not exist
SIAMESE CONNECTION	Inspected
Condition	3- Fair
Deficiency	MISSING CAPS
Deficiency Location/Instance	Van Siden Side/ One of two caps is missing.
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SPRINKLER ALARM VALVE ASSEMBLY	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
SPRINKLER HEAD	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
SPRINKLER PIPING	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
STANDPIPE SYSTEM	Does not exist
WATER GONG	Does not exist
SWIMMING POOL	Does not exist
VENTILATION	Inspected
EXHAUST FAN	Inspected
Condition	3- Fair

NYC Department of Education
Building Condition Assessment Survey 2010-2011

Mechanical Inspection

K166

Question	Response
VENTILATION	
EXHAUST FAN	
Deficiency	No deficiencies recorded
HEATING AND VENTILATING UNIT	
Condition	3- Fair
Deficiency	BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Basement MER / 1 of 1
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
METAL DUCTWORK	
Condition	3- Fair
Deficiency	No deficiencies recorded
SUPPLY FAN	
Condition	3- Fair
Deficiency	No deficiencies recorded
UNIT VENTILATOR	
	Does not exist