

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K167

School: P.S. 167 - BROOKLYN, 1025 EASTERN PKWY, BROOKLYN, NY, 11213

InspectionId	Inspection Type	Time In	Last Edited
2190069	ELECTRICAL	2011-03-02 07:58AM	2011-03-10 09:16AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	<p>Systems: Surface Fluorescent Fixtures in Auditorium Years: 1999-2000</p> <p>Systems: Projection System in Auditorium Years: 2011</p> <p>Systems: Public Address System Years: 2010</p> <p>Systems: Local Sound Systems in Auditorium, Cafeteria, Gymnasium Years: 2010</p> <p>Systems: Fire Alarm System Years: 2010</p> <p>Systems: Smart Boards Years: 2008-2009</p> <p>Systems: Surface Fluorescent Fixtures in Staircases Years: 1999-2000</p> <p>Systems: Fluorescent Fixtures in Staff and Student Toilet Rooms Years: 1999-2000</p> <p>Systems: Panel Board Molded Case Circuit Breaker Type Years: 2007-2008</p> <p>Systems: Exit Light Battery Packs Years: 2011</p> <p>Systems: Emergency Light Battery Packs Years: 1999-2000</p> <p>Systems: LAN Main and Local Distribution Frames Years: 2008-2009</p> <p>Systems: Security Intrusion Alarm Control Panel Years: 2010</p> <p>Systems: Intrusion Alarm Other Components Years: 2004-2005</p> <p>Systems: Security IPDVS / CCTV System Years: 2004-2005</p> <p>Systems: Telephone System Years: 2008-2009</p> <p>Systems: Main Service Switch Years: 2007</p> <p>Systems: Switchboard Fused Disconnect Switch Type Years: 2007</p> <p>Systems: Outside Security Lights Years: Approximately 1995 and 2008/09</p> <p>Systems: Partial Motor Starters Years: 2010</p>
Type of Service	Below Ground

Priority Condition

No condition recorded

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	Ground Floor

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K167

Question	Response
AUDITORIUM	
HOUSE LIGHTING	
Instance on Ground Floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on Ground Floor	Inspected
Pendant Mounted	
Instance on Ground Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	84
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Ground Floor	Does not exist
Surface Mounted	
Instance on Ground Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Ground Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on Ground Floor	Inspected
Pendant Mounted	
Instance on Ground Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Ground Floor	Does not exist
Surface Mounted	
Instance on Ground Floor	Does not exist
LOCAL SOUND SYSTEM	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K167

Question	Response
AUDITORIUM	
LOCAL SOUND SYSTEM	
Instance on Ground Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
PROJECTION SYSTEM	
Instance on Ground Floor	Inspected
Instance Condition	1- Good
Is the projector on a cart or installed on the ceiling?	Cart
Deficiency	No deficiencies recorded
THEATER LIGHTING SYSTEM	
Instance on Ground Floor	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA	
Instance	Ground Floor - West
LIGHTING	
Instance on Ground Floor - West	Inspected
Lighting Fixture - Fluorescent	
Instance on Ground Floor - West	Inspected
Pendant Mounted	
Instance on Ground Floor - West	Does not exist
Recessed Mounted	
Instance on Ground Floor - West	Does not exist
Surface Mounted	
Instance on Ground Floor - West	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	33
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Ground Floor - West	Does not exist
Lighting Fixture - Incandescent	
Instance on Ground Floor - West	Does not exist
LOCAL SOUND SYSTEM	
Instance on Ground Floor - West	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
CITY FIRE ALARM SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K167

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	812
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	69
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K167

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Lighting Fixture - Incandescent	
Surface Mounted	Inspected
Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SMART BOARD	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
COMPUTER LAB	Inspected
Instance	Room 409
Has LAN/Modem access	Yes
Power Panel?	Yes
LIGHTING	
Instance on Room 409	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 409	Inspected
Pendant Mounted	
Instance on Room 409	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room 409	Does not exist
Surface Mounted	
Instance on Room 409	Does not exist
Lighting Fixture - HID	
Instance on Room 409	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 409	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 409	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K167

Question	Response
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
BATTERY PACK	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Main Lobby
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
EXIT LIGHT	Inspected
BATTERY PACK	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	FIXTURE LENS MISSING
Deficiency Location/Instance	Ground Floor near Old Custodian Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
AREA SMOKE DETECTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
BELL/HORN	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
DUCT SMOKE DETECTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
ELEVATOR RECALL	Does not exist
FAN SHUTDOWN CONTROL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
FIRE ALARM DIGITAL COMMUNICATOR	Inspected
Instance	Main Lobby
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ADEMCO
EquipmentId	CENTRAL STATION FIRE ALARM
Capacity/Size	5 zones
Installation Year	2010

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K167

Question	Response
FIRE ALARM SYSTEM	
FIRE ALARM DIGITAL COMMUNICATOR	
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
FUSED CUTOOUT PANEL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
HEAT DETECTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
MAGNETIC DOOR HOLDER CONTACTOR	Does not exist
MAIN PANEL	Inspected
Bell At Panel	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Lobby
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards Systems Technology
Model	GE / EST-2
EquipmentId	Fire Alarm Control Panel
Capacity/Size	8 zones
Installation Year	2010
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist
MANUAL PULL STATION	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
REMOTE ANNUNCIATOR	Inspected
Display Monitor	Does not exist
Panel	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Punch Register	Does not exist
SPRINKLER FLOW/AIR PRESSURE SWITCH	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
STROBE	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
SUB-PANEL	Does not exist
TAMPER FLOW SWITCH/CHAIN	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K167

Question	Response
GYMNASIUM	
Instance	Ground Floor - East
LIGHTING	
Instance on Ground Floor - East	Inspected
Lighting Fixture - Fluorescent	
Instance on Ground Floor - East	Inspected
Pendant Mounted	
Instance on Ground Floor - East	Does not exist
Recessed Mounted	
Instance on Ground Floor - East	Does not exist
Surface Mounted	
Instance on Ground Floor - East	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	31
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Ground Floor - East	Does not exist
Lighting Fixture - Incandescent	
Instance on Ground Floor - East	Does not exist
LOCAL SOUND SYSTEM	
Instance on Ground Floor - East	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
SCOREBOARD	
Instance on Ground Floor - East	Does not exist
THEATER LIGHTING SYSTEM	
Instance on Ground Floor - East	Does not exist
INTERCOM SYSTEM	
Instance	Does not exist
KITCHEN/WARMING PANTRY	
Instance	Inspected
Instance	Ground Floor - West
LIGHTING	
Instance on Ground Floor - West	Inspected
Lighting Fixture - Fluorescent	
Instance on Ground Floor - West	Inspected
Pendant Mounted	
Instance on Ground Floor - West	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Ground Floor - West	Does not exist
Surface Mounted	
Instance on Ground Floor - West	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K167

Question	Response
KITCHEN/WARMING PANTRY	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Ground Floor - West	Does not exist
Lighting Fixture - Incandescent	
Instance on Ground Floor - West	Does not exist
LAN	Inspected
LOCAL DISTRIBUTION FRAME (I/LDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
MAIN EQUIPMENT RACK (MDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	Room 305
Has LAN/Modem access	Yes
LIGHTING	
Instance on Room 305	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 305	Inspected
Pendant Mounted	
Instance on Room 305	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	36
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K167

Question	Response
LIBRARY	
LIGHTING	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Instance on Room 305	Does not exist
Surface Mounted	
Instance on Room 305	Does not exist
Lighting Fixture - HID	
Instance on Room 305	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 305	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 305	Does not exist
SMART BOARD	
Instance on Room 305	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
LIGHTING - SECURITY LIGHTS	Inspected
Condition	2- Between Good and Fair
Replacement Quantity	28
Replacement Uom	EACH
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	Does not exist
LOCKER ROOM	Does not exist
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Mechanical Space in Basement
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
FUSED DISCONNECT SWITCH TYPE	Does not exist
FUSED KNIFE SWITCH TYPE	Does not exist
FUSED TOGGLE SWITCH TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Old Switchboard Room - Basement
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MOLDED CASE CIRCUIT BREAKER TYPE	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	Inspected
Instance	General Office - Room 109

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K167

Question	Response
PUBLIC ADDRESS SYSTEM	
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	DUKANE 250
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	Does not exist
SECURITY	Inspected
INTRUSION ALARM	Inspected
Central Control Panel	Inspected
Instance	Old -Custodians Office in vicinity of Cafeteria
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	ADEMCO VISTA 128B
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	Inspected
Condition	3- Fair
Deficiency	SENSOR NOT IN USE
Deficiency Location/Instance	Kitchen
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
IPDVS/CCTV SYSTEM	Inspected
Condition	4- Between Fair and Poor
Deficiency	CAMERA NOT OPERATIONAL
Deficiency Location/Instance	Cameras 1, 3, 5, 6, 7, 8 , 9, 10, 11, 12, 13, 14, 15, 16
Deficiency Quantity	14
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
SERVICE SWITCH	Inspected
Instance	Electrical Equipment Room - Basement
Instance Condition	1- Good
Instance Quantity	1

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K167

Question	Response
SERVICE SWITCH	
Instance Quantity Uom	EACH
Manufacturer	PS PRECISION SWITCHBOARD / BOLTSWITCH
EquipmentId	Service Switch #1
Capacity/Size	1200 Amps
Source of Capacity/Size	Nameplate
Installation Year	2007
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SWIMMING POOL	
	Does not exist
SWITCHBOARD	
	Inspected
Water Penetration In Electrical Room?	No
Number of Spares	0
AIR CIRCUIT BREAKER TYPE	
	Does not exist
FUSED DISCONNECT SWITCH TYPE	
	Inspected
Instance	Electrical Equipment Room - Basement
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Precision Switchboard Co.
EquipmentId	N/A
Capacity/Size	1200 Amps total, 2 sections
Source of Capacity/Size	Service Switch Size
Installation Year	2007
Source of Installation Year	Documented
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED KNIFE SWITCH TYPE	
	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	
	Does not exist
TELEPHONE	
	Inspected
PBX/INTERCOM	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
STANDARD	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	
	Inspected
LIGHTING	
	Inspected
Lighting Fixture - Fluorescent	
Pendant Mounted	
	Inspected
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	1
Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K167

Question	Response
TOILET ROOM - STAFF	
LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TOILET ROOM - STUDENT	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable System Exist?	Yes
Operational?	Yes
Master Antenna System Exist?	No
MAIN EQUIPMENT RACK	Does not exist