

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K167**

School: **P.S. 167 - BROOKLYN, 1025 EASTERN PKWY, BROOKLYN, NY, 11213**

InspectionId	Inspection Type	Time In	Last Edited
1196042	ELECTRICAL	2009-01-16 08:09AM	2009-01-23 11:29AM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Partial Emergency Lights Years: 2008 Systems: Battery Pack Exit Lights Years: 2002 Systems: Security System Years: 2002 Systems: Fluorescent Lighting in Bathrooms and Boiler Room Years: 1999 Systems: Fluorescent Lighting in Stairwells Years: 2008 Systems: LAN and PBX/ Intercom Years: 2002 Systems: Partial Motor Starters Years: 1999 Systems: Electric Service including panel boards Years: 2007

**Priority Condition**

No condition recorded

**Inspection**

Question	Response
<b>ELECTRICAL</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance	Ground Floor
<b>House Lighting</b>	
Instance on Ground Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Ground Floor	Inspected
<b>Pendant Mounted</b>	
Instance on Ground Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	86
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Ground Floor	Does not exist
<b>Surface Mounted</b>	
Instance on Ground Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Ground Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Ground Floor	Inspected
<b>Pendant Mounted</b>	
Instance on Ground Floor	Inspected
Instance Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K167**

Question	Response
<b>AUDITORIUM</b>	
<b>House Lighting</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Pendant Mounted</b>	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Ground Floor	Does not exist
<b>Surface Mounted</b>	
Instance on Ground Floor	Does not exist
<b>Local Sound System</b>	
Instance on Ground Floor	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Projection System</b>	
Instance on Ground Floor	Inspected
Instance Condition	3- Fair
Deficiency	NOT CONNECTED TO LOCAL SOUND SYSTEM
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL CONNECTION
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Theater Lighting System</b>	
Instance on Ground Floor	Does not exist
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	
Condition	Inspected
Condition	3- Fair
Replacement Quantity	77,000
Replacement Uom	S.F.
Deficiency	No deficiencies recorded
<b>CAFETERIA</b>	
Instance	Inspected
Instance	Ground Floor
<b>Lighting</b>	
Instance on Ground Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Ground Floor	Inspected
<b>Pendant Mounted</b>	
Instance on Ground Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on Ground Floor	Does not exist
<b>Surface Mounted</b>	
Instance on Ground Floor	Inspected
Instance Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K167**

<b>Question</b>	<b>Response</b>
<b>CAFETERIA</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	33
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
Instance on Ground Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Ground Floor	Does not exist
<b>Local Sound System</b>	
Instance on Ground Floor	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>CAFETERIA/MULTIPURPOSE ROOM</b>	
	Does not exist
<b>CITY FIRE ALARM SYSTEM</b>	
Condition	Inspected
Deficiency	3- Fair
	No deficiencies recorded
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1,075
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
	Does not exist
<b>Surface Mounted</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	62
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
	Does not exist
<b>Lighting Fixture - Incandescent</b>	
	Inspected

NYC Department of Education  
Building Condition Assessment Survey 2008-2009

*Electrical Inspection*

K167

Question	Response
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>COMPUTER LAB</b>	Inspected
Instance	Room 409
Has LAN/Modem access	Yes
Power Panel?	Yes
<b>Lighting</b>	
Instance on Room 409	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 409	Inspected
<b>Pendant Mounted</b>	
Instance on Room 409	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 409	Does not exist
<b>Surface Mounted</b>	
Instance on Room 409	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 409	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 409	Does not exist
<b>Raceway With Receptacles</b>	
Instance on Room 409	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>ELECTRIC SERVICE SWITCH</b>	Inspected
Instance	Electrical Room #1
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Precision Switchboard
Model	Precision Switchboard
EquipmentId	Service Switch #1
Capacity/Size	1200 Amps
Installation Year	2007

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K167**

<b>Question</b>	<b>Response</b>
<b>ELECTRIC SERVICE SWITCH</b>	
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Corridors, Cafeteria and Boiler Room
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Connected To Emergency Generator System</b>	Does not exist
<b>Connected To Emergency Light/Exit Light Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Relay Test Switch</b>	Inspected
Condition	5- Poor
Deficiency	NOT OPERATIONAL
Deficiency Location/Instance	Cafeteria, Gym and Auditorium
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>EXIT LIGHT</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Connected To Emergency Generator System</b>	Does not exist
<b>Connected To Emergency Light/Exit Light Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>FIRE ALARM SYSTEM</b>	Inspected
Replacement Quantity	77,000
Replacement Uom	S.F.
<b>Area Smoke Detector</b>	Does not exist
<b>Bell/Horn</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Duct Smoke Detector</b>	Does not exist
<b>Elevator Recall</b>	Does not exist
<b>Fan Shutdown Control</b>	Does not exist
<b>Fire Alarm Digital Communicator</b>	Does not exist
<b>Fused Cutout Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Heat Detector</b>	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K167**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>Magnetic Door Holder Contactor</b>	Does not exist
<b>Main Panel</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Does not exist
<b>Fire Alarm Control Panel (Standard)</b>	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards
EquipmentId	Fire Alarm Control Panel
Capacity/Size	7 circuits
Installation Year	1956
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Manual Pull Station</b>	Inspected
Condition	3- Fair
Deficiency	PULL STATION NOT OPERATIONAL
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Remote Annunciator</b>	Does not exist
<b>Sprinkler Flow/Air Pressure Switch</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Strobe</b>	Does not exist
<b>Sub-Panel</b>	Does not exist
<b>Tamper Flow Switch/Chain</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GROUNDING SYSTEM</b>	Inspected
Condition	4- Between Fair and Poor
Deficiency	GROUNDING IMPROPERLY BONDED
Deficiency Location/Instance	Boiler Room Water Main
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>GYMNASIUM</b>	Inspected
Instance	Ground Floor
<b>Lighting</b>	
Instance on Ground Floor	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K167**

Question	Response
<b>GYMNASIUM</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
Instance on Ground Floor	Inspected
<b>Pendant Mounted</b>	
Instance on Ground Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on Ground Floor	Does not exist
<b>Surface Mounted</b>	
Instance on Ground Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	33
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
Instance on Ground Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Ground Floor	Does not exist
<b>Local Sound System</b>	
Instance on Ground Floor	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Scoreboard</b>	
Instance on Ground Floor	Does not exist
<b>Theater Lighting System</b>	
Instance on Ground Floor	Does not exist
<b>INTERCOM SYSTEM</b>	
	Does not exist
<b>KITCHEN/WARMING PANTRY</b>	
	Inspected
<b>Lighting</b>	
	Inspected
<b>Lighting Fixture - Fluorescent</b>	
	Inspected
<b>Pendant Mounted</b>	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
	Does not exist
<b>Surface Mounted</b>	
	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K167**

<b>Question</b>	<b>Response</b>
<b>KITCHEN/WARMING PANTRY</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>LAN</b>	Inspected
<b>Local Distribution Frame (I/LDF)</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Main Equipment Rack (MDF)</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>LIBRARY</b>	Inspected
Instance	Room 305
Has LAN/Modem access	Yes
<b>Lighting</b>	
Instance on Room 305	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 305	Inspected
<b>Pendant Mounted</b>	
Instance on Room 305	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	36
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 305	Does not exist
<b>Surface Mounted</b>	
Instance on Room 305	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 305	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 305	Does not exist
<b>Raceway With Receptacles</b>	
Instance on Room 305	Does not exist
<b>LIGHTING - EXTERIOR SECURITY</b>	Inaccessible
<b>LIGHTNING PROTECTION</b>	Does not exist
<b>LOCKER ROOM/SHOWER ROOM</b>	Does not exist
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K167**

<b>Question</b>	<b>Response</b>
<b>MOTOR STARTER/CONTACTOR</b>	
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MULTIPURPOSE ROOM</b>	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>Fused Disconnect Switch Type</b>	Does not exist
<b>Fused Knife Switch Type</b>	Does not exist
<b>Fused Toggle Switch Type</b>	Does not exist
<b>Molded Case Circuit Breaker Type</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>PUBLIC ADDRESS SYSTEM</b>	Inspected
Replacement Quantity	77,000
Replacement Uom	S.F.
Instance	General Office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Deficiency	AMPLIFIER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	General Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	MASTER CLOCK NOT OPERATIONAL
Deficiency Location/Instance	General Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SCIENCE DEMO ROOM</b>	Does not exist
<b>SCIENCE LAB</b>	Does not exist
<b>SCIENCE PREP ROOM</b>	Does not exist
<b>SECURITY</b>	Inspected
Replacement Quantity	77,000
Replacement Uom	S.F.
<b>Intrusion Alarm</b>	Inspected
<b>Central Control Panel</b>	Inspected
Instance	Fireman's Office
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	VISTA 128B
Deficiency	No deficiencies recorded
<b>Infrared Sensor</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K167**

<b>Question</b>	<b>Response</b>
<b>SECURITY</b>	
<b>Intrusion Alarm</b>	
<b>Infrared Sensor</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Ultrasonic Sensor</b>	
Condition	Does not exist
<b>IPDVS/CCTV System</b>	
Condition	Inspected
Deficiency	5- Poor
Deficiency Location/Instance	CAMERA NOT OPERATIONAL
Deficiency Quantity	Interior and Exterior Spaces of Building
Quantity Uom	14
Potential Action	EACH
Urgency of Action	REPLACE
Purpose of Action	PRIORITY 4
Violations	LEVEL 3
Violations	No violations recorded
<b>SWIMMING POOL</b>	
Condition	Does not exist
<b>SWITCHBOARD</b>	
Condition	Inspected
<b>Air Circuit Breaker Type</b>	
Condition	Does not exist
<b>Fused Disconnect Switch Type</b>	
Instance	Inspected
Instance Condition	Electrical Room #2
Instance Quantity	1- Good
Instance Quantity Uom	1
Instance Quantity Uom	EACH
Manufacturer	Precision Switchboard
EquipmentId	N/A
Capacity/Size	1200 Amps total, 3 sections
Installation Year	2007
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Fused Knife Switch Type</b>	
Condition	Does not exist
<b>Molded Case Circuit Breaker Type</b>	
Condition	Does not exist
<b>TELEPHONE</b>	
Condition	Inspected
<b>PBX/Intercom</b>	
Condition	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K167**

<b>Question</b>	<b>Response</b>
<b>TELEPHONE</b>	
<b>PBX/Intercom</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Standard</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>TOILET ROOM - STAFF</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist

NYC Department of Education  
Building Condition Assessment Survey 2008-2009

*Electrical Inspection*

K167

Question	Response
<b>TOILET ROOM - STUDENT</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
Surface Mounted	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TRANSFORMER</b>	Does not exist
<b>TV SYSTEM</b>	Inspected
<b>Cable Service</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Main Equipment Rack</b>	Does not exist
<b>Master Antenna System</b>	Does not exist