

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K180

School: P.S. 180 - BROOKLYN, 5601 16TH AVENUE, BROOKLYN, NY, 11204

InspectionId	Inspection Type	Time In	Last Edited
2060017	MECHANICAL	2010-10-27 08:42AM	2010-11-03 03:10PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Science Lab Room 407, 3rd, 4th, 5th Floor Girls Bathrooms Years: 2009 Systems: DX Split System for MDF Room Years: 2003 Systems: Heating Plant, Gas Meter Room, Sump Pumps (2 of 2), Gas fired Domestic Hot Water Heater, Hot Water Circulating Pumps Years: 2001 Systems: Grease Trap (1 of 1) Years: 2010
Are there fuel tanks?	Yes
Total # of above ground tanks	1
Total capacity of all above ground tanks in gal.	10,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0

Priority Condition

No condition recorded

Inspection

Question	Response
MECHANICAL	
AIR CONDITIONING	Does not exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not exist
CLIMATE CONTROL SYSTEM	Inspected
DDC SYSTEM	Does not exist
ELECTRIC SYSTEM	Does not exist
HYBRID SYSTEM	Does not exist
PNEUMATIC SYSTEM	Inspected
Instance	Classrooms and offices throughout
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	DEFECTIVE TEMPERATURE CONTROL ZONE VALVE
Deficiency Location/Instance	Basement MER
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	Throughout
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE TERMINAL UNIT THERMOSTATIC VALVE
Deficiency Location/Instance	Cafeteria, 5th Floor Gym

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K180

Question	Response
CLIMATE CONTROL SYSTEM	
PNEUMATIC SYSTEM	
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
COMPACTOR	Does not exist
CONVEYING	Inspected
ASH HOIST	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
DUMBWAITERS	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
ELEVATORS	Does not exist
ESCALATORS	Does not exist
Non-auditorium Handicap Lift - Stair	Does not exist
Non-auditorium Handicap Lift - Vertical	Does not exist
SIDEWALK ELEVATOR	Does not exist
DOMESTIC WATER SYSTEM	Inspected
DOMESTIC COLD WATER SYSTEM	Inspected
Gravity System	Does not exist
Pressure Booster System	Inspected
Electric Pressure Booster System	Does not exist
Hydraulic/Pneumatic Booster System	Inspected
Domestic Cold Water Tank	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Pressure Booster Pump	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Water Pressure Booster - Compressor	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Water Service	Inspected
Service Piping (Water Main)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Water Main - Double Check Valve	Does not exist
Water Main - RPZ	Does not exist
DOMESTIC HOT WATER SYSTEM	Inspected
Domestic Hot Water Circulating Pump	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Boiler Room (1 of 2)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Domestic Hot Water Remote Storage Tank	Does not exist
Domestic Water Heat Exchanger	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K180

Question	Response
DOMESTIC WATER SYSTEM	
DOMESTIC HOT WATER SYSTEM	
Electric Domestic Water Heater	Does not exist
Gas Fired Domestic Water Heater	Inspected
Instance	Basement
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	PVI
EquipmentId	N/A
Capacity/Size	399 MBH /400 Gallons
Installation Year	2001
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not exist
DOMESTIC WATER DISTRIBUTION PIPING	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE ISOLATION VALVE
Deficiency Location/Instance	1st Floor Boys, 1st Floor Girls, 5th Floor Girls/ Defective hot and cold water valves.
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Throughout
Deficiency Quantity	3,000
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
HOUSE TRAP	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
INTERIOR FLOOR DRAIN	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
INTERIOR STORM PIPING	Inspected
Condition	3- Fair
Deficiency	BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Throughout
Deficiency Quantity	1,250
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	5th Floor Gym
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K180

Question	Response
DRAIN/WASTE/VENT AND STORM SYSTEM	
INTERIOR STORM PIPING	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Boiler Room Pipe Chase
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SEWAGE / WASTE PIPING	
Condition	Inspected
Condition	3- Fair
Deficiency	BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Throughout
Deficiency Quantity	833
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Staircase 5/6 and 7/8 between 2nd and 3rd Floor/ Leaking waste line from drinking fountains.
Deficiency Quantity	60
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SEWAGE EJECTOR PUMP	Does not exist
SUMP PUMP	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
VENT PIPING	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	
Does not exist	
FIXTURES	Inspected
STAFF AND OTHER	Inspected
Janitor Sink	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Urinal	Does not exist
STUDENT	Inspected
Drinking Fountain	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K180

Question	Response
FIXTURES	
STUDENT	
Drinking Fountain	
Deficiency Location/Instance	5th Floor
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lavatory/Sink	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
Locker Room Shower	
Condition	Inspected
Instance on Room 559M	Inspected
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Alternative Use	Yes
Deficiency	NOT IN USE
Deficiency Location/Instance	Room 559M
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Sink And Fountain Combo Unit	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
Toilet	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
Urinal	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	
Condition	Does not exist
GAS SERVICE	
Condition	Inspected
CO/GAS LEAK DETECTION	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
GAS DISTRIBUTION PIPING	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
GAS METER ROOM EXHAUST FAN	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
GAS METER ROOM VENT	
Condition	Inspected
Deficiency	1- Good
Deficiency	No deficiencies recorded
GAS PRESSURE BOOSTER	
Condition	Does not exist
HEATING	
Condition	Inspected
BASEBOARD/FIN TUBE	
Condition	Does not exist
HEATING COILS IN DUCTWORK	
Condition	Inspected
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K180

Question	Response
HEATING	
HEATING COILS IN DUCTWORK	
Deficiency	BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Basement MER (5 of 5)
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
HYDRONIC HEATING	
	Does not exist
RADIATOR / CONVECTOR	
	Inspected
Condition	3- Fair
Deficiency	BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Throughout
Deficiency Quantity	165
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
STEAM HEATING	
	Inspected
F&T/Steam Drip Trap	
	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Basement
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
MER Steam and Condensate Piping	
	Inspected
Condition	3- Fair
Deficiency	BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Basement MER
Deficiency Quantity	100
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Steam Condensate Return Piping	
	Inspected
Condition	3- Fair
Deficiency	BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Throughout
Deficiency Quantity	1,700
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Steam Condensate Return Pumping System	
	Inspected
Condition	2- Between Good and Fair
Deficiency	DEFECTIVE PUMP
Deficiency Location/Instance	Boiler Room/ Leaking pump (1 of 4).
Deficiency Quantity	1

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K180

Question	Response
HEATING	
STEAM HEATING	
Steam Condensate Return Pumping System	
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 1
Violations	No violations recorded
Steam Piping	
Condition	Inspected
Condition	3- Fair
Deficiency	BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Throughout
Deficiency Quantity	1,700
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Terminal Unit Thermostatic Trap	
Condition	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Throughout
Deficiency Quantity	36
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
STEAM SUPPLIED BY EXTERNAL SOURCES	
Does not exist	
UNIT HEATER/CABINET HEATER	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	4th Floor Boys Bathroom (1 of 2)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
HEATING PLANT	
Condition	Inspected
Replacement Quantity	12,996
Replacement Uom	MBH
Instance	Basement
Burner Type	Dual Fuel (Gas / Oil)
Heating Plant Oil Number	2
BOILER AUXILIARIES	
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K180

Question	Response
HEATING PLANT	
BOILER AUXILIARIES	
Boiler Feedwater System	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Flue Exhaust	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Instance Condition	1- Good
Deficiency	DEFECTIVE/LEAKING HEADER VALVE
Deficiency Location/Instance	Basement/ Defective header valve gasket leaking near boiler #2.
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Boiler Safety Valve	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
BOILER SYSTEM	
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not exist
Hot Water Boiler	
Instance on Basement	Does not exist
Modular Boiler	
Instance on Basement	Does not exist
Steam Boiler	
Instance on Basement	Inspected
Instance	Basement
Instance Condition	1- Good
Instance Quantity	6,498
Instance Quantity Uom	MBH
Manufacturer	A.L. Eastmond & Sons
EquipmentId	7882-01
Capacity/Size	6498 MBH Net
Installation Year	2001
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Basement
Instance Condition	1- Good

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K180

Question	Response
HEATING PLANT	
BOILER SYSTEM	
Steam Boiler	
Instance Quantity	6,498
Instance Quantity Uom	MBH
Manufacturer	A.L. Eastmond & Sons
EquipmentId	7882-02
Capacity/Size	6498 MBH Net
Installation Year	2001
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
FUEL SYSTEMS	
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	DEFECTIVE ACTUATOR
Deficiency Location/Instance	Basement/ Boiler #1 damper actuator defective (1 of 3).
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	BURNER CONTROL PANEL:DEFECTIVE
Deficiency Location/Instance	Basement/ Smoke eye defective on boiler #1.
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Gas Trains And Vent At The Boiler	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
IDF (ENCLOSED ROOMS)	
Instance	Room 458
A/C EQUIPMENT	
Instance on Room 458	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Room 458
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K180

Question	Response
IDF (ENCLOSED ROOMS)	
VENTILATION EQUIPMENT	
Instance on Room 458	Does not exist
KITCHEN	Inspected
Instance	1st Floor
CO DETECTOR	
Instance on 1st Floor	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	DETECTOR MISSING
Deficiency Location/Instance	1st Floor
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
GAS SYSTEM	
Instance on 1st Floor	Does not exist
GREASE TRAP	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
HOOD	
Instance on 1st Floor	Does not exist
HOOD EXHAUST DUCTWORK	
Instance on 1st Floor	Does not exist
HOOD EXHAUST FAN	
Instance on 1st Floor	Does not exist
HOOD FIRE SUPPRESSION SYSTEM	
Instance on 1st Floor	Does not exist
HOT WATER TEMPERATURE BOOSTER	
Instance on 1st Floor	Does not exist
KITCHEN SINK	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
MDF ROOM	Inspected
Instance	Room 254
A/C EQUIPMENT	
Instance on Room 254	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
VENTILATION EQUIPMENT	
Instance on Room 254	Does not exist
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	
Instance on Room 407	Inspected
Alternative Use	No
ACID WASTE NEUTRALIZING TANK	
Instance on Room 407	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
CO DETECTOR	
Instance on Room 407	Inspected
Instance Condition	1- Good

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K180

Question	Response
SCIENCE LAB	
CO DETECTOR	
Deficiency	No deficiencies recorded
EMERGENCY SHOWER	
Instance on Room 407	Does not exist
EYE WASH	
Instance on Room 407	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Room 407 (1 of 1)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
FIXED LABORATORY HOOD	
Instance on Room 407	Does not exist
HOOD EXHAUST DUCTWORK	
Instance on Room 407	Does not exist
HOOD EXHAUST FAN	
Instance on Room 407	Does not exist
LABORATORY SINK	
Instance on Room 407	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
MAKE-UP AIR UNIT	
Instance on Room 407	Does not exist
PORTABLE LABORATORY HOOD	
Instance on Room 407	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
SCIENCE PREP ROOM	
Does not exist	
SPRINKLERS, STANDPIPE, FIRE SYSTEM	
Inspected	
DELUGE VALVE	
Does not exist	
FIRE BOOSTER PUMP ASSEMBLY	
Does not exist	
ROOF TANK	
Does not exist	
SIAMESE CONNECTION	
Does not exist	
SPRINKLER ALARM VALVE ASSEMBLY	
Does not exist	
SPRINKLER HEAD	
Condition	3- Fair
Deficiency	No deficiencies recorded
SPRINKLER PIPING	
Condition	3- Fair
Deficiency	No deficiencies recorded
STANDPIPE SYSTEM	
Does not exist	
WATER GONG	
Does not exist	
SWIMMING POOL	
Does not exist	
VENTILATION	
Inspected	
EXHAUST FAN	
Condition	3- Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Basement/ 1st Floor Playroom Exhaust Fan (1 of 9).
Deficiency Quantity	1
Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

K180

Question	Response
VENTILATION	
EXHAUST FAN	
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
HEATING AND VENTILATING UNIT	
	Does not exist
METAL DUCTWORK	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
SUPPLY FAN	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
UNIT VENTILATOR	
	Inspected
Condition	3- Fair
Deficiency	BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Throughout
Deficiency Quantity	72
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded