

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K210**

School: **I.S. 394 - BROOKLYN, 188 ROCHESTER AVENUE, BROOKLYN, NY, 11213**

InspectionId	Inspection Type	Time In	Last Edited
1251016	ELECTRICAL	2008-12-10 08:32AM	2009-04-02 04:05PM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: PAS Years: 2007 Systems: Switchboard, Panel boards, Fire Alarm system, Emergency and Exit lighting, Motor starters, Security alarm, Interior an Exterior lighting Years: 1998

**Priority Condition**

Condition Description	Component Affected	Location Description	Person(s) Notified
Water in the Electrical Room	Main Service SWBD and 1 Switch Board _ 3 sections.	Room BO4 -Basement	Kevin Fitzgerald

**Inspection**

Question	Response
<b>ELECTRICAL</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance	First Floor
<b>House Lighting</b>	
Instance on First Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on First Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on First Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on First Floor	Inspected
<b>Pendant Mounted</b>	
Instance on First Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	INSTALL NEW LAMP
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on First Floor	Does not exist
<b>Surface Mounted</b>	
Instance on First Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Local Sound System</b>	
Instance on First Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on First Floor	Does not exist
<b>Theater Lighting System</b>	
Instance on First Floor	Inspected
<b>Dimming System</b>	
Instance on First Floor	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K210**

<b>Question</b>	<b>Response</b>
<b>AUDITORIUM</b>	
<b>Theater Lighting System</b>	
<b>Theater Lighting</b>	
Instance on First Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	26
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	
Condition	3- Fair
Replacement Quantity	108,000
Replacement Uom	S.F.
Deficiency	No deficiencies recorded
<b>CAFETERIA</b>	
	Does not exist
<b>CAFETERIA/MULTIPURPOSE ROOM</b>	
Instance	Inspected
Instance	First Floor
<b>Lighting</b>	
Instance on First Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on First Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on First Floor	Inspected
<b>Pendant Mounted</b>	
Instance on First Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on First Floor	Does not exist
<b>Surface Mounted</b>	
Instance on First Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - Incandescent</b>	
Instance on First Floor	Does not exist
<b>Local Sound System</b>	
Instance on First Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Theater Lighting System</b>	
Instance on First Floor	Does not exist
<b>CITY FIRE ALARM SYSTEM</b>	
Condition	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
Lighting	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Condition	Inspected
<b>Pendant Mounted</b>	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	INSTALL NEW LAMP

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K210**

Question	Response
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	INSTALL NEW LAMP
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>COMPUTER LAB</b>	Inspected
Instance	Room #414
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room #314
Has LAN/Modem access	Yes
Power Panel?	No
<b>Lighting</b>	
Instance on Room #414	Inspected
Instance on Room #314	Under construction
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room #414	Inspected
<b>Pendant Mounted</b>	
Instance on Room #414	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room #414	Does not exist
<b>Surface Mounted</b>	
Instance on Room #414	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room #414	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room #414	Does not exist
<b>Raceway With Receptacles</b>	
Instance on Room #414	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room #314	Under construction
<b>ELECTRIC SERVICE SWITCH</b>	Inspected
Instance	Electrical Room # B04 - Basement

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K210**

<b>Question</b>	<b>Response</b>
<b>ELECTRIC SERVICE SWITCH</b>	
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Electrotech Service Equipment Corp.
Model	Electrotech Service Equipment Corp.
EquipmentId	Main Disconnect.
Capacity/Size	2500 Amps
Installation Year	1998
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	
	Does not exist
<b>EMERGENCY GENERATOR SET</b>	
	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	
	Inspected
<b>Battery Pack</b>	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency Location/Instance	FIXTURE NOT OPERATIONAL
Deficiency Quantity	Front of Auditorium Area / First Floor
Quantity Uom	3
Potential Action	EACH
Urgency of Action	REPLACE
Purpose of Action	PRIORITY 5
Violations	LEVEL 2
	No violations recorded
<b>Connected To Emergency Generator System</b>	
	Does not exist
<b>Connected To Emergency Light/Exit Light Panel</b>	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Relay Test Switch</b>	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	
	Inspected
<b>Battery Pack</b>	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency Location/Instance	FIXTURE NOT OPERATIONAL
Deficiency Quantity	5th floor corridor
Quantity Uom	1
Potential Action	EACH
Urgency of Action	REPAIR
Purpose of Action	PRIORITY 5
Violations	LEVEL 2
	No violations recorded
<b>Connected To Emergency Generator System</b>	
	Does not exist
<b>Connected To Emergency Light/Exit Light Panel</b>	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>FIRE ALARM SYSTEM</b>	
	Inspected
Replacement Quantity	108,000
Replacement Uom	S.F.
<b>Area Smoke Detector</b>	
Condition	Inspected
Deficiency	2- Between Good and Fair
	No deficiencies recorded
<b>Bell/Horn</b>	
	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K210**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>Bell/Horn</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Duct Smoke Detector</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Elevator Recall</b>	
	Does not exist
<b>Fan Shutdown Control</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Digital Communicator</b>	
	Does not exist
<b>Fused Cutout Panel</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Heat Detector</b>	
	Does not exist
<b>Magnetic Door Holder Contactor</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Main Panel</b>	
	Inspected
<b>Bell At Panel</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	
Instance	Main Lobby
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	IRC -3
EquipmentId	Fire Alarm Control Panel
Capacity/Size	16 zones
Installation Year	1998
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Standard)</b>	
	Does not exist
<b>Manual Pull Station</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	
	Inspected
<b>Display Monitor</b>	
	Does not exist
<b>Panel</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Printer</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Punch Register</b>	
	Does not exist
<b>Sprinkler Flow/Air Pressure Switch</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Strobe</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Sub-Panel</b>	
	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K210**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>Tamper Flow Switch/Chain</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>GROUNDING SYSTEM</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	
Instance	Gym.1 / Third Floor
Instance	Gym 2 / Fith Floor
<b>Lighting</b>	
Instance on Gym.1 / Third Floor	Inspected
Instance on Gym 2 / Fith Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Gym.1 / Third Floor	Inspected
Instance on Gym 2 / Fith Floor	Inspected
<b>Pendant Mounted</b>	
Instance on Gym.1 / Third Floor	Does not exist
Instance on Gym 2 / Fith Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on Gym.1 / Third Floor	Does not exist
Instance on Gym 2 / Fith Floor	Does not exist
<b>Surface Mounted</b>	
Instance on Gym.1 / Third Floor	Does not exist
Instance on Gym 2 / Fith Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Gym.1 / Third Floor	Inspected
Instance on Gym 2 / Fith Floor	Inspected
<b>Pendant Mounted</b>	
Instance on Gym.1 / Third Floor	Does not exist
Instance on Gym 2 / Fith Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on Gym.1 / Third Floor	Does not exist
Instance on Gym 2 / Fith Floor	Does not exist
<b>Surface Mounted</b>	
Instance on Gym.1 / Third Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Gym 2 / Fith Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - Incandescent</b>	
Instance on Gym.1 / Third Floor	Does not exist
Instance on Gym 2 / Fith Floor	Does not exist
<b>Local Sound System</b>	
Instance on Gym.1 / Third Floor	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Gym 2 / Fith Floor	Inspected

NYC Department of Education  
Building Condition Assessment Survey 2008-2009

*Electrical Inspection*

K210

Question	Response
<b>GYMNASIUM</b>	
<b>Local Sound System</b>	
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Scoreboard</b>	
Instance on Gym.1 / Third Floor	Does not exist
Instance on Gym 2 / Fith Floor	Does not exist
<b>Theater Lighting System</b>	
Instance on Gym.1 / Third Floor	Does not exist
Instance on Gym 2 / Fith Floor	Does not exist
<b>INTERCOM SYSTEM</b>	
	Does not exist
<b>KITCHEN/WARMING PANTRY</b>	
	Inspected
<b>Lighting</b>	
	Inspected
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
	Does not exist
<b>Recessed Mounted</b>	
	Does not exist
<b>Surface Mounted</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
	Does not exist
<b>Lighting Fixture - Incandescent</b>	
	Does not exist
<b>LAN</b>	
	Inspected
<b>Local Distribution Frame (I/LDF)</b>	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Main Equipment Rack (MDF)</b>	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>LIBRARY</b>	
	Inspected
Instance	Room # 208
Has LAN/Modem access	Yes
<b>Lighting</b>	
Instance on Room # 208	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room # 208	Inspected
<b>Pendant Mounted</b>	
Instance on Room # 208	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL NEW LAMP
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room # 208	Does not exist
<b>Surface Mounted</b>	
Instance on Room # 208	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room # 208	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room # 208	Does not exist
<b>Raceway With Receptacles</b>	
Instance on Room # 208	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K210**

<b>Question</b>	<b>Response</b>
<b>LIBRARY</b>	
<b>Raceway With Receptacles</b>	
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>LIGHTING - EXTERIOR SECURITY</b>	Inaccessible
<b>LIGHTNING PROTECTION</b>	Under construction
<b>LOCKER ROOM/SHOWER ROOM</b>	Inspected
Instance	Gym 1, Third Floor
Alternative Use	No
<b>Lighting</b>	
Instance on Gym 1, Third Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Gym 1, Third Floor	Inspected
<b>Pendant Mounted</b>	
Instance on Gym 1, Third Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Gym 1, Third Floor	Does not exist
<b>Surface Mounted</b>	
Instance on Gym 1, Third Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Gym 1, Third Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Gym 1, Third Floor	Does not exist
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>MULTIPURPOSE ROOM</b>	Inspected
Instance	First Floor
<b>Lighting</b>	
Instance on First Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on First Floor	Inspected
<b>Pendant Mounted</b>	
Instance on First Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on First Floor	Does not exist
<b>Surface Mounted</b>	
Instance on First Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on First Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on First Floor	Does not exist
<b>Local Sound System</b>	
Instance on First Floor	Does not exist
<b>Theater Lighting System</b>	
Instance on First Floor	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>Fused Disconnect Switch Type</b>	Does not exist
<b>Fused Knife Switch Type</b>	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K210**

<b>Question</b>	<b>Response</b>
<b>PANEL BOARD</b>	
Fused Toggle Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>PUBLIC ADDRESS SYSTEM</b>	
	Inspected
Replacement Quantity	108,000
Replacement Uom	S.F.
Instance	General Office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Rauland TeleCenter /
Deficiency	AMPLIFIER POORLY VENTILATED
Deficiency Location/Instance	General Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SCIENCE DEMO ROOM</b>	
	Inspected
Instance	Rooms # 401, #405
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	Room #409
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
<b>Emergency Gas Shut-Off Valve</b>	
Instance on Rooms # 401, #405	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room #409	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Emergency Shut-Off Power</b>	
Instance on Rooms # 401, #405	Does not exist
Instance on Room #409	Does not exist
<b>Lighting</b>	
Instance on Rooms # 401, #405	Inspected
Instance on Room #409	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Rooms # 401, #405	Inspected
Instance on Room #409	Inspected
<b>Pendant Mounted</b>	
Instance on Rooms # 401, #405	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room #409	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K210**

Question	Response
<b>SCIENCE DEMO ROOM</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Recessed Mounted</b>	
Instance on Rooms # 401, #405	Does not exist
Instance on Room #409	Does not exist
<b>Surface Mounted</b>	
Instance on Rooms # 401, #405	Does not exist
Instance on Room #409	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Rooms # 401, #405	Does not exist
Instance on Room #409	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Rooms # 401, #405	Does not exist
Instance on Room #409	Does not exist
<b>Power Supply</b>	
Instance on Rooms # 401, #405	Does not exist
Instance on Room #409	Does not exist
<b>SCIENCE LAB</b>	Inspected
Instance	Room #407, #408
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
<b>Emergency Gas Shut-Off Valve</b>	
Instance on Room #407, #408	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Emergency Shut-Off Power</b>	
Instance on Room #407, #408	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting</b>	
Instance on Room #407, #408	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room #407, #408	Inspected
<b>Pendant Mounted</b>	
Instance on Room #407, #408	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room #407, #408	Does not exist
<b>Surface Mounted</b>	
Instance on Room #407, #408	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room #407, #408	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room #407, #408	Does not exist
<b>Power Supply</b>	
Instance on Room #407, #408	Inspected
<b>Instructor Unit</b>	
Instance on Room #407, #408	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Meter Demonstration Unit</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K210**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>Power Supply</b>	
<b>Meter Demonstration Unit</b>	
Instance on Room #407, #408	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Student Unit</b>	
Instance on Room #407, #408	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>SCIENCE PREP ROOM</b>	
Instance	Room #450
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	No
<b>Emergency Gas Shut-Off Valve</b>	
Instance on Room #450	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Emergency Shut-Off Power</b>	
Instance on Room #450	Does not exist
<b>Lighting</b>	
Instance on Room #450	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room #450	Inspected
<b>Pendant Mounted</b>	
Instance on Room #450	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room #450	Does not exist
<b>Surface Mounted</b>	
Instance on Room #450	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room #450	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room #450	Does not exist
<b>Power Supply</b>	
Instance on Room #450	Does not exist
<b>SECURITY</b>	
Replacement Quantity	108,000
Replacement Uom	S.F.
<b>Intrusion Alarm</b>	
<b>Central Control Panel</b>	
Instance	Custodian Office
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	ADEMCO - VISTA-50PU / VISTA-50PUL
Deficiency	No deficiencies recorded
<b>Infrared Sensor</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	
	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K210**

Question	Response
<b>SECURITY</b>	
<b>Intrusion Alarm</b>	
<b>Panic Switch</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Ultrasonic Sensor</b>	
	Does not exist
<b>IPDVS/CCTV System</b>	
	Does not exist
<b>SWIMMING POOL</b>	
	Does not exist
<b>SWITCHBOARD</b>	
	Inspected
<b>Air Circuit Breaker Type</b>	
	Does not exist
<b>Fused Disconnect Switch Type</b>	
Instance	Electrical Room # B04 -Basement
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Electrotech Service Equipment Corp..
EquipmentId	N/A
Capacity/Size	2500 Amps total, 3 sections
Installation Year	1998
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Fused Knife Switch Type</b>	
	Does not exist
<b>Molded Case Circuit Breaker Type</b>	
	Does not exist
<b>TELEPHONE</b>	
	Inspected
<b>PBX/Intercom</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Standard</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>TOILET ROOM - STAFF</b>	
	Inspected
<b>Lighting</b>	
	Inspected
<b>Lighting Fixture - Fluorescent</b>	
	Inspected
<b>Pendant Mounted</b>	
	Does not exist
<b>Recessed Mounted</b>	
	Does not exist
<b>Surface Mounted</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
	Does not exist
<b>Lighting Fixture - Incandescent</b>	
	Does not exist
<b>TOILET ROOM - STUDENT</b>	
	Inspected
<b>Lighting</b>	
	Inspected
<b>Lighting Fixture - Fluorescent</b>	
	Inspected
<b>Pendant Mounted</b>	
	Inspected

NYC Department of Education  
 Building Condition Assessment Survey 2008-2009

*Electrical Inspection*

**K210**

Question	Response
<b>TOILET ROOM - STUDENT</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TRANSFORMER</b>	Does not exist
<b>TV SYSTEM</b>	Inspected
<b>Cable Service</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Main Equipment Rack</b>	Does not exist
<b>Master Antenna System</b>	Does not exist