

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K210

School: **I.S. 394 - BROOKLYN, 188 ROCHESTER AVENUE, BROOKLYN, NY, 11213**

InspectionId	Inspection Type	Time In	Last Edited
2000009	ELECTRICAL	2010-10-15 07:54AM	2010-10-22 02:07PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Interior Lights, Exterior Lights Years: 1998 Systems: Telephone System, Smart Boards Years: 2008 Systems: Service Switch, Switchboard, Panel Boards, Motor Starters Years: 1998 Systems: PA System, Local Sound System, Fire Alarm System, Intrusion Alarm System Years: 1998 Systems: Exit / Emergency Lights (batteries) Years: 1998 Systems: Combo Exit Emergency Lights, Computer Room 314 Years: 2009
Type of Service	Below Ground

Priority Condition

Condition Description	Component Affected	Location Description	Person(s) Notified
Water penetration	None	Electrical Room	Fireman: Robert Triglianos

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	1st Floor
HOUSE LIGHTING	
Instance on 1st Floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K210

Question	Response
AUDITORIUM	
HOUSE LIGHTING	
Lighting Fixture - Incandescent	
Surface Mounted	
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
LOCAL SOUND SYSTEM	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	SPEAKER NOT OPERATIONAL
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
PROJECTION SYSTEM	
Instance on 1st Floor	Does not exist
THEATER LIGHTING SYSTEM	
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Does not exist
Theater Lighting	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	27
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA	
Instance	1st Floor
LIGHTING	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K210

Question	Response
CAFETERIA	
LIGHTING	
Lighting Fixture - HID	
Surface Mounted	
Deficiency	No deficiencies recorded
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
CITY FIRE ALARM SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
LIGHTING	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
SMART BOARD	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
COMPUTER LAB	Inspected
Instance	Room 314
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room 414
Has LAN/Modem access	Yes
Power Panel?	Yes
LIGHTING	
Instance on Room 314	Inspected
Instance on Room 414	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 314	Inspected
Instance on Room 414	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K210

Question	Response
COMPUTER LAB	
LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Instance on Room 314	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 414	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room 314	Does not exist
Instance on Room 414	Does not exist
Surface Mounted	
Instance on Room 314	Does not exist
Instance on Room 414	Does not exist
Lighting Fixture - HID	
Instance on Room 314	Does not exist
Instance on Room 414	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 314	Does not exist
Instance on Room 414	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 314	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 414	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
BATTERY PACK	Inspected
Condition	2- Between Good and Fair
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	2nd Floor- Near Staircase #3
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K210

Question	Response
EXIT LIGHT	
BATTERY PACK	Inspected
Condition	2- Between Good and Fair
Deficiency	FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Stairway #2 on 3rd floor, Stairway #4 on 4th floor, Southeast corridor on 5th floor
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Non Battery Pack	Does not exist
EXIT/EMERGENCY LIGHT	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
FIRE ALARM SYSTEM	Inspected
AREA SMOKE DETECTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
BELL/HORN	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
DUCT SMOKE DETECTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
ELEVATOR RECALL	Does not exist
FAN SHUTDOWN CONTROL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
FIRE ALARM DIGITAL COMMUNICATOR	Does not exist
FUSED CUTOOUT PANEL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
HEAT DETECTOR	Does not exist
MAGNETIC DOOR HOLDER CONTACTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MAIN PANEL	Inspected
Bell At Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Lobby
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards
Model	IRC-3
EquipmentId	Fire Alarm Control Panel
Capacity/Size	16 zones
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K210

Question	Response
FIRE ALARM SYSTEM	
MANUAL PULL STATION	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
REMOTE ANNUNCIATOR	Inspected
Display Monitor	Does not exist
Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Punch Register	Does not exist
SPRINKLER FLOW/AIR PRESSURE SWITCH	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
STROBE	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SUB-PANEL	Does not exist
TAMPER FLOW SWITCH/CHAIN	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	Inspected
Instance	3rd and 5th Floor
LIGHTING	
Instance on 3rd and 5th Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 3rd and 5th Floor	Does not exist
Lighting Fixture - HID	
Instance on 3rd and 5th Floor	Inspected
Pendant Mounted	
Instance on 3rd and 5th Floor	Does not exist
Recessed Mounted	
Instance on 3rd and 5th Floor	Does not exist
Surface Mounted	
Instance on 3rd and 5th Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - Incandescent	
Instance on 3rd and 5th Floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 3rd and 5th Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SCOREBOARD	
Instance on 3rd and 5th Floor	Does not exist
THEATER LIGHTING SYSTEM	
Instance on 3rd and 5th Floor	Does not exist
INTERCOM SYSTEM	Does not exist
KITCHEN/WARMING PANTRY	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K210

Question	Response
KITCHEN/WARMING PANTRY	
Instance	1st Floor
LIGHTING	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
LAN	Inspected
LOCAL DISTRIBUTION FRAME (I/LDF)	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
MAIN EQUIPMENT RACK (MDF)	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	Room 208
Has LAN/Modem access	Yes
LIGHTING	
Instance on Room 208	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 208	Inspected
Pendant Mounted	
Instance on Room 208	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 208	Does not exist
Surface Mounted	
Instance on Room 208	Does not exist
Lighting Fixture - HID	
Instance on Room 208	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 208	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 208	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SMART BOARD	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K210

Question	Response
LIBRARY	
SMART BOARD	
Instance on Room 208	Does not exist
LIGHTING - SECURITY LIGHTS	
Condition	Inspected
Replacement Quantity	2- Between Good and Fair
Replacement Uom	20
Deficiency	EACH
Deficiency Location/Instance	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	On Roof
Quantity Uom	3
Potential Action	EACH
Urgency of Action	REPAIR
Purpose of Action	PRIORITY 4
Violations	LEVEL 3
	No violations recorded
LIGHTNING PROTECTION	
Condition	Inspected
Deficiency	3- Fair
	No deficiencies recorded
LOCKER ROOM	
Instance on Room 361	Inspected
Alternative Use	Yes
Instance on Room 561	Inspected
Alternative Use	Yes
LIGHTING	
Instance on Room 361	Inspected
Instance on Room 561	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 361	Inspected
Instance on Room 561	Inspected
Pendant Mounted	
Instance on Room 361	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 561	Does not exist
Recessed Mounted	
Instance on Room 361	Does not exist
Instance on Room 561	Does not exist
Surface Mounted	
Instance on Room 361	Does not exist
Instance on Room 561	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room 361	Does not exist
Instance on Room 561	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 361	Does not exist
Instance on Room 561	Does not exist
MOTOR CONTROL CENTER	
	Does not exist
MOTOR STARTER/CONTACTOR	
Condition	Inspected
Deficiency	2- Between Good and Fair
	No deficiencies recorded
MULTIPURPOSE ROOM	
Instance	Inspected
	1st floor

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K210

Question	Response
MULTIPURPOSE ROOM	
LIGHTING	
Instance on 1st floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st floor	Does not exist
Lighting Fixture - HID	
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on 1st floor	Does not exist
Recessed Mounted	
Instance on 1st floor	Does not exist
Surface Mounted	
Instance on 1st floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - Incandescent	
Instance on 1st floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 1st floor	Does not exist
PROJECTION SYSTEM	
Instance on 1st floor	Does not exist
THEATER LIGHTING SYSTEM	
Instance on 1st floor	Does not exist
PANEL BOARD	
	Inspected
FUSED DISCONNECT SWITCH TYPE	
	Does not exist
FUSED KNIFE SWITCH TYPE	
	Does not exist
FUSED TOGGLE SWITCH TYPE	
	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	
	Inspected
Instance	General Office
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Rauland
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Classrooms, Corridors
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SCIENCE DEMO ROOM	
Instance on Room 401,405,409	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 401,405,409	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	

NYC Department of Education
Building Condition Assessment Survey 2010-2011

Electrical Inspection

K210

Question	Response
SCIENCE DEMO ROOM	
EMERGENCY SHUT-OFF POWER	
Instance on Room 401,405,409	Does not exist
LIGHTING	
Instance on Room 401,405,409	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 401,405,409	Inspected
Pendant Mounted	
Instance on Room 401,405,409	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 401,405,409	Does not exist
Surface Mounted	
Instance on Room 401,405,409	Does not exist
Lighting Fixture - HID	
Instance on Room 401,405,409	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 401,405,409	Does not exist
POWER SUPPLY	
Instance on Room 401,405,409	Does not exist
PROJECTION SYSTEM	
Instance on Room 401,405,409	Does not exist
SMART BOARD	
Instance on Room 401,405,409	Does not exist
SCIENCE LAB	
Instance on Room 407,408	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 407,408	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room 407,408	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Room 407,408	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 407,408	Inspected
Pendant Mounted	
Instance on Room 407,408	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 407,408	Does not exist
Surface Mounted	
Instance on Room 407,408	Does not exist
Lighting Fixture - HID	
Instance on Room 407,408	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 407,408	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K210

Question	Response
SCIENCE LAB	
POWER SUPPLY	
Instance on Room 407,408	Inspected
Instructor Unit	
Instance on Room 407,408	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 407,408	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Student Unit	
Instance on Room 407,408	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
PROJECTION SYSTEM	
Instance on Room 407,408	Does not exist
SMART BOARD	
Instance on Room 407,408	Does not exist
SCIENCE PREP ROOM	
Instance on Room 450	Inspected
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 450	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room 450	Does not exist
LIGHTING	
Instance on Room 450	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 450	Inspected
Pendant Mounted	
Instance on Room 450	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 450	Does not exist
Surface Mounted	
Instance on Room 450	Does not exist
Lighting Fixture - HID	
Instance on Room 450	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 450	Does not exist
POWER SUPPLY	
Instance on Room 450	Does not exist
SECURITY	
INTRUSION ALARM	
Central Control Panel	
Instance	Custodian Office
Instance Condition	3- Fair
Instance Quantity	1

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K210

Question	Response
SECURITY	
INTRUSION ALARM	
Central Control Panel	
Instance Quantity Uom	EACH
Model	Vista-128B
Deficiency	No deficiencies recorded
Infrared Sensor	
Condition	Inspected
Deficiency	3- Fair
Panic Switch	
Condition	Inspected
Deficiency	3- Fair
Remote Annunciator	
Condition	Inspected
Deficiency	3- Fair
Siren/Strobe	
Condition	Inspected
Deficiency	3- Fair
Ultrasonic Sensor	
Condition	Does not exist
IPDVS/CCTV SYSTEM	
Condition	Does not exist
SERVICE SWITCH	
Instance	Inspected
Instance Condition	Electrical Room
Instance Quantity	2- Between Good and Fair
Instance Quantity Uom	1
Manufacturer	EACH
EquipmentId	Electrotech
Capacity/Size	Main Disconnect
Source of Capacity/Size	2500 Amps
Installation Year	Nameplate
Source of Installation Year	1998
Deficiency	Documented
SWIMMING POOL	
Condition	Does not exist
SWITCHBOARD	
Water Penetration In Electrical Room?	Inspected
Number of Spares	Yes
AIR CIRCUIT BREAKER TYPE	
Condition	0
FUSED DISCONNECT SWITCH TYPE	
Condition	Does not exist
FUSED DISCONNECT SWITCH TYPE	
Instance	Inspected
Instance Condition	Electrical Room
Instance Quantity	2- Between Good and Fair
Instance Quantity Uom	1
Manufacturer	EACH
EquipmentId	Electrotech
Capacity/Size	N/A
Source of Capacity/Size	2500 Amps total, 3 sections
Installation Year	Service Switch Size
Source of Installation Year	1998
Deficiency	Documented
Deficiency Quantity	SWITCHBOARD ID IS MISSING
Quantity Uom	1
Potential Action	EACH
Urgency of Action	MAINTENANCE
Purpose of Action	PRIORITY 2
Violations	LEVEL 2
	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K210

Question	Response
SWITCHBOARD	
FUSED DISCONNECT SWITCH TYPE	
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED KNIFE SWITCH TYPE	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	Does not exist
TELEPHONE	Inspected
PBX/INTERCOM	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
STANDARD	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TOILET ROOM - STUDENT	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Does not exist