

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K211**

School: **I.S. 211 - BROOKLYN, 1001 EAST 100 STREET, BROOKLYN, NY, 11236**

InspectionId	Inspection Type	Time In	Last Edited
1294117	ELECTRICAL	2009-05-06 08:21AM	2009-05-13 11:27AM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Panel Boards - Molded Type Years: 2009 Systems: Switchboard - Fused Type Years: 2002 Systems: Emergency/ Exit lighting Years: 2002 Systems: Local Sound, projection system in Auditorium Years: 2005 Systems: HID Lighting in the Auditorium Years: 2002 Systems: Intercom for Holding areas Years: 2006

**Priority Condition**

Condition Description	Component Affected	Location Description	Person(s) Notified
Public Address not operational	Public Address	General office	Peer Mc landless
Elevator Intercom not operational	Elevator	Passenger Elevator	Peter Mc Cadless

**Inspection**

Question	Response
<b>ELECTRICAL</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance	1st Floor
<b>House Lighting</b>	
Instance on 1st Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K211**

Question	Response
<b>AUDITORIUM</b>	
<b>House Lighting</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Surface Mounted</b>	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Local Sound System</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Theater Lighting System</b>	
Instance on 1st Floor	Inspected
<b>Dimming System</b>	
Instance on 1st Floor	Inspected
Instance Condition	5- Poor
Deficiency	LIGHT CONSOLE NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Theater Lighting</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	54
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	
Condition	3- Fair
Replacement Quantity	140,000
Replacement Uom	S.F.
Deficiency	No deficiencies recorded
<b>CAFETERIA</b>	
Instance	Basement
Instance	Basement (Teachers' Cafeteria)
<b>Lighting</b>	
Instance on Basement	Inspected
Instance on Basement (Teachers' Cafeteria)	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement	Inspected
Instance on Basement (Teachers' Cafeteria)	Inspected
<b>Pendant Mounted</b>	
Instance on Basement	Does not exist
Instance on Basement (Teachers' Cafeteria)	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K211**

Question	Response
<b>CAFETERIA</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Recessed Mounted</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	121
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Basement (Teachers' Cafeteria)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	14
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on Basement	Does not exist
Instance on Basement (Teachers' Cafeteria)	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Basement	Does not exist
Instance on Basement (Teachers' Cafeteria)	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement	Does not exist
Instance on Basement (Teachers' Cafeteria)	Does not exist
<b>Local Sound System</b>	
Instance on Basement	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K211**

<b>Question</b>	<b>Response</b>
<b>CAFETERIA</b>	
<b>Local Sound System</b>	
Instance on Basement (Teachers' Cafeteria)	Does not exist
<b>CAFETERIA/MULTIPURPOSE ROOM</b>	
	Does not exist
<b>CITY FIRE ALARM SYSTEM</b>	
Condition	Inspected
Deficiency	3- Fair
	No deficiencies recorded
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
	Inspected
<b>Lighting</b>	
	Inspected
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1,308
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	25
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	82
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	328
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	15
Quantity Uom	EACH

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K211**

<b>Question</b>	<b>Response</b>
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	51
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	64
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>COMPUTER LAB</b>	
Instance	Room 310, 312
Has LAN/Modem access	Yes
Power Panel?	Yes
<b>Lighting</b>	
Instance on Room 310, 312	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 310, 312	Inspected
<b>Pendant Mounted</b>	
Instance on Room 310, 312	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K211**

<b>Question</b>	<b>Response</b>
<b>COMPUTER LAB</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	54
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 310, 312	Does not exist
<b>Surface Mounted</b>	
Instance on Room 310, 312	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 310, 312	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 310, 312	Does not exist
<b>Raceway With Receptacles</b>	
Instance on Room 310, 312	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>ELECTRIC SERVICE SWITCH</b>	
Instance	Electrical Equipment room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	"Empire Switchboard Co."
Model	"Empire Switchboard Co."
EquipmentId	Service A
Capacity/Size	1200 Amps
Installation Year	1958
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Electrical equipment room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCH NAME PLATE IS MISSING
Deficiency Location/Instance	Electrical Equipment room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Equipment room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	"Empire Switchboard Co."

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K211**

<b>Question</b>	<b>Response</b>
<b>ELECTRIC SERVICE SWITCH</b>	
Model	"Empire Switchboard Co."
EquipmentId	Service B
Capacity/Size	1200 Amps
Installation Year	1958
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Electrical Equipment room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCH NAME PLATE IS MISSING
Deficiency Location/Instance	Electrical Equipment room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Girls' Locker room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Connected To Emergency Generator System</b>	Does not exist
<b>Connected To Emergency Light/Exit Light Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Relay Test Switch</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	FIXTURE POORLY MOUNTED
Deficiency Location/Instance	1st Floor corridor by exit H, by Exit 4 stair H, by Room 134
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Connected To Emergency Generator System</b>	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K211**

<b>Question</b>	<b>Response</b>
<b>EXIT LIGHT</b>	
<b>Connected To Emergency Light/Exit Light Panel</b>	Inspected
Condition	3- Fair
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Library Room 229 (2); Auditorium, Boys' Gym, Girls' Locker room (2),
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>FIRE ALARM SYSTEM</b>	Inspected
Replacement Quantity	140,000
Replacement Uom	S.F.
<b>Area Smoke Detector</b>	Inspected
Condition	3- Fair
Deficiency	DETECTOR POORLY MOUNTED
Deficiency Location/Instance	In front of elevator (Basement)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Bell/Horn</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Duct Smoke Detector</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Elevator Recall</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fan Shutdown Control</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Digital Communicator</b>	Does not exist
<b>Fused Cutout Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Heat Detector</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Magnetic Door Holder Contactor</b>	Does not exist
<b>Main Panel</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Does not exist
<b>Fire Alarm Control Panel (Standard)</b>	Inspected
Instance	Boiler room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K211**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>Main Panel</b>	
<b>Fire Alarm Control Panel (Standard)</b>	
Manufacturer	ACME
EquipmentId	Fire Alarm
Capacity/Size	6 gong bell circuits
Installation Year	1958
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Manual Pull Station</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	Inspected
<b>Display Monitor</b>	Does not exist
<b>Panel</b>	Does not exist
<b>Printer</b>	Does not exist
<b>Punch Register</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Sprinkler Flow/Air Pressure Switch</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Strobe</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Sub-Panel</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Inspected
Instance	Boiler room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Faraday
Model	19000A
EquipmentId	Visual Fire Signal Indicator Panel
Capacity/Size	4 zones
Installation Year	1988
Deficiency	No deficiencies recorded
Instance	Boiler room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Kidde
Model	N/A
EquipmentId	No ID
Capacity/Size	5 zones
Installation Year	1988
Deficiency	PANEL ID IS MISSING
Deficiency Quantity	1

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K211**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>Sub-Panel</b>	
<b>Fire Alarm Control Panel (Electronic)</b>	
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Boiler room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Faraday
Model	Fire Watch XVI
EquipmentId	Duct Detector Control Board
Capacity/Size	12 zones
Installation Year	1988
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Standard)</b>	
Instance	Boiler room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Sprinkler Alarm
Capacity/Size	2 circuits
Installation Year	1958
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Boiler room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Register Control Board
Capacity/Size	Single circuit
Installation Year	1958
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Tamper Flow Switch/Chain</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GROUNDING SYSTEM</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	
	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K211**

<b>Question</b>	<b>Response</b>
<b>GYMNASIUM</b>	
Instance	1st Floor (Boys)
Instance	1st Floor (Girls)
<b>Lighting</b>	
Instance on 1st Floor (Boys)	Inspected
Instance on 1st Floor (Girls)	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor (Boys)	Inspected
Instance on 1st Floor (Girls)	Does not exist
<b>Pendant Mounted</b>	
Instance on 1st Floor (Boys)	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st Floor (Boys)	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor (Boys)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor (Boys)	Inspected
Instance on 1st Floor (Girls)	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor (Boys)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	13
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 1st Floor (Girls)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	9

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K211**

<b>Question</b>	<b>Response</b>
<b>GYMNASIUM</b>	
<b>Lighting</b>	
<b>Lighting Fixture - HID</b>	
<b>Pendant Mounted</b>	
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on 1st Floor (Boys)	Does not exist
Instance on 1st Floor (Girls)	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor (Boys)	Does not exist
Instance on 1st Floor (Girls)	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor (Boys)	Does not exist
Instance on 1st Floor (Girls)	Does not exist
<b>Local Sound System</b>	
Instance on 1st Floor (Boys)	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 1st Floor (Girls)	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Scoreboard</b>	
Instance on 1st Floor (Boys)	Does not exist
Instance on 1st Floor (Girls)	Does not exist
<b>Theater Lighting System</b>	
Instance on 1st Floor (Boys)	Does not exist
Instance on 1st Floor (Girls)	Does not exist
<b>INTERCOM SYSTEM</b>	
	Inspected
<b>Elevator</b>	
	Inspected
Condition	5- Poor
Deficiency	INTERCOM CABINET NOT OPERATIONAL
Deficiency Location/Instance	Passenger Elevator
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
<b>Holding Area</b>	
	Inspected
Condition	1- Good

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K211**

<b>Question</b>	<b>Response</b>
<b>INTERCOM SYSTEM</b>	
<b>Holding Area</b>	
Deficiency	No deficiencies recorded
<b>KITCHEN/WARMING PANTRY</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	21
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	22
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Does not exist
<b>LAN</b>	Inspected
<b>Local Distribution Frame (I/LDF)</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Main Equipment Rack (MDF)</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>LIBRARY</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K211**

<b>Question</b>	<b>Response</b>
<b>LIBRARY</b>	
Instance	Room 229
Has LAN/Modem access	Yes
<b>Lighting</b>	
Instance on Room 229	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 229	Inspected
<b>Pendant Mounted</b>	
Instance on Room 229	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 229	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	56
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on Room 229	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 229	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 229	Does not exist
<b>Raceway With Receptacles</b>	
Instance on Room 229	Does not exist
<b>LIGHTING - EXTERIOR SECURITY</b>	
Condition	4- Between Fair and Poor
Replacement Quantity	31
Replacement Uom	EACH
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Exterior wall facing E 100 St
Deficiency Quantity	14
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 3
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Exterior walls facing Ave J and playground
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K211**

<b>Question</b>	<b>Response</b>
<b>LIGHTING - EXTERIOR SECURITY</b>	
Violations	No violations recorded
<b>LIGHTNING PROTECTION</b>	Does not exist
<b>LOCKER ROOM/SHOWER ROOM</b>	Inspected
Instance	B 32 (Boys) and B-36( Girls). Now used as storage.
Alternative Use	Yes
<b>Lighting</b>	
Instance on B 32 (Boys) and B-36( Girls). Now used as storage.	Not required
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Boiler room, Fan room (next to Cafeteria, Room B-35), kitchen
Deficiency Quantity	26
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	MOTOR STARTER INDICATOR LIGHT NOT OPERATIONAL
Deficiency Location/Instance	Fan room next to Cafeteria
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE INDICATOR LIGHT
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MULTIPURPOSE ROOM</b>	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>Fused Disconnect Switch Type</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fused Knife Switch Type</b>	Does not exist
<b>Fused Toggle Switch Type</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Electrical meter room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Molded Case Circuit Breaker Type</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Corridors, kitchen, Auditorium, Cafeteria, Fan room ( Room B-35)
Deficiency Quantity	17
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>PUBLIC ADDRESS SYSTEM</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K211**

<b>Question</b>	<b>Response</b>
<b>PUBLIC ADDRESS SYSTEM</b>	
Replacement Quantity	140,000
Replacement Uom	S.F.
Instance	General office
Instance Condition	5- Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Model	RCA
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Location/Instance	General office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Deficiency	MASTER CLOCK BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	General office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Classrooms, Corridors, offices, etc
Deficiency Quantity	35
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SCIENCE DEMO ROOM</b>	Inspected
Instance	Room 101,201,205, 301,305
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
<b>Emergency Gas Shut-Off Valve</b>	
Instance on Room 101,201,205, 301,305	Does not exist
<b>Emergency Shut-Off Power</b>	
Instance on Room 101,201,205, 301,305	Does not exist
<b>Lighting</b>	
Instance on Room 101,201,205, 301,305	Not required
<b>Power Supply</b>	
Instance on Room 101,201,205, 301,305	Does not exist
<b>SCIENCE LAB</b>	Inspected
Instance	Room 209,307,309,207
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
<b>Emergency Gas Shut-Off Valve</b>	
Instance on Room 209,307,309,207	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	3

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K211**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>Emergency Gas Shut-Off Valve</b>	
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>Emergency Shut-Off Power</b>	
Instance on Room 209,307,309,207	Does not exist
<b>Lighting</b>	
Instance on Room 209,307,309,207	Not required
<b>Power Supply</b>	
Instance on Room 209,307,309,207	Does not exist
<b>SCIENCE PREP ROOM</b>	
Instance	Inspected
Instance	Room 203
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	Yes
Instance	Room 303
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
<b>Emergency Gas Shut-Off Valve</b>	
Instance on Room 203	Does not exist
Instance on Room 303	Does not exist
<b>Emergency Shut-Off Power</b>	
Instance on Room 203	Does not exist
Instance on Room 303	Does not exist
<b>Lighting</b>	
Instance on Room 203	Not required
Instance on Room 303	Not required
<b>Power Supply</b>	
Instance on Room 203	Does not exist
Instance on Room 303	Does not exist
<b>SECURITY</b>	
Replacement Quantity	Inspected
Replacement Uom	140,000
Intrusion Alarm	S.F.
<b>Central Control Panel</b>	Inspected
Instance	Inspected
Instance Condition	Custodian office
Instance Quantity	3- Fair
Instance Quantity Uom	1
Model	EACH
Deficiency	Ademco- Vista 50 PUL
<b>Infrared Sensor</b>	No deficiencies recorded
Condition	Inspected
Deficiency	3- Fair
<b>Panic Switch</b>	No deficiencies recorded
Condition	Inspected
Deficiency	3- Fair
<b>Remote Annunciator</b>	No deficiencies recorded
Condition	Inspected
Deficiency	3- Fair
	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K211**

<b>Question</b>	<b>Response</b>
<b>SECURITY</b>	
<b>Intrusion Alarm</b>	
<b>Siren/Strobe</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Ultrasonic Sensor</b>	
<b>Condition</b>	Inspected
Condition	3- Fair
Deficiency	SENSOR NOT IN USE
Deficiency Location/Instance	Cafeteria, kitchen, staircases.
Deficiency Quantity	17
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>IPDVS/CCTV System</b>	
<b>Condition</b>	Inspected
Condition	5- Poor
Deficiency	CAMERA NOT OPERATIONAL
Deficiency Location/Instance	Cafeteria, Entrance Ave J
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
<b>SWIMMING POOL</b>	
	Does not exist
<b>SWITCHBOARD</b>	
	Inspected
<b>Air Circuit Breaker Type</b>	
	Does not exist
<b>Fused Disconnect Switch Type</b>	
	Inspected
Instance	Electrical Equipment room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Cutler Hammer
EquipmentId	DP-EM
Capacity/Size	400 Amps total, I section
Installation Year	2002
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Fused Knife Switch Type</b>	
	Does not exist
<b>Molded Case Circuit Breaker Type</b>	
	Inspected
Instance	Electrical equipment room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Not available
EquipmentId	Service A
Capacity/Size	1200 Amps total, 1 section
Installation Year	1958
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K211**

<b>Question</b>	<b>Response</b>
<b>SWITCHBOARD</b>	
<b>Molded Case Circuit Breaker Type</b>	
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical equipment room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Not available
EquipmentId	Service B
Capacity/Size	1200 Amps total, 1 section
Installation Year	1958
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>TELEPHONE</b>	Inspected
<b>PBX/Intercom</b>	Inspected
Condition	4- Between Fair and Poor
Deficiency	TELEPHONE NOT OPERATIONAL
Deficiency Location/Instance	Classrooms, Boiler room,
Deficiency Quantity	27
Quantity Uom	EACH
Potential Action	REPLACE TELEPHONE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	TELEPHONE MISSING
Deficiency Location/Instance	Auditorium ,Teachers' Cafeteria
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	INSTALL TELEPHONE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K211**

<b>Question</b>	<b>Response</b>
<b>TELEPHONE</b>	
<b>Standard</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>TOILET ROOM - STAFF</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TRANSFORMER</b>	Does not exist
<b>TV SYSTEM</b>	Inspected
<b>Cable Service</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Main Equipment Rack</b>	Does not exist
<b>Master Antenna System</b>	Inspected
Condition	3- Fair
Deficiency	ANTENNA NOT IN USE

NYC Department of Education  
Building Condition Assessment Survey 2008-2009

*Electrical Inspection*

K211

Question	Response
<b>TV SYSTEM</b>	
<b>Master Antenna System</b>	
Deficiency Location/Instance	Building roof
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded