

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K238**

School: **P.S. 238 - BROOKLYN, 1633 EAST 8 STREET, BROOKLYN, NY, 11223**

InspectionId	Inspection Type	Time In	Last Edited
1196015	ELECTRICAL	2008-12-04 08:21AM	2009-04-17 11:37AM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Partial Emergency and Exit Lights Years: 2002 Systems: Fire Alarm System Years: Under Construction Systems: PA System Amplifier Years: Approx. 1990 Systems: Intrusion Alarm Years: 1996 Systems: Most Fluorescent Lighting in Stairwells Years: 2004 and 2007 Systems: Fluorescent Lighting in Student Bathrooms on 2nd, 3rd and 4th Floors Years: Approx. 1985 Systems: Fluorescent Lighting in Kitchen Years: Approx. 1990 Systems: Outside Security Lights Years: 2006 Systems: LAN and PBX/ Intercom Years: 2003 Systems: Local Sound Systems in Cafeteria and Auditorium Years: 2007 Systems: Projection System in Auditorium Years: 2007 Systems: Most Motor Starters Years: 2001 Systems: Panel Boards Years: 1970 and 2001 Systems: Electric Service Years: 1970

**Priority Condition**

No condition recorded

**Inspection**

Question	Response
<b>ELECTRICAL</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance	First Floor
<b>House Lighting</b>	
Instance on First Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on First Floor	Inspected
<b>Pendant Mounted</b>	
Instance on First Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K238**

Question	Response
<b>AUDITORIUM</b>	
<b>House Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on First Floor	Does not exist
<b>Surface Mounted</b>	
Instance on First Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	40
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
Instance on First Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on First Floor	Does not exist
<b>Local Sound System</b>	
Instance on First Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on First Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Theater Lighting System</b>	
Instance on First Floor	Inspected
<b>Dimming System</b>	
Instance on First Floor	Does not exist
<b>Theater Lighting</b>	
Instance on First Floor	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	21
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	
Condition	3- Fair
Replacement Quantity	88,000

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K238**

<b>Question</b>	<b>Response</b>
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	
Replacement Uom	S.F.
Deficiency	No deficiencies recorded
<b>CAFETERIA</b>	
Instance	Inspected
	First Floor
<b>Lighting</b>	
Instance on First Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on First Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on First Floor	Inspected
<b>Pendant Mounted</b>	
Instance on First Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on First Floor	Does not exist
<b>Surface Mounted</b>	
Instance on First Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - Incandescent</b>	
Instance on First Floor	Inspected
<b>Pendant Mounted</b>	
Instance on First Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on First Floor	Does not exist
<b>Surface Mounted</b>	
Instance on First Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Local Sound System</b>	
Instance on First Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>CAFETERIA/MULTIPURPOSE ROOM</b>	
	Does not exist
<b>CITY FIRE ALARM SYSTEM</b>	
Condition	Inspected
	3- Fair
Deficiency	No deficiencies recorded
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
	Inspected
<b>Lighting</b>	
	Inspected
<b>Lighting Fixture - Fluorescent</b>	
	Inspected
<b>Pendant Mounted</b>	
	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K238**

Question	Response
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	850
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	110
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	30
Quantity Uom	EACH

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K238**

Question	Response
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Surface Mounted</b>	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>COMPUTER LAB</b>	Inspected
Instance	Room 322
Has LAN/Modem access	Yes
Power Panel?	Yes
<b>Lighting</b>	
Instance on Room 322	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 322	Inspected
<b>Pendant Mounted</b>	
Instance on Room 322	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 322	Does not exist
<b>Surface Mounted</b>	
Instance on Room 322	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 322	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 322	Does not exist
<b>Raceway With Receptacles</b>	
Instance on Room 322	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>ELECTRIC SERVICE SWITCH</b>	Inspected
Instance	Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Metropolitan Electric
Model	Metropolitan Electric
EquipmentId	Service Switch
Capacity/Size	1600 Amps
Installation Year	1970
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K238**

<b>Question</b>	<b>Response</b>
<b>EMERGENCY LIGHTING</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Connected To Emergency Generator System</b>	Does not exist
<b>Connected To Emergency Light/Exit Light Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Relay Test Switch</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Connected To Emergency Generator System</b>	Does not exist
<b>Connected To Emergency Light/Exit Light Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>FIRE ALARM SYSTEM</b>	Under construction
<b>GROUNDING SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	Inspected
Instance	Fourth Floor
Instance	Third Floor
<b>Lighting</b>	
Instance on Fourth Floor	Inspected
Instance on Third Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Fourth Floor	Does not exist
Instance on Third Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Fourth Floor	Inspected
Instance on Third Floor	Inspected
<b>Pendant Mounted</b>	
Instance on Fourth Floor	Does not exist
Instance on Third Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on Fourth Floor	Does not exist
Instance on Third Floor	Does not exist
<b>Surface Mounted</b>	
Instance on Fourth Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	16
Quantity Uom	EACH

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K238**

Question	Response
<b>GYMNASIUM</b>	
<b>Lighting</b>	
<b>Lighting Fixture - HID</b>	
<b>Surface Mounted</b>	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Third Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	17
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - Incandescent</b>	
Instance on Fourth Floor	Does not exist
Instance on Third Floor	Does not exist
<b>Local Sound System</b>	
Instance on Fourth Floor	Does not exist
Instance on Third Floor	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Scoreboard</b>	
Instance on Fourth Floor	Does not exist
Instance on Third Floor	Does not exist
<b>Theater Lighting System</b>	
Instance on Fourth Floor	Does not exist
Instance on Third Floor	Does not exist
<b>INTERCOM SYSTEM</b>	
<b>Elevator</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>Holding Area</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>KITCHEN/WARMING PANTRY</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
	Inspected
	Inspected
	Does not exist

NYC Department of Education  
Building Condition Assessment Survey 2008-2009

*Electrical Inspection*

K238

Question	Response
<b>KITCHEN/WARMING PANTRY</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>LAN</b>	Inspected
<b>Local Distribution Frame (I/LDF)</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Main Equipment Rack (MDF)</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>LIBRARY</b>	Inspected
Instance	Room 309
Has LAN/Modem access	Yes
<b>Lighting</b>	
Instance on Room 309	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 309	Inspected
<b>Pendant Mounted</b>	
Instance on Room 309	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	30
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 309	Does not exist
<b>Surface Mounted</b>	
Instance on Room 309	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 309	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 309	Does not exist
<b>Raceway With Receptacles</b>	
Instance on Room 309	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>LIGHTING - EXTERIOR SECURITY</b>	Inspected
Condition	1- Good
Replacement Quantity	31
Replacement Uom	EACH
Deficiency	No deficiencies recorded
<b>LIGHTNING PROTECTION</b>	Does not exist
<b>LOCKER ROOM/SHOWER ROOM</b>	Inspected
Instance	Fourth Floor
Alternative Use	Yes

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K238**

<b>Question</b>	<b>Response</b>
<b>LOCKER ROOM/SHOWER ROOM</b>	
Instance	Third Floor
Alternative Use	Yes
<b>Lighting</b>	
Instance on Fourth Floor	Not required
Instance on Third Floor	Not required
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>MULTIPURPOSE ROOM</b>	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>Fused Disconnect Switch Type</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fused Knife Switch Type</b>	Does not exist
<b>Fused Toggle Switch Type</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Molded Case Circuit Breaker Type</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>PUBLIC ADDRESS SYSTEM</b>	Inspected
Replacement Quantity	88,000
Replacement Uom	S.F.
Instance	General Office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Deficiency	SPEAKER NOT OPERATIONAL
Deficiency Location/Instance	Five Classrooms on 3rd and 4th Floors
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Corridors and Public Assembly Spaces
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SCIENCE DEMO ROOM</b>	Inspected
Instance	Room 417, 415
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
<b>Emergency Gas Shut-Off Valve</b>	
Instance on Room 417, 415	Does not exist
<b>Emergency Shut-Off Power</b>	
Instance on Room 417, 415	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K238**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>Lighting</b>	
Instance on Room 417, 415	Not required
<b>Power Supply</b>	
Instance on Room 417, 415	Does not exist
<b>SCIENCE LAB</b>	
	Does not exist
<b>SCIENCE PREP ROOM</b>	
	Inspected
Instance	Room 419
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
<b>Emergency Gas Shut-Off Valve</b>	
Instance on Room 419	Does not exist
<b>Emergency Shut-Off Power</b>	
Instance on Room 419	Does not exist
<b>Lighting</b>	
Instance on Room 419	Not required
<b>Power Supply</b>	
Instance on Room 419	Does not exist
<b>SECURITY</b>	
	Inspected
Replacement Quantity	88,000
Replacement Uom	S.F.
<b>Intrusion Alarm</b>	
	Inspected
<b>Central Control Panel</b>	
	Inspected
Instance	Old Custodians Office by Kitchen
Instance Condition	5- Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Model	VISTA 50P
Deficiency	PANEL NOT OPERATIONAL
Deficiency Location/Instance	Old Custodians Office by Kitchen
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
<b>Infrared Sensor</b>	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	
	Inspected
Condition	4- Between Fair and Poor
Deficiency	SIREN/STROBE POORLY MOUNTED
Deficiency Location/Instance	Above Main Entrance
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K238**

<b>Question</b>	<b>Response</b>
<b>SECURITY</b>	
<b>Intrusion Alarm</b>	
<b>Siren/Strobe</b>	
Violations	No violations recorded
<b>Ultrasonic Sensor</b>	Does not exist
<b>IPDVS/CCTV System</b>	Does not exist
<b>SWIMMING POOL</b>	Does not exist
<b>SWITCHBOARD</b>	Inspected
<b>Air Circuit Breaker Type</b>	Does not exist
<b>Fused Disconnect Switch Type</b>	Inspected
Instance	Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Metropolitan Electric
EquipmentId	N/A
Capacity/Size	1000 Amps total, 4 sections
Installation Year	1970
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Fused Knife Switch Type</b>	Does not exist
<b>Molded Case Circuit Breaker Type</b>	Does not exist
<b>TELEPHONE</b>	Inspected
<b>PBX/Intercom</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Standard</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>TOILET ROOM - STAFF</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K238**

<b>Question</b>	<b>Response</b>
<b>TOILET ROOM - STAFF</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TRANSFORMER</b>	Does not exist
<b>TV SYSTEM</b>	Inspected
<b>Cable Service</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Main Equipment Rack</b>	Does not exist
<b>Master Antenna System</b>	Does not exist