

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K293

School: **J.H.S. 293 - BROOKLYN, 284 BALTIC STREET, BROOKLYN, NY, 11201**

InspectionId	Inspection Type	Time In	Last Edited
1183015	ELECTRICAL	2009-02-23 08:39AM	2009-04-24 10:00AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	<p>Systems: Local Sound Systems in Auditorium, Cafeteria And GYM, CCTV, HID Lights, Projector, Spot lights and stage lights in Auditorium, PA system, Science Labs in Room 334 and room #336/338.</p> <p>Years: 2008</p> <p>Systems: Telephone</p> <p>Years: 2004</p> <p>Systems: Emergency Lights and Exit Lights in part</p> <p>Years: 2000 and 2005</p> <p>Systems: Outside security lights</p> <p>Years: 1998</p> <p>Systems: LAN</p> <p>Years: 1998</p> <p>Systems: Intrusion Alarm</p> <p>Years: 2001</p>

Priority Condition

No condition recorded

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	1st Floor
House Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Local Sound System	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Projection System	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Theater Lighting System	

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K293

Question	Response
AUDITORIUM	
Theater Lighting System	
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
AUXILIARY SIGNAL/BELL SYSTEM	
	Inspected
Condition	3- Fair
Replacement Quantity	157,000
Replacement Uom	S.F.
Deficiency	No deficiencies recorded
CAFETERIA	
	Inspected
Instance	Basement
Lighting	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Does not exist
Recessed Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	96
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on Basement	Does not exist
Lighting Fixture - HID	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
Local Sound System	
Instance on Basement	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
CAFETERIA/MULTIPURPOSE ROOM	
	Does not exist
CITY FIRE ALARM SYSTEM	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
	Inspected
Lighting	
	Inspected
Lighting Fixture - Fluorescent	
	Inspected
Pendant Mounted	
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K293

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	103
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Condition	Inspected
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	93
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Condition	Inspected
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1,280
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
	Does not exist
Lighting Fixture - Incandescent	
Pendant Mounted	
Condition	Inspected
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	44
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
	Does not exist
Surface Mounted	
Condition	Inspected
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	50
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
COMPUTER LAB	
Instance	Inspected
	Room # 321

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K293

Question	Response
COMPUTER LAB	
Has LAN/Modem access	No
Power Panel?	Yes
Instance	Room #B19
Has LAN/Modem access	Yes
Power Panel?	Yes
Lighting	
Instance on Room # 321	Inspected
Instance on Room #B19	Inspected
Lighting Fixture - Fluorescent	
Instance on Room # 321	Inspected
Instance on Room #B19	Inspected
Pendant Mounted	
Instance on Room # 321	Does not exist
Instance on Room #B19	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	34
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room # 321	Does not exist
Instance on Room #B19	Does not exist
Surface Mounted	
Instance on Room # 321	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	24
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room #B19	Does not exist
Lighting Fixture - HID	
Instance on Room # 321	Does not exist
Instance on Room #B19	Does not exist
Lighting Fixture - Incandescent	
Instance on Room # 321	Does not exist
Instance on Room #B19	Does not exist
Raceway With Receptacles	
Instance on Room # 321	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room #B19	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
ELECTRIC SERVICE SWITCH	
Instance	Basement, Electric Room
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K293

Question	Response
ELECTRIC SERVICE SWITCH	
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Empire Switchboard Co. Inc
Model	Empire Switchboard Co. Inc
EquipmentId	SERV. SWITCH
Capacity/Size	1600 Amps
Installation Year	1968
Deficiency	No deficiencies recorded
Instance	Basement, Electric Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Empire Switchboard Co Inc
Model	Empire Switchboard Co Inc
EquipmentId	SERV. SWITCH
Capacity/Size	3000 Amps
Installation Year	1968
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Connected To Emergency Generator System	Does not exist
Connected To Emergency Light/Exit Light Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Relay Test Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	BULB NOT OPERATIONAL
Deficiency Location/Instance	All Around in corridors
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE BULB
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Connected To Emergency Generator System	Does not exist
Connected To Emergency Light/Exit Light Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
FIRE ALARM SYSTEM	Under construction
GROUNDING SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K293

Question	Response
GYMNASIUM	Inspected
Instance	First Floor
Lighting	
Instance on First Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on First Floor	Does not exist
Lighting Fixture - HID	
Instance on First Floor	Inspected
Pendant Mounted	
Instance on First Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on First Floor	Does not exist
Surface Mounted	
Instance on First Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on First Floor	Does not exist
Local Sound System	
Instance on First Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Scoreboard	
Instance on First Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Theater Lighting System	
Instance on First Floor	Does not exist
INTERCOM SYSTEM	Does not exist
KITCHEN/WARMING PANTRY	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	INSTALL NEW LAMP
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	70
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K293

Question	Response
KITCHEN/WARMING PANTRY	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
LAN	Inspected
Local Distribution Frame (I/LDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	Room #110
Has LAN/Modem access	Yes
Lighting	
Instance on Room #110	Inspected
Lighting Fixture - Fluorescent	
Instance on Room #110	Inspected
Pendant Mounted	
Instance on Room #110	Does not exist
Recessed Mounted	
Instance on Room #110	Does not exist
Surface Mounted	
Instance on Room #110	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	39
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL NEW LAMP
Urgency of Action	PRIORITY 3

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K293

Question	Response
LIBRARY	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Room #110	Does not exist
Lighting Fixture - Incandescent	
Instance on Room #110	Does not exist
Raceway With Receptacles	
Instance on Room #110	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
LIGHTING - EXTERIOR SECURITY	
Condition	3- Fair
Replacement Quantity	47
Replacement Uom	EACH
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	
	Does not exist
LOCKER ROOM/SHOWER ROOM	
	Inspected
Instance	First floor, Boys Locker Room
Alternative Use	No
Instance	First floor, Girls Locker Room
Alternative Use	No
Lighting	
Instance on First floor, Boys Locker Room	Inspected
Instance on First floor, Girls Locker Room	Inspected
Lighting Fixture - Fluorescent	
Instance on First floor, Boys Locker Room	Does not exist
Instance on First floor, Girls Locker Room	Does not exist
Lighting Fixture - HID	
Instance on First floor, Boys Locker Room	Does not exist
Instance on First floor, Girls Locker Room	Does not exist
Lighting Fixture - Incandescent	
Instance on First floor, Boys Locker Room	Inspected
Instance on First floor, Girls Locker Room	Inspected
Pendant Mounted	
Instance on First floor, Boys Locker Room	Does not exist
Instance on First floor, Girls Locker Room	Does not exist
Recessed Mounted	
Instance on First floor, Boys Locker Room	Does not exist
Instance on First floor, Girls Locker Room	Does not exist
Surface Mounted	
Instance on First floor, Boys Locker Room	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K293

Question	Response
LOCKER ROOM/SHOWER ROOM	
Lighting	
Lighting Fixture - Incandescent	
Surface Mounted	
Deficiency Quantity	28
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on First floor, Girls Locker Room	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Molded Case Circuit Breaker Type	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	Inspected
Replacement Quantity	157,000
Replacement Uom	S.F.
Instance	General Office, First floor
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Rauland Telecenter TC 2105
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Inspected
Instance	Room #334
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance	Room #336/338
Has LAN/Modem access	Yes
Power Panel?	Yes

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K293

Question	Response
SCIENCE LAB	
Alternative Use	No
Instance	Room #307
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	Yes
Emergency Gas Shut-Off Valve	
Instance on Room #334	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room #336/338	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room #307	Inspected
Instance Condition	5- Poor
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Emergency Shut-Off Power	
Instance on Room #334	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room #336/338	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room #307	Inspected
Instance Condition	5- Poor
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Lighting	
Instance on Room #334	Inspected
Instance on Room #336/338	Inspected
Instance on Room #307	Not required
Lighting Fixture - Fluorescent	
Instance on Room #334	Inspected
Instance on Room #336/338	Inspected
Pendant Mounted	
Instance on Room #334	Does not exist
Instance on Room #336/338	Does not exist
Recessed Mounted	
Instance on Room #334	Does not exist
Instance on Room #336/338	Does not exist
Surface Mounted	
Instance on Room #334	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K293

Question	Response
SCIENCE LAB	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	21
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room #336/338	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	21
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Room #334	Does not exist
Instance on Room #336/338	Does not exist
Lighting Fixture - Incandescent	
Instance on Room #334	Does not exist
Instance on Room #336/338	Does not exist
Power Supply	
Instance on Room #334	Inspected
Instance on Room #336/338	Inspected
Instance on Room #307	Does not exist
Instructor Unit	
Instance on Room #334	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room #336/338	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room #334	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room #336/338	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Student Unit	
Instance on Room #334	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room #336/338	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
SCIENCE PREP ROOM	
Instance	Inspected
Instance	Room #334A, 309

NYC Department of Education
Building Condition Assessment Survey 2008-2009

Electrical Inspection

K293

Question	Response
SCIENCE PREP ROOM	
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on Room #334A, 309	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room #334A, 309	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Lighting	
Instance on Room #334A, 309	Inspected
Lighting Fixture - Fluorescent	
Instance on Room #334A, 309	Inspected
Pendant Mounted	
Instance on Room #334A, 309	Does not exist
Recessed Mounted	
Instance on Room #334A, 309	Does not exist
Surface Mounted	
Instance on Room #334A, 309	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Room #334A, 309	Does not exist
Lighting Fixture - Incandescent	
Instance on Room #334A, 309	Does not exist
Power Supply	
Instance on Room #334A, 309	Does not exist
SECURITY	
Replacement Quantity	157,000
Replacement Uom	S.F.
Intrusion Alarm	
Instance	Inspected
Central Control Panel	
Instance	Inspected
Instance Condition	Custodian Office
Instance Quantity	2- Between Good and Fair
Instance Quantity Uom	1
Model	EACH
Deficiency	Ademco vista 50P
Deficiency	No deficiencies recorded
Infrared Sensor	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
Panic Switch	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
Remote Annunciator	
Instance	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K293

Question	Response
SECURITY	
Intrusion Alarm	
Remote Annunciator	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Siren/Strobe	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	
Condition	Does not exist
IPDVS/CCTV System	
Condition	Inspected
Deficiency	1- Good
Deficiency	No deficiencies recorded
SWIMMING POOL	
Condition	Does not exist
SWITCHBOARD	
Condition	Inspected
Air Circuit Breaker Type	
Condition	Does not exist
Fused Disconnect Switch Type	
Instance	Inspected
Instance Condition	Basement, Electric Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Empire Switchboard Co Inc
EquipmentId	N/A
Capacity/Size	3000 Amps total, 2 Sections
Installation Year	1968
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fused Knife Switch Type	
Condition	Does not exist
Molded Case Circuit Breaker Type	
Condition	Does not exist
TELEPHONE	
Condition	Inspected
PBX/Intercom	
Condition	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Standard	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	
Condition	Inspected
Lighting	
Condition	Inspected
Lighting Fixture - Fluorescent	
Pendant Mounted	
Condition	Does not exist
Recessed Mounted	
Condition	Does not exist
Surface Mounted	
Condition	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2008-2009

Electrical Inspection

K293

Question	Response
TOILET ROOM - STAFF	
Lighting	
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	32
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable Service	Does not exist
Main Equipment Rack	Does not exist
Master Antenna System	Inspected
Condition	5- Poor
Deficiency	ANTENNA NOT OPERATIONAL
Deficiency Location/Instance	Roof
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded