

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K293**

School: **J.H.S. 293 - BROOKLYN, 284 BALTIC STREET, BROOKLYN, NY, 11201**

InspectionId	Inspection Type	Time In	Last Edited
1620091	ELECTRICAL	2011-01-26 08:28AM	2011-05-09 05:50AM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	<p>Systems: Partial Fire Alarm System. Years: Under Construction</p> <p>Systems: Security Lights. Years: 1998</p> <p>Systems: Partial Fluorescent Lights: Rooms , Corridors, Medical room &amp; Toilet rooms. Years: Approximately 2003</p> <p>Systems: Partial Science Rooms. Years: 2007</p> <p>Systems: Public Address &amp; Local Sound Systems. Years: 2008</p> <p>Systems: Auditorium, Smart Boards &amp; Auxiliary Signal/ Bell System. Years: 2008</p> <p>Systems: Intrusion Alarm System. Years: 1998</p> <p>Systems: Security Cameras. Years: 2010</p> <p>Systems: Telephone System. Years: 2003</p> <p>Systems: Partial Motor Starters. Years: Approximately 2002</p> <p>Systems: Partial Molded Case Panel Boards ( Rooms 311, 306,206, 201, Auditorium, Kitchen &amp; Electrical room). Years: Approximately 2000 &amp; 2008</p> <p>Systems: Local Area Network. Years: 2005</p> <p>Systems: Score Board In The Gymnasium. Years: 2005</p> <p>Systems: Lighting In The Gymnasium. Years: 2007</p> <p>Systems: Batteries For Emergency Lights. Years: 2010</p> <p>Systems: Partial Emergency &amp; Exit Lights. Years: 2008</p> <p>Type of Service Below Ground</p>

**Priority Condition**

No condition recorded

**Inspection**

Question	Response
<b>ELECTRICAL</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance	1st floor
<b>HOUSE LIGHTING</b>	
Instance on 1st floor	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st floor	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K293**

Question	Response
<b>AUDITORIUM</b>	
<b>HOUSE LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on 1st floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st floor	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>PROJECTION SYSTEM</b>	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	No deficiencies recorded
<b>THEATER LIGHTING SYSTEM</b>	
Instance on 1st floor	Inspected
<b>Dimming System</b>	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Theater Lighting</b>	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>CAFETERIA</b>	
Instance	Basement
<b>LIGHTING</b>	
Instance on Basement	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement	Inspected
<b>Pendant Mounted</b>	
Instance on Basement	Does not exist
<b>Recessed Mounted</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE BALLAST

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K293**

Question	Response
<b>CAFETERIA</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Recessed Mounted</b>	
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	110
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on Basement	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>CITY FIRE ALARM SYSTEM</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	142
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K293**

<b>Question</b>	<b>Response</b>
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Recessed Mounted</b>	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	51
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Condition	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	68
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1,461
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	26
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K293**

Question	Response
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	32
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SMART BOARD</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>COMPUTER LAB</b>	Inspected
Instance	Room 321
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room B19
Has LAN/Modem access	Yes
Power Panel?	Yes
<b>LIGHTING</b>	
Instance on Room 321	Inspected
Instance on Room B19	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 321	Inspected
Instance on Room B19	Inspected
<b>Pendant Mounted</b>	
Instance on Room 321	Does not exist
Instance on Room B19	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	37
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 321	Does not exist
Instance on Room B19	Does not exist
<b>Surface Mounted</b>	
Instance on Room 321	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	25
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K293**

Question	Response
<b>COMPUTER LAB</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Instance on Room B19	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 321	Does not exist
Instance on Room B19	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 321	Does not exist
Instance on Room B19	Does not exist
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room 321	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room B19	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	LESS THAN 20% SPARE CIRCUIT BREAKERS
Deficiency Location/Instance	Electrical Room B3
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL NEW PANEL BOARD
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>EMERGENCY LIGHTING</b>	Inspected
<b>BATTERY PACK</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Auditorium
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 4
Violations	11167628R
<b>EXIT LIGHT</b>	Inspected
<b>BATTERY PACK</b>	Does not exist
<b>Non Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	FIXTURE LENS MISSING
Deficiency Location/Instance	Boiler room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K293**

<b>Question</b>	<b>Response</b>
<b>EXIT LIGHT</b>	
<b>Non Battery Pack</b>	
Violations	No violations recorded
Deficiency	FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Library, 1st floor corridor next to room 133, 2nd floor by stair 7 & inside room 162
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>EXIT/EMERGENCY LIGHT</b>	
	Does not exist
<b>FIRE ALARM SYSTEM</b>	
	Inspected
<b>AREA SMOKE DETECTOR</b>	
	Under construction
<b>BELL/HORN</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>DUCT SMOKE DETECTOR</b>	
	Under construction
<b>ELEVATOR RECALL</b>	
	Under construction
<b>FAN SHUTDOWN CONTROL</b>	
	Under construction
<b>FIRE ALARM DIGITAL COMMUNICATOR</b>	
	Under construction
<b>FUSED CUTOOUT PANEL</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>HEAT DETECTOR</b>	
	Under construction
<b>MAGNETIC DOOR HOLDER CONTACTOR</b>	
	Under construction
<b>MAIN PANEL</b>	
	Inspected
<b>Bell At Panel</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	
	Does not exist
<b>Fire Alarm Control Panel (Standard)</b>	
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Fire Alarm Control Board
Capacity/Size	8 circuits
Installation Year	1966
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	157,000
Quantity Uom	S.F.
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MANUAL PULL STATION</b>	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>REMOTE ANNUNCIATOR</b>	
	Inspected
<b>Display Monitor</b>	
	Under construction
<b>Panel</b>	
	Under construction
<b>Printer</b>	
	Under construction

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K293**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>REMOTE ANNUNCIATOR</b>	
<b>Punch Register</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>SPRINKLER FLOW/AIR PRESSURE SWITCH</b>	Under construction
<b>STROBE</b>	Under construction
<b>SUB-PANEL</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Under construction
<b>Fire Alarm Control Panel (Standard)</b>	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Sprinkler Alarm Control Board
Capacity/Size	2 circuits
Installation Year	1966
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Register Control Board
Capacity/Size	2 circuits
Installation Year	1966
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>TAMPER FLOW SWITCH/CHAIN</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GROUNDING SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	Inspected
Instance	1st floor
<b>LIGHTING</b>	
Instance on 1st floor	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K293**

<b>Question</b>	<b>Response</b>
<b>GYMNASIUM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 1st floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st floor	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>SCOREBOARD</b>	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>THEATER LIGHTING SYSTEM</b>	
Instance on 1st floor	Does not exist
<b>INTERCOM SYSTEM</b>	
	Does not exist
<b>KITCHEN/WARMING PANTRY</b>	
Instance	Inspected
	Basement
<b>LIGHTING</b>	
Instance on Basement	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement	Inspected
<b>Pendant Mounted</b>	
Instance on Basement	Does not exist
<b>Recessed Mounted</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	51
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on Basement	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K293**

<b>Question</b>	<b>Response</b>
<b>KITCHEN/WARMING PANTRY</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - HID</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement	Does not exist
<b>LAN</b>	Inspected
<b>LOCAL DISTRIBUTION FRAME (I/LDF)</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>MAIN EQUIPMENT RACK (MDF)</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>LIBRARY</b>	Inspected
Instance	Room 110
Has LAN/Modem access	Yes
<b>LIGHTING</b>	
Instance on Room 110	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 110	Inspected
<b>Pendant Mounted</b>	
Instance on Room 110	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 110	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on Room 110	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	41
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K293**

Question	Response
<b>LIBRARY</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
Instance on Room 110	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 110	Does not exist
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room 110	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>SMART BOARD</b>	
Instance on Room 110	Does not exist
<b>LIGHTING - SECURITY LIGHTS</b>	
Condition	Inspected
Replacement Quantity	2- Between Good and Fair
Replacement Uom	30
Replacement Uom	EACH
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Facing Butler St & Facing The Backyard.
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
<b>LIGHTNING PROTECTION</b>	
	Does not exist
<b>LOCKER ROOM</b>	
Instance on 1st floor inside the gymnasium (Boys & Girls)	Inspected
Alternative Use	No
<b>LIGHTING</b>	
Instance on 1st floor inside the gymnasium (Boys & Girls)	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st floor inside the gymnasium (Boys & Girls)	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st floor inside the gymnasium (Boys & Girls)	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st floor inside the gymnasium (Boys & Girls)	Inspected
<b>Pendant Mounted</b>	
Instance on 1st floor inside the gymnasium (Boys & Girls)	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st floor inside the gymnasium (Boys & Girls)	Does not exist
<b>Surface Mounted</b>	
Instance on 1st floor inside the gymnasium (Boys & Girls)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	22
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K293**

<b>Question</b>	<b>Response</b>
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Room B12 & Boiler Room
Deficiency Quantity	31
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MULTIPURPOSE ROOM</b>	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>FUSED DISCONNECT SWITCH TYPE</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	3rd floor corridor & Room B12 & Boiler Room
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>FUSED KNIFE SWITCH TYPE</b>	Does not exist
<b>FUSED TOGGLE SWITCH TYPE</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Electrical Room B3
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD DIRECTORY MISSING OR REQUIRES UPDATING
Deficiency Location/Instance	2nd & 3rd floors corridors
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PANEL BOARD ID IS MISSING
Deficiency Location/Instance	Corridors, Room 327, Cafeteria, Kitchen and Boiler Room
Deficiency Quantity	21
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Corridors, Room 327, Cafeteria, Kitchen & Boiler Room
Deficiency Quantity	21

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K293**

<b>Question</b>	<b>Response</b>
<b>PANEL BOARD</b>	
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>PUBLIC ADDRESS SYSTEM</b>	
	Inspected
Instance	General Office (Room 103)
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	RaulandTelecenter
Deficiency	No deficiencies recorded
<b>SCIENCE DEMO ROOM</b>	
	Does not exist
<b>SCIENCE LAB</b>	
Instance on Room 307	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	Yes
Instance on Room 334	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 336	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Room 307	Does not exist
Instance on Room 334	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 336	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY SHUT-OFF POWER</b>	
Instance on Room 307	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 334	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 336	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>LIGHTING</b>	
Instance on Room 307	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K293**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>LIGHTING</b>	
Instance on Room 334	Inspected
Instance on Room 336	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 307	Inspected
Instance on Room 334	Inspected
Instance on Room 336	Inspected
<b>Pendant Mounted</b>	
Instance on Room 307	Does not exist
Instance on Room 334	Does not exist
Instance on Room 336	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 307	Does not exist
Instance on Room 334	Does not exist
Instance on Room 336	Does not exist
<b>Surface Mounted</b>	
Instance on Room 307	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	25
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 334	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	35
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 336	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	35
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
Instance on Room 307	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K293**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - HID</b>	
Instance on Room 334	Does not exist
Instance on Room 336	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 307	Does not exist
Instance on Room 334	Does not exist
Instance on Room 336	Does not exist
<b>POWER SUPPLY</b>	
Instance on Room 307	Does not exist
Instance on Room 334	Inspected
Instance on Room 336	Inspected
<b>Instructor Unit</b>	
Instance on Room 334	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 336	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Meter Demonstration Unit</b>	
Instance on Room 334	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 336	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Student Unit</b>	
Instance on Room 334	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 336	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>PROJECTION SYSTEM</b>	
Instance on Room 307	Does not exist
Instance on Room 334	Does not exist
Instance on Room 336	Does not exist
<b>SMART BOARD</b>	
Instance on Room 307	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 334	Does not exist
Instance on Room 336	Does not exist
<b>SCIENCE PREP ROOM</b>	
Instance on Room 309	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 334A	Inspected
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	No
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K293**

<b>Question</b>	<b>Response</b>
<b>SCIENCE PREP ROOM</b>	
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Room 309	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 334A	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>EMERGENCY SHUT-OFF POWER</b>	
Instance on Room 309	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 334A	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>LIGHTING</b>	
Instance on Room 309	Inspected
Instance on Room 334A	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 309	Inspected
Instance on Room 334A	Inspected
<b>Pendant Mounted</b>	
Instance on Room 309	Does not exist
Instance on Room 334A	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 309	Does not exist
Instance on Room 334A	Does not exist
<b>Surface Mounted</b>	
Instance on Room 309	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 334A	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
Instance on Room 309	Does not exist
Instance on Room 334A	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 309	Does not exist
Instance on Room 334A	Does not exist
<b>POWER SUPPLY</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K293**

<b>Question</b>	<b>Response</b>
<b>SCIENCE PREP ROOM</b>	
<b>POWER SUPPLY</b>	
Instance on Room 309	Does not exist
Instance on Room 334A	Does not exist
<b>SECURITY</b>	Inspected
<b>INTRUSION ALARM</b>	Inspected
<b>Central Control Panel</b>	Inspected
Instance	Custodian's Office (Room 109)
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A (no key with custodian))
Deficiency	No deficiencies recorded
<b>Infrared Sensor</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Ultrasonic Sensor</b>	Does not exist
<b>IPDVS/CCTV SYSTEM</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>SERVICE SWITCH</b>	Inspected
Instance	Electrical Room B3
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Empire Switchboard Co. Inc.
EquipmentId	SERV SW
Capacity/Size	3000 Amps
Source of Capacity/Size	Nameplate
Installation Year	1966
Source of Installation Year	Estimated
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room B3
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Empire Switchboard Co. Inc.
EquipmentId	SERV SW
Capacity/Size	1600 Amps
Source of Capacity/Size	Nameplate

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K293**

<b>Question</b>	<b>Response</b>
<b>SERVICE SWITCH</b>	
Installation Year	1966
Source of Installation Year	Estimated
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SWIMMING POOL</b>	
	Does not exist
<b>SWITCHBOARD</b>	
	Inspected
Water Penetration In Electrical Room?	No
Number of Spares	0
<b>AIR CIRCUIT BREAKER TYPE</b>	
	Does not exist
<b>FUSED DISCONNECT SWITCH TYPE</b>	
	Inspected
Instance	Electrical Room B3
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Empire Switchboard Co. Inc.
EquipmentId	N/A
Capacity/Size	3000 Amps total, 2 sections
Source of Capacity/Size	Service Switch Size
Installation Year	1966
Source of Installation Year	Estimated
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>FUSED KNIFE SWITCH TYPE</b>	
	Does not exist
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	
	Does not exist
<b>TELEPHONE</b>	
	Inspected
<b>PBX/INTERCOM</b>	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>STANDARD</b>	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K293**

<b>Question</b>	<b>Response</b>
<b>TOILET ROOM - STAFF</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>TRANSFORMER</b>	Does not exist
<b>TV SYSTEM</b>	Inspected
Cable System Exist?	Yes
Operational?	No
Master Antenna System Exist?	Yes
Operational?	No
<b>MAIN EQUIPMENT RACK</b>	Does not exist