

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K332

School: **P.S. 332 - BROOKLYN, 51 CHRISTOPHER AVENUE, BROOKLYN, NY, 11212**

InspectionId	Inspection Type	Time In	Last Edited
1620036	ELECTRICAL	2010-11-12 09:10AM	2011-04-21 10:46AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Emergency / Exit Light Panel. Years: 1992 Systems: Surface Fluorescent In The Library. Years: 2005 Systems: Science Lab & Prep Room & Partial Battery Packed Emergency and Exit Lights. Years: 2007 Systems: Fire Alarm System & Elevator Intercom. Years: 2006 Systems: Public Address & Local Sound System. Years: 2006 Systems: All Auditorium Electrical Systems Except (Surface Fluorescent & Surface Incandescent). Years: 2006 Systems: Partial HID Lighting In The Gymnasium. Years: 2006 Systems: Local Area Network & Telephone System. Years: 2006 Systems: Security Exterior Lighting. Years: 2004 Systems: Intrusion Alarm System. Years: 1996
Type of Service	Below Ground

Priority Condition

Condition Description	Component Affected	Location Description	Person(s) Notified
Not Operational.	Magnetic Door Holder.	2nd floor corridor next to room 223	Elmer Acosta (Fireman)
Not Operational	Manual Pull Station.	1st floor exit 5	Elmer Acosta (Fireman)

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	1st floor
HOUSE LIGHTING	
Instance on 1st floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K332

Question	Response
AUDITORIUM	
HOUSE LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on 1st floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on 1st floor	Does not exist
Recessed Mounted	
Instance on 1st floor	Does not exist
Surface Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
LOCAL SOUND SYSTEM	
Instance on 1st floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
PROJECTION SYSTEM	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	No deficiencies recorded
THEATER LIGHTING SYSTEM	
Instance on 1st floor	Inspected
Dimming System	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA	
Instance	Inspected
Instance	1st floor
LIGHTING	
Instance on 1st floor	Inspected

NYC Department of Education
 Building Condition Assessment Survey 2010-2011

Electrical Inspection

K332

Question	Response
CAFETERIA	
LIGHTING	
Lighting Fixture - Fluorescent	
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on 1st floor	Does not exist
Recessed Mounted	
Instance on 1st floor	Does not exist
Surface Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 1st floor	Does not exist
Surface Mounted	
Instance on 1st floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K332

Question	Response
CAFETERIA	
LIGHTING	
Lighting Fixture - Incandescent	
Recessed Mounted	
Instance on 1st floor	Does not exist
Surface Mounted	
Instance on 1st floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 1st floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
CITY FIRE ALARM SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Pendant Mounted	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1,026
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Does not exist	
Surface Mounted	
Inspected	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	227
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Does not exist	
Lighting Fixture - Incandescent	
Inspected	
Pendant Mounted	
Inspected	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K332

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Lighting Fixture - Incandescent	
Pendant Mounted	
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	67
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	52
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SMART BOARD	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
COMPUTER LAB	Inspected
Instance	Rooms 323,423
Has LAN/Modem access	Yes
Power Panel?	Yes
LIGHTING	
Instance on Rooms 323,423	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms 323,423	Inspected
Pendant Mounted	
Instance on Rooms 323,423	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	36
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Rooms 323,423	Does not exist
Surface Mounted	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K332

Question	Response
COMPUTER LAB	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Instance on Rooms 323,423	Does not exist
Lighting Fixture - HID	
Instance on Rooms 323,423	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms 323,423	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Rooms 323,423	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
BATTERY PACK	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
BATTERY PACK	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
AREA SMOKE DETECTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
BELL/HORN	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
DUCT SMOKE DETECTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
ELEVATOR RECALL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
FAN SHUTDOWN CONTROL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
FIRE ALARM DIGITAL COMMUNICATOR	Does not exist
FUSED CUTOFF PANEL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
HEAT DETECTOR	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K332

Question	Response
FIRE ALARM SYSTEM	
HEAT DETECTOR	
Condition	1- Good
Deficiency	No deficiencies recorded
MAGNETIC DOOR HOLDER CONTACTOR	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	CONTACTOR NOT OPERATIONAL
Deficiency Location/Instance	2nd floor corridor next to Room 223
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
MAIN PANEL	
	Inspected
Bell At Panel	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	
	Inspected
Instance	1st floor (Main Lobby)
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Notifier
Model	N/A
EquipmentId	FACP
Capacity/Size	16 zones
Installation Year	2006
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	
	Does not exist
MANUAL PULL STATION	
	Inspected
Condition	1- Good
Deficiency	PULL STATION NOT OPERATIONAL
Deficiency Location/Instance	1st floor exit 5
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
REMOTE ANNUNCIATOR	
	Inspected
Display Monitor	
	Does not exist
Panel	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Printer	
	Inspected
Condition	5- Poor
Deficiency	PRINTER NOT OPERATIONAL
Deficiency Location/Instance	Custodian's Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K332

Question	Response
FIRE ALARM SYSTEM	
REMOTE ANNUNCIATOR	
Punch Register	Does not exist
SPRINKLER FLOW/AIR PRESSURE SWITCH	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
STROBE	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
SUB-PANEL	Does not exist
TAMPER FLOW SWITCH/CHAIN	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	Inspected
Instance	1st floor
LIGHTING	
Instance on 1st floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st floor	Does not exist
Lighting Fixture - HID	
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	17
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 1st floor	Does not exist
Surface Mounted	
Instance on 1st floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 1st floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SCOREBOARD	
Instance on 1st floor	Does not exist
THEATER LIGHTING SYSTEM	
Instance on 1st floor	Does not exist
INTERCOM SYSTEM	Inspected
ELEVATOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
HOLDING AREA	Inspected
Condition	3- Fair

NYC Department of Education
Building Condition Assessment Survey 2010-2011

Electrical Inspection

K332

Question	Response
INTERCOM SYSTEM	
HOLDING AREA	
Deficiency	No deficiencies recorded
KITCHEN/WARMING PANTRY	Inspected
Instance	1st floor
LIGHTING	
Instance on 1st floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on 1st floor	Does not exist
Recessed Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	34
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 1st floor	Does not exist
Lighting Fixture - HID	
Instance on 1st floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 1st floor	Does not exist
Surface Mounted	
Instance on 1st floor	Does not exist
LAN	Inspected
LOCAL DISTRIBUTION FRAME (I/LDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
MAIN EQUIPMENT RACK (MDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	Room 207
Has LAN/Modem access	Yes
LIGHTING	
Instance on Room 207	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K332

Question	Response
LIBRARY	
LIGHTING	
Lighting Fixture - Fluorescent	
Instance on Room 207	Inspected
Pendant Mounted	
Instance on Room 207	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	27
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room 207	Does not exist
Surface Mounted	
Instance on Room 207	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room 207	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 207	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 207	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SMART BOARD	
Instance on Room 207	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
LIGHTING - SECURITY LIGHTS	Inaccessible
LIGHTNING PROTECTION	Does not exist
LOCKER ROOM	
Instance on 1st floor (Inside The Gymnasium)	Inspected
Alternative Use	Yes
LIGHTING	
Instance on 1st floor (Inside The Gymnasium)	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st floor (Inside The Gymnasium)	Does not exist
Lighting Fixture - HID	
Instance on 1st floor (Inside The Gymnasium)	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st floor (Inside The Gymnasium)	Inspected
Pendant Mounted	
Instance on 1st floor (Inside The Gymnasium)	Does not exist
Recessed Mounted	
Instance on 1st floor (Inside The Gymnasium)	Does not exist
Surface Mounted	
Instance on 1st floor (Inside The Gymnasium)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K332

Question	Response
LOCKER ROOM	
LIGHTING	
Lighting Fixture - Incandescent	
Surface Mounted	
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Boiler Room & Mechanical Room (Basement)
Deficiency Quantity	21
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
FUSED DISCONNECT SWITCH TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Boiler Room & Mechanical Room (Basement)
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED KNIFE SWITCH TYPE	Does not exist
FUSED TOGGLE SWITCH TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Electrical Room (Basement)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MOLDED CASE CIRCUIT BREAKER TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Corridors, Gymnasium, Cafeteria, Kitchen and Basement
Deficiency Quantity	14
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K332

Question	Response
PUBLIC ADDRESS SYSTEM	
Instance	Main Office (Room 123)
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	
	Does not exist
SCIENCE LAB	
Instance on Room 413	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 413	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room 413	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Room 413	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 413	Inspected
Pendant Mounted	
Instance on Room 413	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 413	Does not exist
Surface Mounted	
Instance on Room 413	Does not exist
Lighting Fixture - HID	
Instance on Room 413	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 413	Does not exist
POWER SUPPLY	
Instance on Room 413	Does not exist
PROJECTION SYSTEM	
Instance on Room 413	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
SMART BOARD	
Instance on Room 413	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
SCIENCE PREP ROOM	
Instance on Room 413A	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 413A	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K332

Question	Response
SCIENCE PREP ROOM	
EMERGENCY GAS SHUT-OFF VALVE	
Instance Condition	1- Good
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room 413A	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Room 413A	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 413A	Inspected
Pendant Mounted	
Instance on Room 413A	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 413A	Does not exist
Surface Mounted	
Instance on Room 413A	Does not exist
Lighting Fixture - HID	
Instance on Room 413A	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 413A	Does not exist
POWER SUPPLY	
Instance on Room 413A	Does not exist
SECURITY	
INTRUSION ALARM	
Central Control Panel	
Instance	Custodian's Office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista 50P
Deficiency	No deficiencies recorded
Infrared Sensor	
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	
Condition	3- Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	
	Does not exist
IPDVS/CCTV SYSTEM	
	Does not exist
SERVICE SWITCH	
Instance	Electrical Room (Basement)
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K332

Question	Response
SERVICE SWITCH	
Manufacturer	Metropolitan Electric MFG Co.
EquipmentId	Main Serve. Sw.
Capacity/Size	2000 Amps
Source of Capacity/Size	Nameplate
Installation Year	1967
Source of Installation Year	Documented
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SWIMMING POOL	
	Does not exist
SWITCHBOARD	
	Inspected
Water Penetration In Electrical Room?	No
Number of Spares	0
AIR CIRCUIT BREAKER TYPE	
	Does not exist
FUSED DISCONNECT SWITCH TYPE	
	Inspected
Instance	Electrical Room (Basement)
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Metropolitan Electric MFG Co.
EquipmentId	Main SWBD
Capacity/Size	2000 Amps total, 2 sections
Source of Capacity/Size	Service Switch Size
Installation Year	1967
Source of Installation Year	Documented
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED KNIFE SWITCH TYPE	
	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	
	Does not exist
TELEPHONE	
	Inspected
PBX/INTERCOM	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
STANDARD	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	
	Inspected
LIGHTING	
	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K332

Question	Response
TOILET ROOM - STAFF	
LIGHTING	
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	19
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TOILET ROOM - STUDENT	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K332

Question	Response
TOILET ROOM - STUDENT	
LIGHTING	
Lighting Fixture - Incandescent	
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	13
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable System Exist?	Yes
Operational?	Yes
Master Antenna System Exist?	Yes
Operational?	No
MAIN EQUIPMENT RACK	Does not exist