

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K400

School: LAFAYETTE HS - K, 2630 BENSON AVENUE, BROOKLYN, NY, 11214

InspectionId	Inspection Type	Time In	Last Edited
1620029	ELECTRICAL	2010-11-02 08:51AM	2010-11-23 12:13PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	<p>Systems: Science Rooms (Labs, Preps). Years: 2006</p> <p>Systems: Theater Lighting System, Dimming System, Projector In Auditorium. Years: 1999</p> <p>Systems: Partial Emergency Lights (Battery Packed). Years: 1999</p> <p>Systems: Smart Boards. Years: 2008</p> <p>Systems: Elevator Intercom, Security Cameras. Years: 2009</p> <p>Systems: Partial Fluorescent Lights (Some Classrooms, Stairs, Some Toilets). Years: 2002</p> <p>Systems: Most Other Fluorescent Lights. Years: Approximately 1990</p> <p>Systems: Fluorescent Lights In Corridors, Partial Motor Starters. Years: 2005</p> <p>Systems: Partial Panel Boards (Molded Case). Years: 2001 to 2010</p> <p>Systems: Fused Disconnect Type Panel Boards (In Boiler Room). Years: 2010</p> <p>Systems: Lighting/ Security Lights. Years: 1995</p> <p>Systems: Local Sound System, Intrusion Alarm. Years: 1993</p> <p>Systems: Locker Rooms. Years: 2009</p> <p>Systems: Local Area Network, Telephone System. Years: 2003</p> <p>Systems: Fire Alarm System/ Public Address. Years: Under Construction</p> <p>Systems: Raceway In Computer Lab. Years: Approximately 2007</p> <p>Systems: Score Board In The Gym. Years: Approximately 2000</p> <p>Below Ground</p>
Type of Service	

Priority Condition

Condition Description	Component Affected	Location Description	Person(s) Notified
Water Penetration.	Lighting Fixtures.	Gym (Room 465)	Mike Desimone

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	1st floor
HOUSE LIGHTING	
Instance on 1st floor	Inspected
Does a Chandelier Exist?	Yes
Lighting Fixture - Fluorescent	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K400

Question	Response
AUDITORIUM	
HOUSE LIGHTING	
Lighting Fixture - Fluorescent	
Instance on 1st floor	Does not exist
Lighting Fixture - HID	
Instance on 1st floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 1st floor	Does not exist
Surface Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	31
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
LOCAL SOUND SYSTEM	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
PROJECTION SYSTEM	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Is the projector on a cart or installed on the ceiling?	Cart
Deficiency	No deficiencies recorded
THEATER LIGHTING SYSTEM	
Instance on 1st floor	Inspected
Dimming System	
Instance on 1st floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on 1st floor	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K400

Question	Response
AUDITORIUM	
THEATER LIGHTING SYSTEM	
Theater Lighting	
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	3- Fair
Deficiency	BELL NOT OPERATIONAL
Deficiency Location/Instance	Main Entrance Door
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BELL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
CAFETERIA	
Instance	Basement (Students)
Instance	Basement (Staff)
LIGHTING	
Instance on Basement (Students)	Inspected
Instance on Basement (Staff)	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement (Students)	Inspected
Instance on Basement (Staff)	Inspected
Pendant Mounted	
Instance on Basement (Students)	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Basement (Staff)	Does not exist
Recessed Mounted	
Instance on Basement (Students)	Does not exist
Instance on Basement (Staff)	Does not exist
Surface Mounted	
Instance on Basement (Students)	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Basement (Staff)	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Basement (Students)	Does not exist
Instance on Basement (Staff)	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement (Students)	Does not exist
Instance on Basement (Staff)	Does not exist
LOCAL SOUND SYSTEM	
Instance on Basement (Students)	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Basement (Staff)	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
CITY FIRE ALARM SYSTEM	
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K400

Question	Response
CITY FIRE ALARM SYSTEM	
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
LIGHTING	Inspected
Does a Chandelier Exist?	Yes
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	44
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	17
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	23
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	53
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K400

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Lighting Fixture - Incandescent	
Surface Mounted	
Purpose of Action	LEVEL 2
Violations	No violations recorded
SMART BOARD	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
COMPUTER LAB	Inspected
Instance	Room 427
Has LAN/Modem access	Yes
Power Panel?	Yes
LIGHTING	
Instance on Room 427	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 427	Inspected
Pendant Mounted	
Instance on Room 427	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	27
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room 427	Does not exist
Surface Mounted	
Instance on Room 427	Does not exist
Lighting Fixture - HID	
Instance on Room 427	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 427	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 427	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
BATTERY PACK	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
BATTERY PACK	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K400

Question	Response
EXIT LIGHT	
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Under construction
GROUNDING SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	Inspected
Instance	1st floor
Instance	Room 465 (Girls)
Instance	Room 466 (Bays)
Instance	Basement
LIGHTING	
Instance on 1st floor	Inspected
Instance on Room 465 (Girls)	Inspected
Instance on Room 466 (Bays)	Inspected
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st floor	Does not exist
Instance on Room 465 (Girls)	Does not exist
Instance on Room 466 (Bays)	Does not exist
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st floor	Inspected
Instance on Room 465 (Girls)	Inspected
Instance on Room 466 (Bays)	Inspected
Instance on Basement	Does not exist
Pendant Mounted	
Instance on 1st floor	Does not exist
Instance on Room 465 (Girls)	Does not exist
Instance on Room 466 (Bays)	Does not exist
Recessed Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K400

Question	Response
GYMNASIUM	
LIGHTING	
Lighting Fixture - HID	
Recessed Mounted	
Deficiency Quantity	17
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 465 (Girls)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 466 (Bays)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 1st floor	Does not exist
Instance on Room 465 (Girls)	Does not exist
Instance on Room 466 (Bays)	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st floor	Does not exist
Instance on Room 465 (Girls)	Does not exist
Instance on Room 466 (Bays)	Does not exist
Instance on Basement	Does not exist
LOCAL SOUND SYSTEM	
Instance on 1st floor	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K400

Question	Response
GYMNASIUM	
LOCAL SOUND SYSTEM	
Deficiency	No deficiencies recorded
Instance on Room 465 (Girls)	Does not exist
Instance on Room 466 (Bays)	Does not exist
Instance on Basement	Does not exist
SCOREBOARD	
Instance on 1st floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 465 (Girls)	Does not exist
Instance on Room 466 (Bays)	Does not exist
Instance on Basement	Does not exist
THEATER LIGHTING SYSTEM	
Instance on 1st floor	Does not exist
Instance on Room 465 (Girls)	Does not exist
Instance on Room 466 (Bays)	Does not exist
Instance on Basement	Does not exist
INTERCOM SYSTEM	
	Inspected
ELEVATOR	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
HOLDING AREA	
	Does not exist
KITCHEN/WARMING PANTRY	
	Inspected
Instance	Basement
LIGHTING	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Does not exist
Recessed Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
LAN	
	Inspected
LOCAL DISTRIBUTION FRAME (I/LDF)	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MAIN EQUIPMENT RACK (MDF)	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIBRARY	
	Inspected
Instance	Room 368
Has LAN/Modem access	Yes
LIGHTING	
Instance on Room 368	Inspected
Lighting Fixture - Fluorescent	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K400

Question	Response
LIBRARY	
LIGHTING	
Lighting Fixture - Fluorescent	
Instance on Room 368	Inspected
Pendant Mounted	
Instance on Room 368	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 368	Does not exist
Surface Mounted	
Instance on Room 368	Does not exist
Lighting Fixture - HID	
Instance on Room 368	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 368	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 368	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SMART BOARD	
Instance on Room 368	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
LIGHTING - SECURITY LIGHTS	
	Inspected
Condition	3- Fair
Replacement Quantity	57
Replacement Uom	EACH
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	At The Front Entrance Fence & Door
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 3
Violations	No violations recorded
LIGHTNING PROTECTION	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
LOCKER ROOM	
Instance on Room 365 (Girls)	Inspected
Alternative Use	No
Instance on Room 366 (Boys)	Inspected
Alternative Use	No
LIGHTING	
Instance on Room 365 (Girls)	Inspected
Instance on Room 366 (Boys)	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 365 (Girls)	Inspected
Instance on Room 366 (Boys)	Inspected
Pendant Mounted	
Instance on Room 365 (Girls)	Does not exist
Instance on Room 366 (Boys)	Does not exist
Recessed Mounted	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K400

Question	Response
LOCKER ROOM	
LIGHTING	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Instance on Room 365 (Girls)	Does not exist
Instance on Room 366 (Boys)	Does not exist
Surface Mounted	
Instance on Room 365 (Girls)	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 366 (Boys)	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room 365 (Girls)	Does not exist
Instance on Room 366 (Boys)	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 365 (Girls)	Does not exist
Instance on Room 366 (Boys)	Does not exist
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Mechanical Spaces
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
FUSED DISCONNECT SWITCH TYPE	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
FUSED KNIFE SWITCH TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Fan Room (Roof) & Boiler Room (Basement)
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED TOGGLE SWITCH TYPE	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	Inspected
Condition	2- Between Good and Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	All Floors Corridors, Rooms 325, 321, Kitchen and Cafeteria
Deficiency Quantity	35
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K400

Question	Response
PANEL BOARD	
MOLDED CASE CIRCUIT BREAKER TYPE	
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	
	Under construction
SCIENCE DEMO ROOM	
Instance on Room 115	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 202	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 208	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 302	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 313	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 315	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	Yes
Instance on Room 317	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 348	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 350	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 352	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 115	Does not exist
Instance on Room 202	Does not exist
Instance on Room 208	Does not exist
Instance on Room 302	Does not exist
Instance on Room 313	Does not exist
Instance on Room 315	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K400

Question	Response
SCIENCE DEMO ROOM	
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 317	Does not exist
Instance on Room 348	Does not exist
Instance on Room 350	Does not exist
Instance on Room 352	Does not exist
EMERGENCY SHUT-OFF POWER	
Instance on Room 115	Does not exist
Instance on Room 202	Does not exist
Instance on Room 208	Does not exist
Instance on Room 302	Does not exist
Instance on Room 313	Does not exist
Instance on Room 315	Does not exist
Instance on Room 317	Does not exist
Instance on Room 348	Does not exist
Instance on Room 350	Does not exist
Instance on Room 352	Does not exist
LIGHTING	
Instance on Room 115	Inspected
Instance on Room 202	Inspected
Instance on Room 208	Inspected
Instance on Room 302	Inspected
Instance on Room 313	Inspected
Instance on Room 315	Inspected
Instance on Room 317	Inspected
Instance on Room 348	Inspected
Instance on Room 350	Inspected
Instance on Room 352	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 115	Inspected
Instance on Room 202	Inspected
Instance on Room 208	Inspected
Instance on Room 302	Inspected
Instance on Room 313	Inspected
Instance on Room 315	Inspected
Instance on Room 317	Inspected
Instance on Room 348	Inspected
Instance on Room 350	Inspected
Instance on Room 352	Inspected
Pendant Mounted	
Instance on Room 115	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 202	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 208	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 302	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 313	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K400

Question	Response
SCIENCE DEMO ROOM	
LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Deficiency	No deficiencies recorded
Instance on Room 315	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 317	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 348	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 350	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 352	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 115	Does not exist
Instance on Room 202	Does not exist
Instance on Room 208	Does not exist
Instance on Room 302	Does not exist
Instance on Room 313	Does not exist
Instance on Room 315	Does not exist
Instance on Room 317	Does not exist
Instance on Room 348	Does not exist
Instance on Room 350	Does not exist
Instance on Room 352	Does not exist
Surface Mounted	
Instance on Room 115	Does not exist
Instance on Room 202	Does not exist
Instance on Room 208	Does not exist
Instance on Room 302	Does not exist
Instance on Room 313	Does not exist
Instance on Room 315	Does not exist
Instance on Room 317	Does not exist
Instance on Room 348	Does not exist
Instance on Room 350	Does not exist
Instance on Room 352	Does not exist
Lighting Fixture - HID	
Instance on Room 115	Does not exist
Instance on Room 202	Does not exist
Instance on Room 208	Does not exist
Instance on Room 302	Does not exist
Instance on Room 313	Does not exist
Instance on Room 315	Does not exist
Instance on Room 317	Does not exist
Instance on Room 348	Does not exist
Instance on Room 350	Does not exist
Instance on Room 352	Does not exist
Lighting Fixture - Incandescent	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K400

Question	Response
SCIENCE DEMO ROOM	
LIGHTING	
Lighting Fixture - Incandescent	
Instance on Room 115	Does not exist
Instance on Room 202	Does not exist
Instance on Room 208	Does not exist
Instance on Room 302	Does not exist
Instance on Room 313	Does not exist
Instance on Room 315	Does not exist
Instance on Room 317	Does not exist
Instance on Room 348	Does not exist
Instance on Room 350	Does not exist
Instance on Room 352	Does not exist
POWER SUPPLY	
Instance on Room 115	Does not exist
Instance on Room 202	Does not exist
Instance on Room 208	Does not exist
Instance on Room 302	Does not exist
Instance on Room 313	Does not exist
Instance on Room 315	Does not exist
Instance on Room 317	Does not exist
Instance on Room 348	Does not exist
Instance on Room 350	Does not exist
Instance on Room 352	Does not exist
PROJECTION SYSTEM	
Instance on Room 115	Does not exist
Instance on Room 202	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 208	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 302	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 313	Does not exist
Instance on Room 315	Does not exist
Instance on Room 317	Does not exist
Instance on Room 348	Does not exist
Instance on Room 350	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 352	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SMART BOARD	
Instance on Room 115	Does not exist
Instance on Room 202	Does not exist
Instance on Room 208	Does not exist
Instance on Room 302	Does not exist
Instance on Room 313	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 315	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K400

Question	Response
SCIENCE DEMO ROOM	
SMART BOARD	
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 317	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 348	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 350	Does not exist
Instance on Room 352	Does not exist
SCIENCE LAB	
Instance on Rooms 107, 205, 306 and 311	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Rooms 107, 205, 306 and 311	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Rooms 107, 205, 306 and 311	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Rooms 107, 205, 306 and 311	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms 107, 205, 306 and 311	Inspected
Pendant Mounted	
Instance on Rooms 107, 205, 306 and 311	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Rooms 107, 205, 306 and 311	Does not exist
Surface Mounted	
Instance on Rooms 107, 205, 306 and 311	Does not exist
Lighting Fixture - HID	
Instance on Rooms 107, 205, 306 and 311	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms 107, 205, 306 and 311	Does not exist
POWER SUPPLY	
Instance on Rooms 107, 205, 306 and 311	Inspected
Instructor Unit	
Instance on Rooms 107, 205, 306 and 311	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Rooms 107, 205, 306 and 311	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Student Unit	
Instance on Rooms 107, 205, 306 and 311	Inspected
Instance Condition	1- Good

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K400

Question	Response
SCIENCE LAB	
POWER SUPPLY	
Student Unit	
Deficiency	No deficiencies recorded
PROJECTION SYSTEM	
Instance on Rooms 107, 205, 306 and 311	Does not exist
SMART BOARD	
Instance on Rooms 107, 205, 306 and 311	Does not exist
SCIENCE PREP ROOM	
Instance on Rooms 113, 209, 308 and 309	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Rooms 113, 209, 308 and 309	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Rooms 113, 209, 308 and 309	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Rooms 113, 209, 308 and 309	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms 113, 209, 308 and 309	Inspected
Pendant Mounted	
Instance on Rooms 113, 209, 308 and 309	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Rooms 113, 209, 308 and 309	Does not exist
Surface Mounted	
Instance on Rooms 113, 209, 308 and 309	Does not exist
Lighting Fixture - HID	
Instance on Rooms 113, 209, 308 and 309	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms 113, 209, 308 and 309	Does not exist
POWER SUPPLY	
Instance on Rooms 113, 209, 308 and 309	Does not exist
SECURITY	
INTRUSION ALARM	
Central Control Panel	
Instance	Custodian's Office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Deficiency	No deficiencies recorded
Infrared Sensor	
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	
Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K400

Question	Response
SECURITY	
INTRUSION ALARM	
Remote Annunciator	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	Does not exist
IPDVS/CCTV SYSTEM	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
SERVICE SWITCH	Inspected
Instance	Electrical Room (Basement)
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Boltswitch, Inc.
EquipmentId	Main Service Switch B
Capacity/Size	1600 Amps
Source of Capacity/Size	Nameplate
Installation Year	1953
Source of Installation Year	Estimated
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room (Basement)
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Boltswitch, Inc.
EquipmentId	N/A
Capacity/Size	1600 Amps
Source of Capacity/Size	Nameplate
Installation Year	1953
Source of Installation Year	Estimated
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCH ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
SWIMMING POOL	Does not exist
SWITCHBOARD	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K400

Question	Response
SWITCHBOARD	
Water Penetration In Electrical Room?	No
Number of Spares	0
AIR CIRCUIT BREAKER TYPE	Does not exist
FUSED DISCONNECT SWITCH TYPE	Inspected
Instance	Electrical Room (Basement)
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	Main Switchboard A
Capacity/Size	1600 Amps total, 4 sections
Source of Capacity/Size	Service Switch Size
Installation Year	1953
Source of Installation Year	Estimated
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room (Basement)
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	Main Switchboard B
Capacity/Size	1600 Amps total, 4 sections
Source of Capacity/Size	Service Switch Size
Installation Year	1953
Source of Installation Year	Estimated
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED KNIFE SWITCH TYPE	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K400

Question	Response
TELEPHONE	Inspected
PBX/INTERCOM	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
STANDARD	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TOILET ROOM - STUDENT	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TRANSFORMER	Does not exist
TV SYSTEM	Inspected

NYC Department of Education
Building Condition Assessment Survey 2010-2011

Electrical Inspection

K400

Question	Response
TV SYSTEM	
Cable System Exist?	No
Master Antenna System Exist?	No
MAIN EQUIPMENT RACK	
	Does not exist
