

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K426**

School: **MADISON AF - BROOKLYN, 3787 BEDFORD AVENUE, BROOKLYN, NY, 11229**

InspectionId	Inspection Type	Time In	Last Edited
2000025	ELECTRICAL	2010-11-05 08:52AM	2010-11-15 04:59PM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: HID Lighting Years: 1989 Systems: Scoreboard, Fluorescent Lights, Circuit Breaker Panel, Exterior Light Years: 2003
Type of Service	Below Ground

**Priority Condition**

No condition recorded

**Inspection**

Question	Response
<b>ELECTRICAL</b>	
<b>ATHLETIC FIELD</b>	Inspected
<b>EXTERIOR LIGHTING</b>	Does not exist
<b>LOCAL SOUND SYSTEM</b>	Does not exist
<b>SCOREBOARD</b>	Inspected
Instance	East Side
Instance Condition	5- Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>AUDITORIUM</b>	Does not exist
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	Does not exist
<b>CAFETERIA</b>	Does not exist
<b>CITY FIRE ALARM SYSTEM</b>	Does not exist
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	Inspected
<b>LIGHTING</b>	Inspected
Does a Chandelier Exist?	Yes
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K426**

<b>Question</b>	<b>Response</b>
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Pendant Mounted</b>	
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SMART BOARD</b>	Does not exist
<b>COMPUTER LAB</b>	Does not exist
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Does not exist
<b>EMERGENCY LIGHTING</b>	Does not exist
<b>EXIT LIGHT</b>	Does not exist
<b>EXIT/EMERGENCY LIGHT</b>	Does not exist
<b>FIRE ALARM SYSTEM</b>	Does not exist
<b>GROUNDING SYSTEM</b>	Does not exist
<b>GYMNASIUM</b>	Does not exist
<b>INTERCOM SYSTEM</b>	Does not exist
<b>KITCHEN/WARMING PANTRY</b>	Does not exist
<b>LAN</b>	Does not exist
<b>LIBRARY</b>	Does not exist
<b>LIGHTING - SECURITY LIGHTS</b>	Inspected
Condition	2- Between Good and Fair
Replacement Quantity	1
Replacement Uom	EACH
Deficiency	No deficiencies recorded
<b>LIGHTNING PROTECTION</b>	Does not exist
<b>LOCKER ROOM</b>	
Instance on 1st Floor- Boys West	Inspected
Alternative Use	No
Instance on 1st Floor- Boys East	Inspected
Alternative Use	No
<b>LIGHTING</b>	
Instance on 1st Floor- Boys West	Inspected
Instance on 1st Floor- Boys East	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor- Boys West	Does not exist
Instance on 1st Floor- Boys East	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor- Boys West	Inspected
Instance on 1st Floor- Boys East	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor- Boys West	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K426**

Question	Response
<b>LOCKER ROOM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - HID</b>	
<b>Pendant Mounted</b>	
Instance on 1st Floor- Boys East	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st Floor- Boys West	Does not exist
Instance on 1st Floor- Boys East	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor- Boys West	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 1st Floor- Boys East	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor- Boys West	Inspected
Instance on 1st Floor- Boys East	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor- Boys West	Does not exist
Instance on 1st Floor- Boys East	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st Floor- Boys West	Does not exist
Instance on 1st Floor- Boys East	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor- Boys West	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 1st Floor- Boys East	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Does not exist
<b>MULTIPURPOSE ROOM</b>	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>FUSED DISCONNECT SWITCH TYPE</b>	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K426**

<b>Question</b>	<b>Response</b>
<b>PANEL BOARD</b>	
<b>FUSED KNIFE SWITCH TYPE</b>	Does not exist
<b>FUSED TOGGLE SWITCH TYPE</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Jimmy's office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>PUBLIC ADDRESS SYSTEM</b>	Does not exist
<b>SCIENCE DEMO ROOM</b>	Does not exist
<b>SCIENCE LAB</b>	Does not exist
<b>SCIENCE PREP ROOM</b>	Does not exist
<b>SECURITY</b>	Does not exist
<b>SERVICE SWITCH</b>	Does not exist
<b>SWIMMING POOL</b>	Does not exist
<b>SWITCHBOARD</b>	Does not exist
<b>TELEPHONE</b>	Does not exist
<b>TOILET ROOM - STAFF</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Does not exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE

NYC Department of Education  
Building Condition Assessment Survey 2010-2011

*Electrical Inspection*

K426

Question	Response
<b>TOILET ROOM - STUDENT</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Surface Mounted</b>	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>TRANSFORMER</b>	Does not exist
<b>TV SYSTEM</b>	Does not exist