

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K426

School: **MADISON AF - BROOKLYN, 3787 BEDFORD AVENUE, BROOKLYN, NY, 11229**

InspectionId	Inspection Type	Time In	Last Edited
1251158	ELECTRICAL	2009-06-04 08:29AM	2009-06-29 08:33AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Exterior Security Light Years: 2004 Systems: Scoreboard, General Lighting / Partial, Panel Board Molded Case Circuit Breakers Years: 2003 Systems: HID Lighting in Boys and Girls Locker Rooms Years: 1989

Priority Condition

No condition recorded

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Inspected
Exterior Lighting	Does not exist
Local Sound System	Does not exist
Scoreboard	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
AUDITORIUM	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	Does not exist
CAFETERIA	Does not exist
CAFETERIA/MULTIPURPOSE ROOM	Does not exist
CITY FIRE ALARM SYSTEM	Does not exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Inspected
Condition	5- Poor
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	5- Poor
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K426

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Lighting Fixture - Incandescent	
Surface Mounted	
Purpose of Action	LEVEL 2
Violations	No violations recorded
COMPUTER LAB	Does not exist
ELECTRIC SERVICE SWITCH	Does not exist
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not exist
EMERGENCY LIGHTING	Does not exist
EXIT LIGHT	Inspected
Battery Pack	Does not exist
Connected To Emergency Generator System	Does not exist
Connected To Emergency Light/Exit Light Panel	Inspected
Condition	5- Poor
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Boys Locker Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
FIRE ALARM SYSTEM	Does not exist
GROUNDING SYSTEM	Does not exist
GYMNASIUM	Does not exist
INTERCOM SYSTEM	Does not exist
KITCHEN/WARMING PANTRY	Does not exist
LAN	Does not exist
LIBRARY	Does not exist
LIGHTING - EXTERIOR SECURITY	Inspected
Condition	2- Between Good and Fair
Replacement Quantity	1
Replacement Uom	EACH
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	Does not exist
LOCKER ROOM/SHOWER ROOM	Inspected
Instance	Field House (Boys and Girls)
Alternative Use	No
Lighting	
Instance on Field House (Boys and Girls)	Inspected
Lighting Fixture - Fluorescent	
Instance on Field House (Boys and Girls)	Inspected
Pendant Mounted	
Instance on Field House (Boys and Girls)	Does not exist
Recessed Mounted	
Instance on Field House (Boys and Girls)	Does not exist
Surface Mounted	
Instance on Field House (Boys and Girls)	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K426

Question	Response
LOCKER ROOM/SHOWER ROOM	
Lighting	
Lighting Fixture - HID	
Instance on Field House (Boys and Girls)	Inspected
Pendant Mounted	
Instance on Field House (Boys and Girls)	Does not exist
Recessed Mounted	
Instance on Field House (Boys and Girls)	Does not exist
Surface Mounted	
Instance on Field House (Boys and Girls)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - Incandescent	
Instance on Field House (Boys and Girls)	Inspected
Pendant Mounted	
Instance on Field House (Boys and Girls)	Does not exist
Recessed Mounted	
Instance on Field House (Boys and Girls)	Does not exist
Surface Mounted	
Instance on Field House (Boys and Girls)	Inspected
Instance Condition	5- Poor
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Does not exist
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Does not exist
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Boile Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Molded Case Circuit Breaker Type	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	Does not exist
SCIENCE DEMO ROOM	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K426

Question	Response
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	Does not exist
SECURITY	Does not exist
SWIMMING POOL	Does not exist
SWITCHBOARD	Does not exist
TELEPHONE	Does not exist
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Inspected
Condition	5- Poor
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Inspected
Condition	5- Poor
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Does not exist