

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

School: **SHEEPSHEAD BAY HS - K, 3000 AVENUE X, BROOKLYN, NY, 11235**

InspectionId	Inspection Type	Time In	Last Edited
1247097	ELECTRICAL	2009-04-21 08:25AM	2009-05-26 10:54AM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Auditorium- Local Sound System Years: 2009 Systems: Switchboards, Gymnasium- Scoreboard Years: 2006 Systems: Fire Alarm System, Projection System, Telephone System, Intercom System- Elevator Years: 2005 Systems: Exterior Security Lighting, Interior Lighting- Fluorescent, HID; Partial Panel Boards, Security Intrusion Alarm, Partial Science Rooms Years: 2002-2003 Systems: LAN, CCTV System Years: 2004 Systems: Emergency and Exit Lighting Years: 1999-2000 Systems: Intercom System- Holding Areas Years: 2007

**Priority Condition**

No condition recorded

**Inspection**

Question	Response
<b>ELECTRICAL</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance	First Floor
<b>House Lighting</b>	
Instance on First Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on First Floor	Inspected
<b>Pendant Mounted</b>	
Instance on First Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on First Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on First Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on First Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on First Floor	Does not exist
<b>Local Sound System</b>	
Instance on First Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on First Floor	Inspected
Instance Condition	2- Between Good and Fair

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

<b>Question</b>	<b>Response</b>
<b>AUDITORIUM</b>	
<b>Projection System</b>	
Deficiency	No deficiencies recorded
<b>Theater Lighting System</b>	
Instance on First Floor	Inspected
<b>Dimming System</b>	
Instance on First Floor	Inspected
Instance Condition	3- Fair
Deficiency	DIMMING RACK BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Theater Lighting</b>	
Instance on First Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	144
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	
Condition	3- Fair
Replacement Quantity	300,000
Replacement Uom	S.F.
Deficiency	No deficiencies recorded
<b>CAFETERIA</b>	
Instance	First Floor (Students)
Instance	Teachers- Room129
<b>Lighting</b>	
Instance on First Floor (Students)	Inspected
Instance on Teachers- Room129	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on First Floor (Students)	Inspected
Instance on Teachers- Room129	Inspected
<b>Pendant Mounted</b>	
Instance on First Floor (Students)	Does not exist
Instance on Teachers- Room129	Does not exist
<b>Recessed Mounted</b>	
Instance on First Floor (Students)	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Teachers- Room129	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on First Floor (Students)	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

<b>Question</b>	<b>Response</b>
<b>CAFETERIA</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Instance on Teachers- Room129	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on First Floor (Students)	Does not exist
Instance on Teachers- Room129	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on First Floor (Students)	Does not exist
Instance on Teachers- Room129	Does not exist
<b>Local Sound System</b>	
Instance on First Floor (Students)	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Teachers- Room129	Does not exist
<b>CAFETERIA/MULTIPURPOSE ROOM</b>	Does not exist
<b>CITY FIRE ALARM SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	Does not exist
<b>COMPUTER LAB</b>	Inspected
Instance	Room 380
Has LAN/Modem access	No

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

<b>Question</b>	<b>Response</b>
<b>COMPUTER LAB</b>	
Power Panel?	No
Instance	Room 379, Room 377, Room 373
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room 376
Has LAN/Modem access	No
Power Panel?	No
Instance	Room 210
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room 206
Has LAN/Modem access	Yes
Power Panel?	Yes
<b>Lighting</b>	
Instance on Room 380	Inspected
Instance on Room 379, Room 377, Room 373	Inspected
Instance on Room 376	Inspected
Instance on Room 210	Inspected
Instance on Room 206	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 380	Inspected
Instance on Room 379, Room 377, Room 373	Inspected
Instance on Room 376	Inspected
Instance on Room 210	Inspected
Instance on Room 206	Inspected
<b>Pendant Mounted</b>	
Instance on Room 380	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 379, Room 377, Room 373	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 376	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 210	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 206	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 380	Does not exist
Instance on Room 379, Room 377, Room 373	Does not exist
Instance on Room 376	Does not exist
Instance on Room 210	Does not exist
Instance on Room 206	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

Question	Response
<b>COMPUTER LAB</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Instance on Room 379, Room 377, Room 373	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 376	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 210	Does not exist
Instance on Room 206	Does not exist
Instance on Room 380	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 380	Does not exist
Instance on Room 379, Room 377, Room 373	Does not exist
Instance on Room 376	Does not exist
Instance on Room 210	Does not exist
Instance on Room 206	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 380	Does not exist
Instance on Room 379, Room 377, Room 373	Does not exist
Instance on Room 376	Does not exist
Instance on Room 210	Does not exist
Instance on Room 206	Does not exist
<b>Raceway With Receptacles</b>	
Instance on Room 380	Does not exist
Instance on Room 379, Room 377, Room 373	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 376	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 210	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 206	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>ELECTRIC SERVICE SWITCH</b>	
Instance	Inspected
Instance	Electrical Meter Room- Room 053
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co.
Model	Royal Switchboard Co.
EquipmentId	Switchboard West
Capacity/Size	4000 Amps
Installation Year	1965
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Electrical Meter Room- Room 053
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

<b>Question</b>	<b>Response</b>
<b>ELECTRIC SERVICE SWITCH</b>	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Meter Room- Room 053
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co.
Model	Royal Switchboard Co.
EquipmentId	Switchboard East Section A
Capacity/Size	2000 Amps
Installation Year	1965
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Electrical Meter Room- Room 053
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Meter Room- Room 053
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co.
Model	Royal Switchboard Co.
EquipmentId	Switchboard East Section B
Capacity/Size	2000 Amps
Installation Year	1965
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Electrical Meter Room- Room 053
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Meter Room- Room 053
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co.
Model	Royal Switchboard Co.
EquipmentId	N/A
Capacity/Size	1200 Amps
Installation Year	1965
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Electrical Meter Room- Room 053
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCH ID IS MISSING
Deficiency Location/Instance	Electrical Meter Room- Room 053
Deficiency Quantity	1

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

<b>Question</b>	<b>Response</b>
<b>ELECTRIC SERVICE SWITCH</b>	
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Sub Electrical Room (Switchboard Room)- Room B22A
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co.
Model	Royal Switchboard Co.
EquipmentId	Switchboard West Section A
Capacity/Size	2000 Amps
Installation Year	1965
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Sub Electrical Room (Switchboard Room)- Room B22A
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Sub Electrical Room (Switchboard Room)- Room B22A
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co.
Model	Royal Switchboard Co.
EquipmentId	Switchboard West Section B
Capacity/Size	2000 Amps
Installation Year	1965
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Sub Electrical Room (Switchboard Room)- Room B22A
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Gymnasium- Room 183G
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

<b>Question</b>	<b>Response</b>
<b>EMERGENCY LIGHTING</b>	
<b>Connected To Emergency Generator System</b>	Does not exist
<b>Connected To Emergency Light/Exit Light Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Relay Test Switch</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	
<b>Battery Pack</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Connected To Emergency Generator System</b>	Does not exist
<b>Connected To Emergency Light/Exit Light Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>FIRE ALARM SYSTEM</b>	
Replacement Quantity	300,000
Replacement Uom	S.F.
<b>Area Smoke Detector</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Bell/Horn</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Duct Smoke Detector</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Elevator Recall</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Fan Shutdown Control</b>	Inspected
Condition	5- Poor
Deficiency	CONTROL NOT OPERATIONAL
Deficiency Location/Instance	Throughout Building
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Fire Alarm Digital Communicator</b>	Does not exist
<b>Fused Cutout Panel</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Heat Detector</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Magnetic Door Holder Contactor</b>	Inspected
Condition	5- Poor
Deficiency	CONTACTOR NOT OPERATIONAL
Deficiency Location/Instance	Corridors
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>Magnetic Door Holder Contactor</b>	
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Main Panel</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Inspected
Instance	Main Entrance of Building
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards Systems Technology
Model	EST-2
EquipmentId	N/A
Capacity/Size	24 zones
Installation Year	2005
Deficiency	PANEL ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Fire Alarm Control Panel (Standard)</b>	Does not exist
<b>Manual Pull Station</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	PULL STATION NOT OPERATIONAL
Deficiency Location/Instance	Third Floor- Near Exit 5 and 6
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Remote Annunciator</b>	Inspected
<b>Display Monitor</b>	Does not exist
<b>Panel</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Printer</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Punch Register</b>	Does not exist
<b>Sprinkler Flow/Air Pressure Switch</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Strobe</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Sub-Panel</b>	Does not exist
<b>Tamper Flow Switch/Chain</b>	Inspected
Condition	1- Good

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>Tamper Flow Switch/Chain</b>	
Deficiency	No deficiencies recorded
<b>GROUNDING SYSTEM</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	
Instance	Inspected
Instance	Room 183G
Instance	Room 173G
Instance	Room 171G
Instance	Room 081G
<b>Lighting</b>	
Instance on Room 183G	Inspected
Instance on Room 173G	Inspected
Instance on Room 171G	Inspected
Instance on Room 081G	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 183G	Does not exist
Instance on Room 173G	Does not exist
Instance on Room 171G	Does not exist
Instance on Room 081G	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 183G	Inspected
Instance on Room 173G	Inspected
Instance on Room 171G	Inspected
Instance on Room 081G	Inspected
<b>Pendant Mounted</b>	
Instance on Room 183G	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 173G	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 171G	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 081G	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 183G	Does not exist
Instance on Room 173G	Does not exist
Instance on Room 171G	Does not exist
Instance on Room 081G	Does not exist
<b>Surface Mounted</b>	
Instance on Room 183G	Does not exist
Instance on Room 173G	Does not exist
Instance on Room 171G	Does not exist
Instance on Room 081G	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 183G	Does not exist
Instance on Room 173G	Does not exist
Instance on Room 171G	Does not exist
Instance on Room 081G	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

<b>Question</b>	<b>Response</b>
<b>GYMNASIUM</b>	
<b>Local Sound System</b>	
Instance on Room 183G	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 173G	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 171G	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 081G	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Scoreboard</b>	
Instance on Room 183G	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 173G	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 171G	Does not exist
Instance on Room 081G	Does not exist
<b>Theater Lighting System</b>	
Instance on Room 183G	Does not exist
Instance on Room 173G	Does not exist
Instance on Room 171G	Does not exist
Instance on Room 081G	Does not exist
<b>INTERCOM SYSTEM</b>	
<b>Elevator</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

<b>Question</b>	<b>Response</b>
<b>INTERCOM SYSTEM</b>	
<b>Holding Area</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>KITCHEN/WARMING PANTRY</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>LAN</b>	Inspected
<b>Local Distribution Frame (I/LDF)</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Main Equipment Rack (MDF)</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>LIBRARY</b>	Inspected
Instance	Room 236
Has LAN/Modem access	Yes
<b>Lighting</b>	
Instance on Room 236	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 236	Inspected
<b>Pendant Mounted</b>	
Instance on Room 236	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 236	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on Room 236	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on Room 236	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 236	Does not exist
<b>Raceway With Receptacles</b>	
Instance on Room 236	Does not exist
<b>LIGHTING - EXTERIOR SECURITY</b>	Inspected
Condition	2- Between Good and Fair
Replacement Quantity	56

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

<b>Question</b>	<b>Response</b>
<b>LIGHTING - EXTERIOR SECURITY</b>	
Replacement Uom	EACH
Deficiency	No deficiencies recorded
<b>LIGHTNING PROTECTION</b>	Does not exist
<b>LOCKER ROOM/SHOWER ROOM</b>	Inspected
Instance	Room B85 (Boys), Room B83 (Boys Varsity), Room B81 (Girls Varsity), Room B79 (Girls)
Alternative Use	No
<b>Lighting</b>	
Instance on Room B85 (Boys), Room B83 (Boys Varsity), Room B81 (Girls Varsity), Room B79 (Girls)	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room B85 (Boys), Room B83 (Boys Varsity), Room B81 (Girls Varsity), Room B79 (Girls)	Inspected
<b>Pendant Mounted</b>	
Instance on Room B85 (Boys), Room B83 (Boys Varsity), Room B81 (Girls Varsity), Room B79 (Girls)	Does not exist
<b>Recessed Mounted</b>	
Instance on Room B85 (Boys), Room B83 (Boys Varsity), Room B81 (Girls Varsity), Room B79 (Girls)	Does not exist
<b>Surface Mounted</b>	
Instance on Room B85 (Boys), Room B83 (Boys Varsity), Room B81 (Girls Varsity), Room B79 (Girls)	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on Room B85 (Boys), Room B83 (Boys Varsity), Room B81 (Girls Varsity), Room B79 (Girls)	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room B85 (Boys), Room B83 (Boys Varsity), Room B81 (Girls Varsity), Room B79 (Girls)	Does not exist
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Second Floor Fan Room, Boiler Room
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MULTIPURPOSE ROOM</b>	Inspected
Instance	Dance Studio- Room B082G
<b>Lighting</b>	
Instance on Dance Studio- Room B082G	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Dance Studio- Room B082G	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Dance Studio- Room B082G	Inspected
<b>Pendant Mounted</b>	
Instance on Dance Studio- Room B082G	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

<b>Question</b>	<b>Response</b>
<b>MULTIPURPOSE ROOM</b>	
<b>Lighting</b>	
<b>Lighting Fixture - HID</b>	
<b>Recessed Mounted</b>	
Instance on Dance Studio- Room B082G	Does not exist
<b>Surface Mounted</b>	
Instance on Dance Studio- Room B082G	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Dance Studio- Room B082G	Does not exist
<b>Local Sound System</b>	
Instance on Dance Studio- Room B082G	Does not exist
<b>Theater Lighting System</b>	
Instance on Dance Studio- Room B082G	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>Fused Disconnect Switch Type</b>	Does not exist
<b>Fused Knife Switch Type</b>	Does not exist
<b>Fused Toggle Switch Type</b>	Does not exist
<b>Molded Case Circuit Breaker Type</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Cafeteria, Kitchen, Basement- Fan Room, First Floor Corridors
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>PUBLIC ADDRESS SYSTEM</b>	Inspected
Replacement Quantity	300,000
Replacement Uom	S.F.
Instance	Room 290
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Rauland Pro103
Deficiency	AMPLIFIER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Room 290
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	MASTER CLOCK BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Room 290
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Classrooms, and Corridors
Deficiency Quantity	20
Quantity Uom	EACH

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

<b>Question</b>	<b>Response</b>
<b>PUBLIC ADDRESS SYSTEM</b>	
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SCIENCE DEMO ROOM</b>	
	Inspected
Instance	Room 372
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	Room 325
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	Room 329, Room 327, Room 272, Room 271
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	Room 371
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance	Room 229, Room 227, Room 225
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
<b>Emergency Gas Shut-Off Valve</b>	
Instance on Room 372	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 325	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 329, Room 327, Room 272, Room 271	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 371	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 229, Room 227, Room 225	Does not exist
<b>Emergency Shut-Off Power</b>	
Instance on Room 372	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 325	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 329, Room 327, Room 272, Room 271	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 371	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 229, Room 227, Room 225	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>Lighting</b>	
Instance on Room 372	Inspected
Instance on Room 325	Inspected
Instance on Room 329, Room 327, Room 272, Room 271	Inspected
Instance on Room 371	Inspected
Instance on Room 229, Room 227, Room 225	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 372	Inspected
Instance on Room 325	Inspected
Instance on Room 329, Room 327, Room 272, Room 271	Inspected
Instance on Room 371	Inspected
Instance on Room 229, Room 227, Room 225	Inspected
<b>Pendant Mounted</b>	
Instance on Room 372	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 325	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 329, Room 327, Room 272, Room 271	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 371	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 229, Room 227, Room 225	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 372	Does not exist
Instance on Room 325	Does not exist
Instance on Room 329, Room 327, Room 272, Room 271	Does not exist
Instance on Room 371	Does not exist
Instance on Room 229, Room 227, Room 225	Does not exist
<b>Surface Mounted</b>	
Instance on Room 372	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 325	Does not exist
Instance on Room 329, Room 327, Room 272, Room 271	Does not exist
Instance on Room 371	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 229, Room 227, Room 225	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on Room 372	Does not exist
Instance on Room 325	Does not exist
Instance on Room 329, Room 327, Room 272, Room 271	Does not exist
Instance on Room 371	Does not exist
Instance on Room 229, Room 227, Room 225	Does not exist
<b>Lighting Fixture - Incandescent</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 372	Does not exist
Instance on Room 325	Does not exist
Instance on Room 329, Room 327, Room 272, Room 271	Does not exist
Instance on Room 371	Does not exist
Instance on Room 229, Room 227, Room 225	Does not exist
<b>Power Supply</b>	
Instance on Room 372	Inspected
Instance on Room 325	Inspected
Instance on Room 329, Room 327, Room 272, Room 271	Inspected
Instance on Room 371	Inspected
Instance on Room 229, Room 227, Room 225	Inspected
<b>Instructor Unit</b>	
Instance on Room 372	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 325	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 329, Room 327, Room 272, Room 271	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 371	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 229, Room 227, Room 225	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Meter Demonstration Unit</b>	
Instance on Room 372	Does not exist
Instance on Room 325	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 329, Room 327, Room 272, Room 271	Does not exist
Instance on Room 371	Does not exist
Instance on Room 229, Room 227, Room 225	Does not exist
<b>SCIENCE LAB</b>	
Instance	Room 328
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance	Room 320
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	Room 274
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	Room 228
Has LAN/Modem access	Yes
Power Panel?	Yes

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
Alternative Use	No
<b>Emergency Gas Shut-Off Valve</b>	
Instance on Room 328	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 320	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 274	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 228	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Emergency Shut-Off Power</b>	
Instance on Room 328	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 320	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 274	Does not exist
Instance on Room 228	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting</b>	
Instance on Room 328	Inspected
Instance on Room 320	Inspected
Instance on Room 274	Inspected
Instance on Room 228	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 328	Inspected
Instance on Room 320	Inspected
Instance on Room 274	Inspected
Instance on Room 228	Inspected
<b>Pendant Mounted</b>	
Instance on Room 328	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 320	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 274	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 228	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 328	Does not exist
Instance on Room 320	Does not exist
Instance on Room 274	Does not exist
Instance on Room 228	Does not exist
<b>Surface Mounted</b>	
Instance on Room 328	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Instance on Room 320	Does not exist
Instance on Room 274	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 228	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on Room 328	Does not exist
Instance on Room 320	Does not exist
Instance on Room 274	Does not exist
Instance on Room 228	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 328	Does not exist
Instance on Room 320	Does not exist
Instance on Room 274	Does not exist
Instance on Room 228	Does not exist
<b>Power Supply</b>	
Instance on Room 328	Inspected
Instance on Room 320	Inspected
Instance on Room 274	Inspected
Instance on Room 228	Inspected
<b>Instructor Unit</b>	
Instance on Room 328	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 320	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 274	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 228	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Meter Demonstration Unit</b>	
Instance on Room 328	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 320	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 274	Does not exist
Instance on Room 228	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Student Unit</b>	
Instance on Room 328	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>Power Supply</b>	
<b>Student Unit</b>	
Instance on Room 320	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 274	Does not exist
Instance on Room 228	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>SCIENCE PREP ROOM</b>	
Instance	Inspected
Instance	Room 324
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	No
Instance	Room 271P
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance	Room 226
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
<b>Emergency Gas Shut-Off Valve</b>	
Instance on Room 324	Does not exist
Instance on Room 271P	Does not exist
Instance on Room 226	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Emergency Shut-Off Power</b>	
Instance on Room 324	Does not exist
Instance on Room 271P	Does not exist
Instance on Room 226	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting</b>	
Instance on Room 324	Inspected
Instance on Room 271P	Inspected
Instance on Room 226	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 324	Inspected
Instance on Room 271P	Inspected
Instance on Room 226	Inspected
<b>Pendant Mounted</b>	
Instance on Room 324	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 271P	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 226	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 324	Does not exist
Instance on Room 271P	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

<b>Question</b>	<b>Response</b>
<b>SCIENCE PREP ROOM</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Recessed Mounted</b>	
Instance on Room 226	Does not exist
<b>Surface Mounted</b>	
Instance on Room 324	Does not exist
Instance on Room 271P	Does not exist
Instance on Room 226	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on Room 324	Does not exist
Instance on Room 271P	Does not exist
Instance on Room 226	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 324	Does not exist
Instance on Room 271P	Does not exist
Instance on Room 226	Does not exist
<b>Power Supply</b>	
Instance on Room 324	Does not exist
Instance on Room 271P	Does not exist
Instance on Room 226	Does not exist
<b>SECURITY</b>	Inspected
Replacement Quantity	300,000
Replacement Uom	S.F.
<b>Intrusion Alarm</b>	Inspected
<b>Central Control Panel</b>	Inspected
Instance	Custodian Office- Room 139
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Ademco Vista-128B
Deficiency	No deficiencies recorded
<b>Infrared Sensor</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Ultrasonic Sensor</b>	Does not exist
<b>IPDVS/CCTV System</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>SWIMMING POOL</b>	Does not exist
<b>SWITCHBOARD</b>	Inspected
<b>Air Circuit Breaker Type</b>	Does not exist
<b>Fused Disconnect Switch Type</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

<b>Question</b>	<b>Response</b>
<b>SWITCHBOARD</b>	
<b>Fused Disconnect Switch Type</b>	
Instance	Electrical Meter Room- Room 053
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard Co.
EquipmentId	East Distribution "A"
Capacity/Size	2000 Amps total, 2 sections
Installation Year	2006
Deficiency	No deficiencies recorded
Instance	Electrical Meter Room- Room 053
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard Co.
EquipmentId	East Distribution "B"
Capacity/Size	2000 Amps total, 2 sections
Installation Year	2006
Deficiency	No deficiencies recorded
Instance	Sub Electrical Room (Switchboard Room)- Room B22A
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard Co.
EquipmentId	LPP-PP
Capacity/Size	1200 Amps total, 2 sections
Installation Year	2006
Deficiency	No deficiencies recorded
<b>Fused Knife Switch Type</b>	Does not exist
<b>Molded Case Circuit Breaker Type</b>	Inspected
Instance	Electrical Meter Room- Room 053
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard Co.
EquipmentId	DP-EM
Capacity/Size	400 Amps total, 1 section
Installation Year	1999
Deficiency	No deficiencies recorded
Instance	Sub Electrical Room (Switchboard Room)- Room B22A
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard Co.
EquipmentId	Dist. SWBD West (A)
Capacity/Size	1600 Amps total, 1 section
Installation Year	2006
Deficiency	No deficiencies recorded
Instance	Sub Electrical Room (Switchboard Room)- Room B22A
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard Co.
EquipmentId	Dist. SWBD West (B)

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

<b>Question</b>	<b>Response</b>
<b>SWITCHBOARD</b>	
<b>Molded Case Circuit Breaker Type</b>	
Capacity/Size	1600 Amps total, 1 section
Installation Year	2006
Deficiency	No deficiencies recorded
Instance	Sub Electrical Room (Switchboard Room)- Room B22A
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard Co.
EquipmentId	LP-EM-A
Capacity/Size	400 Amps total, 1 section
Installation Year	1999
Deficiency	No deficiencies recorded
Instance	Sub Electrical Room (Switchboard Room)- Room B22A
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Electric Switchboard Co.
EquipmentId	Comp Distr. Panel
Capacity/Size	500 Amps total, 1 section
Installation Year	1999
Deficiency	No deficiencies recorded
Instance	Sub Electrical Room (Switchboard Room)- Room B22A
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Electric Switchboard Co.
EquipmentId	Air Cond. Power Panel
Capacity/Size	400 Amps total, 1 section
Installation Year	1999
Deficiency	No deficiencies recorded
Instance	Fan Room- Room B073
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co.
EquipmentId	FAN RM PP
Capacity/Size	600 Amps total, 1 section
Installation Year	1965
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>TELEPHONE</b>	Inspected
<b>PBX/Intercom</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Standard</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>TOILET ROOM - STAFF</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**K495**

<b>Question</b>	<b>Response</b>
<b>TOILET ROOM - STAFF</b>	
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TRANSFORMER</b>	Does not exist
<b>TV SYSTEM</b>	Inspected
<b>Cable Service</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Main Equipment Rack</b>	Does not exist
<b>Master Antenna System</b>	Inspected
Condition	3- Fair
Deficiency	ANTENNA NOT IN USE
Deficiency Location/Instance	Roof
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded