

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

School: **SHEEPSHEAD BAY HS - K, 3000 AVENUE X, BROOKLYN, NY, 11235**

InspectionId	Inspection Type	Time In	Last Edited
1620079	ELECTRICAL	2011-01-11 08:53AM	2011-06-01 09:43AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	<p>Systems: All Interior Fluorescent Lighting. Years: 2001</p> <p>Systems: Security Lights. Years: 2000</p> <p>Systems: Intercom System (Elevator). Years: 2010</p> <p>Systems: Intercom System (Holding Areas). Years: 2008</p> <p>Systems: Auditorium Local Sound System Years: 2009</p> <p>Systems: Auditorium Theater Lights & Dimming System & Projection System. Years: 1998</p> <p>Systems: Smart Boards. Years: 2008</p> <p>Systems: Local Area Network. Years: 2004</p> <p>Systems: Telephone System. Years: 2004</p> <p>Systems: Fire Alarm System (Except Standard Sub Panel). Years: 2005</p> <p>Systems: Intrusion Alarm System. Years: 2002</p> <p>Systems: Security Cameras. Years: 2004</p> <p>Systems: Partial Non Battery Packed Emergency Lights & Partial Non Battery Packed Exit Lights. Years: 1999</p> <p>Systems: Partial Battery Packed Emergency Lights & Partial Battery Packed Exit Lights. Years: 2004</p> <p>Systems: Partial Molded Case Panel Boards. Years: Approximately 1990 & 2000</p> <p>Systems: Science Rooms 228 & 226. Years: 2000- 2001</p> <p>Systems: Score Boards In 1st Floor Gymnasium. Years: 2005</p> <p>Systems: Switchboards. Years: Approximately 2006</p> <p>Systems: Partial Motor Starters. Years: Approximately 1990</p> <p>Systems: Master Clock For Public Address System. Years: Approximately 2004</p> <p>Systems: Emergency/ Exit Light Panel. Years: Approximately 2000</p> <p>Type of Service Below Ground</p>

Priority Condition

No condition recorded

Inspection

Question	Response
ELECTRICAL	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	1st floor
HOUSE LIGHTING	
Instance on 1st floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on 1st floor	Does not exist
Recessed Mounted	
Instance on 1st floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 1st floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on 1st floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on 1st floor	Does not exist
Recessed Mounted	
Instance on 1st floor	Does not exist
Surface Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
AUDITORIUM	
LOCAL SOUND SYSTEM	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
PROJECTION SYSTEM	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	No deficiencies recorded
THEATER LIGHTING SYSTEM	
Instance on 1st floor	Inspected
Dimming System	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	Inspected
Deficiency	3- Fair
CAFETERIA	
Instance	Inspected
Instance	1st floor (Students)
Instance	1st floor (Staff) -Room 129
LIGHTING	
Instance on 1st floor (Students)	Inspected
Instance on 1st floor (Staff) -Room 129	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st floor (Students)	Inspected
Instance on 1st floor (Staff) -Room 129	Inspected
Pendant Mounted	
Instance on 1st floor (Students)	Does not exist
Instance on 1st floor (Staff) -Room 129	Does not exist
Recessed Mounted	
Instance on 1st floor (Students)	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on 1st floor (Staff) -Room 129	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st floor (Students)	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on 1st floor (Staff) -Room 129	Does not exist
Lighting Fixture - HID	
Instance on 1st floor (Students)	Does not exist
Instance on 1st floor (Staff) -Room 129	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st floor (Students)	Does not exist
Instance on 1st floor (Staff) -Room 129	Does not exist
LOCAL SOUND SYSTEM	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
CAFETERIA	
LOCAL SOUND SYSTEM	
Instance on 1st floor (Students)	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SYSTEM NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on 1st floor (Staff) -Room 129	Does not exist
CITY FIRE ALARM SYSTEM	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Does a Chandelier Exist?	Inspected
Lighting Fixture - Fluorescent	No
Pendant Mounted	Inspected
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency Quantity	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Quantity Uom	14
Potential Action	EACH
Urgency of Action	MAINTENANCE
Purpose of Action	PRIORITY 3
Violations	LEVEL 2
Deficiency	No violations recorded
Deficiency Quantity	LIGHTING FIXTURE LENS MISSING
Quantity Uom	5
Potential Action	EACH
Urgency of Action	INSTALL LENS
Purpose of Action	PRIORITY 3
Violations	LEVEL 2
Deficiency	No violations recorded
Recessed Mounted	Inspected
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency Quantity	LIGHTING FIXTURE LENS MISSING
Quantity Uom	1
Potential Action	EACH
Urgency of Action	INSTALL LENS
Purpose of Action	PRIORITY 3
Violations	LEVEL 2
Deficiency	No violations recorded
Surface Mounted	Inspected
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency Quantity	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Quantity Uom	6
Potential Action	EACH
Potential Action	MAINTENANCE

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Inspected
Pendant Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	Does not exist
SMART BOARD	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
COMPUTER LAB	Inspected
Instance	Rooms 206, 210, 301, 377, 379
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Rooms 373 & 376
Has LAN/Modem access	Yes
Power Panel?	No
LIGHTING	
Instance on Rooms 206, 210, 301, 377, 379	Inspected
Instance on Rooms 373 & 376	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms 206, 210, 301, 377, 379	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
COMPUTER LAB	
LIGHTING	
Lighting Fixture - Fluorescent	
Instance on Rooms 373 & 376	Inspected
Pendant Mounted	
Instance on Rooms 206, 210, 301, 377, 379	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Rooms 373 & 376	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Rooms 206, 210, 301, 377, 379	Does not exist
Instance on Rooms 373 & 376	Does not exist
Surface Mounted	
Instance on Rooms 206, 210, 301, 377, 379	Does not exist
Instance on Rooms 373 & 376	Does not exist
Lighting Fixture - HID	
Instance on Rooms 206, 210, 301, 377, 379	Does not exist
Instance on Rooms 373 & 376	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms 206, 210, 301, 377, 379	Does not exist
Instance on Rooms 373 & 376	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Rooms 206, 210, 301, 377, 379	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 373 & 376	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
BATTERY PACK	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
BATTERY PACK	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
AREA SMOKE DETECTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
FIRE ALARM SYSTEM	
BELL/HORN	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
DUCT SMOKE DETECTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
ELEVATOR RECALL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
FAN SHUTDOWN CONTROL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
FIRE ALARM DIGITAL COMMUNICATOR	Does not exist
FUSED CUTOFF PANEL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
HEAT DETECTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MAGNETIC DOOR HOLDER CONTACTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MAIN PANEL	Inspected
Bell At Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance Lobby
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards Systems Technology
Model	MEA # 13-92-E
EquipmentId	N/A
Capacity/Size	24 Zones
Installation Year	2005
Source of Installation Year	Documented
Deficiency	PANEL ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fire Alarm Control Panel (Standard)	Does not exist
MANUAL PULL STATION	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
REMOTE ANNUNCIATOR	Inspected
Display Monitor	Does not exist
Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Printer	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
FIRE ALARM SYSTEM	
REMOTE ANNUNCIATOR	
Printer	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Punch Register	Does not exist
SPRINKLER FLOW/AIR PRESSURE SWITCH	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
STROBE	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SUB-PANEL	
Bell At Panel	Does not exist
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Boiler Room (Basement)
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
Model	N/A
EquipmentId	Door Holder Panel
Capacity/Size	12 zones
Installation Year	2005
Source of Installation Year	Estimated
Deficiency	PANEL DIRECTION/DIAGRAM IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Boiler Room (Basement)
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
Model	N/A
EquipmentId	Strobe Panel
Capacity/Size	12 Zones
Installation Year	2005
Source of Installation Year	Estimated
Deficiency	PANEL DIRECTION/DIAGRAM IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fire Alarm Control Panel (Standard)	Inspected
Instance	Boiler Room (Basement)
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Raisler Corporation
EquipmentId	Sprinkler Head

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
FIRE ALARM SYSTEM	
SUB-PANEL	
Fire Alarm Control Panel (Standard)	
Capacity/Size	1 circuit
Installation Year	1965
Source of Installation Year	Estimated
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TAMPER FLOW SWITCH/CHAIN	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	
Instance	Room 081G
Instance	1st floor
LIGHTING	
Instance on Room 081G	Inspected
Instance on 1st floor	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 081G	Does not exist
Instance on 1st floor	Does not exist
Lighting Fixture - HID	
Instance on Room 081G	Inspected
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on Room 081G	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 1st floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 081G	Does not exist
Instance on 1st floor	Does not exist
Surface Mounted	
Instance on Room 081G	Does not exist
Instance on 1st floor	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 081G	Does not exist
Instance on 1st floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on Room 081G	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
GYMNASIUM	
LOCAL SOUND SYSTEM	
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 1st floor	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SCOREBOARD	
Instance on Room 081G	Does not exist
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
THEATER LIGHTING SYSTEM	
Instance on Room 081G	Does not exist
Instance on 1st floor	Does not exist
INTERCOM SYSTEM	
	Inspected
ELEVATOR	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
HOLDING AREA	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
KITCHEN/WARMING PANTRY	
	Inspected
Instance	1st floor
LIGHTING	
Instance on 1st floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on 1st floor	Does not exist
Recessed Mounted	
Instance on 1st floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 1st floor	Inspected
Instance Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
KITCHEN/WARMING PANTRY	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st floor	Does not exist
LAN	Inspected
LOCAL DISTRIBUTION FRAME (I/LDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MAIN EQUIPMENT RACK (MDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	Room 236
Has LAN/Modem access	Yes
LIGHTING	
Instance on Room 236	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 236	Inspected
Pendant Mounted	
Instance on Room 236	Does not exist
Recessed Mounted	
Instance on Room 236	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 236	Does not exist
Lighting Fixture - HID	
Instance on Room 236	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 236	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 236	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SMART BOARD	
Instance on Room 236	Does not exist
LIGHTING - SECURITY LIGHTS	Inspected
Condition	2- Between Good and Fair
Replacement Quantity	50
Replacement Uom	EACH
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	Does not exist
LOCKER ROOM	
Instance on Rooms B081 (Girls Varsity), B083 (Boys Varsity), B79 (Girls) & B85 (Boys)	Inspected
Alternative Use	No
LIGHTING	
Instance on Rooms B081 (Girls Varsity), B083 (Boys Varsity), B79 (Girls) & B85 (Boys)	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
LOCKER ROOM	
LIGHTING	
Lighting Fixture - Fluorescent	
Instance on Rooms B081 (Girls Varsity), B083 (Boys Varsity), B79 (Girls) & B85 (Boys)	Inspected
Pendant Mounted	
Instance on Rooms B081 (Girls Varsity), B083 (Boys Varsity), B79 (Girls) & B85 (Boys)	Does not exist
Recessed Mounted	
Instance on Rooms B081 (Girls Varsity), B083 (Boys Varsity), B79 (Girls) & B85 (Boys)	Does not exist
Surface Mounted	
Instance on Rooms B081 (Girls Varsity), B083 (Boys Varsity), B79 (Girls) & B85 (Boys)	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Rooms B081 (Girls Varsity), B083 (Boys Varsity), B79 (Girls) & B85 (Boys)	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms B081 (Girls Varsity), B083 (Boys Varsity), B79 (Girls) & B85 (Boys)	Does not exist
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Kitchen Storage, Boiler Room, Fan Rooms B20, B62 & B73E
Deficiency Quantity	63
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
FUSED DISCONNECT SWITCH TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Room B073
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED KNIFE SWITCH TYPE	Does not exist
FUSED TOGGLE SWITCH TYPE	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	Inspected
Condition	2- Between Good and Fair
Deficiency	PANEL BOARD DIRECTORY MISSING OR REQUIRES UPDATING
Deficiency Location/Instance	Closet in room 171, Rooms 185, 171G & Next to room 375
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
PANEL BOARD	
MOLDED CASE CIRCUIT BREAKER TYPE	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PANEL BOARD ID IS MISSING
Deficiency Location/Instance	Fan room B62, Rooms 371T, 290, 185, 171 G, 165 and 161, Cafeteria, Closet in room 171 & Boiler Room, front of room 062, next to room 165 & In the garage.
Deficiency Quantity	17
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Fan rooms B62, B73E, B20, Rooms 371T, 290, 185, 171G, 165 and 161, Kitchen, Cafeteria, Closet in room 171, Boiler room, next to rooms 165, 375, Garage & front of rooms 062 & B48
Deficiency Quantity	26
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	Inspected
Instance	Projection Booth Room 290
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Projection Booth Room 290
Deficiency Quantity	300,000
Quantity Uom	S.F.
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SCIENCE DEMO ROOM	
Instance on Rooms 225 & 229	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 227	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Rooms 271 & 272 & 329	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 325	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
SCIENCE DEMO ROOM	
Instance on Room 327	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Rooms 371 & 372	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Rooms 225 & 229	Does not exist
Instance on Room 227	Does not exist
Instance on Rooms 271 & 272 & 329	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 325	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 327	Does not exist
Instance on Rooms 371 & 372	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
EMERGENCY SHUT-OFF POWER	
Instance on Rooms 225 & 229	Does not exist
Instance on Room 227	Does not exist
Instance on Rooms 271 & 272 & 329	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 325	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 327	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 371 & 372	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
SCIENCE DEMO ROOM	
LIGHTING	
Instance on Rooms 225 & 229	Inspected
Instance on Room 227	Inspected
Instance on Rooms 271 & 272 & 329	Inspected
Instance on Room 325	Inspected
Instance on Room 327	Inspected
Instance on Rooms 371 & 372	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms 225 & 229	Inspected
Instance on Room 227	Inspected
Instance on Rooms 271 & 272 & 329	Inspected
Instance on Room 325	Inspected
Instance on Room 327	Inspected
Instance on Rooms 371 & 372	Inspected
Pendant Mounted	
Instance on Rooms 225 & 229	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 227	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Rooms 271 & 272 & 329	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 325	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 327	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Rooms 371 & 372	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Rooms 225 & 229	Does not exist
Instance on Room 227	Does not exist
Instance on Rooms 271 & 272 & 329	Does not exist
Instance on Room 325	Does not exist
Instance on Room 327	Does not exist
Instance on Rooms 371 & 372	Does not exist
Surface Mounted	
Instance on Rooms 225 & 229	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 227	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Rooms 271 & 272 & 329	Does not exist
Instance on Room 325	Does not exist
Instance on Room 327	Does not exist
Instance on Rooms 371 & 372	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
SCIENCE DEMO ROOM	
LIGHTING	
Lighting Fixture - HID	
Instance on Rooms 225 & 229	Does not exist
Instance on Room 227	Does not exist
Instance on Rooms 271 & 272 & 329	Does not exist
Instance on Room 325	Does not exist
Instance on Room 327	Does not exist
Instance on Rooms 371 & 372	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms 225 & 229	Does not exist
Instance on Room 227	Does not exist
Instance on Rooms 271 & 272 & 329	Does not exist
Instance on Room 325	Does not exist
Instance on Room 327	Does not exist
Instance on Rooms 371 & 372	Does not exist
POWER SUPPLY	
Instance on Rooms 225 & 229	Inspected
Instance on Room 227	Inspected
Instance on Rooms 271 & 272 & 329	Inspected
Instance on Room 325	Inspected
Instance on Room 327	Inspected
Instance on Rooms 371 & 372	Inspected
Instructor Unit	
Instance on Rooms 225 & 229	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 227	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 271 & 272 & 329	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 325	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 327	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 371 & 372	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Rooms 225 & 229	Does not exist
Instance on Room 227	Does not exist
Instance on Rooms 271 & 272 & 329	Does not exist
Instance on Room 325	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 327	Does not exist
Instance on Rooms 371 & 372	Does not exist
PROJECTION SYSTEM	
Instance on Rooms 225 & 229	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
SCIENCE DEMO ROOM	
PROJECTION SYSTEM	
Deficiency	No deficiencies recorded
Instance on Room 227	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 271 & 272 & 329	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 325	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 327	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 371 & 372	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SMART BOARD	
Instance on Rooms 225 & 229	Does not exist
Instance on Room 227	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Rooms 271 & 272 & 329	Does not exist
Instance on Room 325	Does not exist
Instance on Room 327	Does not exist
Instance on Rooms 371 & 372	Does not exist
SCIENCE LAB	
Instance on Room 228	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 274	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 320	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 328	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 228	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
SCIENCE LAB	
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 274	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 320	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 328	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room 228	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 274	Does not exist
Instance on Room 320	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 328	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Room 228	Inspected
Instance on Room 274	Inspected
Instance on Room 320	Inspected
Instance on Room 328	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 228	Inspected
Instance on Room 274	Inspected
Instance on Room 320	Inspected
Instance on Room 328	Inspected
Pendant Mounted	
Instance on Room 228	Does not exist
Instance on Room 274	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
SCIENCE LAB	
LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Instance on Room 320	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 328	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 228	Does not exist
Instance on Room 274	Does not exist
Instance on Room 320	Does not exist
Instance on Room 328	Does not exist
Surface Mounted	
Instance on Room 228	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 274	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 320	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 328	Does not exist
Lighting Fixture - HID	
Instance on Room 228	Does not exist
Instance on Room 274	Does not exist
Instance on Room 320	Does not exist
Instance on Room 328	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 228	Does not exist
Instance on Room 274	Does not exist
Instance on Room 320	Does not exist
Instance on Room 328	Does not exist
POWER SUPPLY	
Instance on Room 228	Inspected
Instance on Room 274	Inspected
Instance on Room 320	Inspected
Instance on Room 328	Inspected
Instructor Unit	
Instance on Room 228	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 274	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 320	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 328	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
SCIENCE LAB	
POWER SUPPLY	
Meter Demonstration Unit	
Instance on Room 228	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 274	Does not exist
Instance on Room 320	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 328	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Student Unit	
Instance on Room 228	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 274	Does not exist
Instance on Room 320	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 328	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
PROJECTION SYSTEM	
Instance on Room 228	Does not exist
Instance on Room 274	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 320	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 328	Does not exist
SMART BOARD	
Instance on Room 228	Does not exist
Instance on Room 274	Does not exist
Instance on Room 320	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 328	Does not exist
SCIENCE PREP ROOM	
Instance on Room 226	Inspected
Has LAN/Modem access	No
Power Panel?	Yes
Alternative Use	No
Instance on Room 271P	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 324	Inspected
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	No
Instance on Room 330	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
SCIENCE PREP ROOM	
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	Yes
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 226	Does not exist
Instance on Room 271P	Does not exist
Instance on Room 324	Does not exist
Instance on Room 330	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room 226	Does not exist
Instance on Room 271P	Does not exist
Instance on Room 324	Does not exist
Instance on Room 330	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
LIGHTING	
Instance on Room 226	Inspected
Instance on Room 271P	Inspected
Instance on Room 324	Inspected
Instance on Room 330	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 226	Inspected
Instance on Room 271P	Inspected
Instance on Room 324	Inspected
Instance on Room 330	Inspected
Pendant Mounted	
Instance on Room 226	Does not exist
Instance on Room 271P	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 324	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 330	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 226	Does not exist
Instance on Room 271P	Does not exist
Instance on Room 324	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
SCIENCE PREP ROOM	
LIGHTING	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Instance on Room 330	Does not exist
Surface Mounted	
Instance on Room 226	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 271P	Does not exist
Instance on Room 324	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 330	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room 226	Does not exist
Instance on Room 271P	Does not exist
Instance on Room 324	Does not exist
Instance on Room 330	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 226	Does not exist
Instance on Room 271P	Does not exist
Instance on Room 324	Does not exist
Instance on Room 330	Does not exist
POWER SUPPLY	
Instance on Room 226	Does not exist
Instance on Room 271P	Does not exist
Instance on Room 324	Does not exist
Instance on Room 330	Inspected
Instructor Unit	
Instance on Room 330	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
SECURITY	
INTRUSION ALARM	
Central Control Panel	
Instance	Custodian's Office Room 139
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista 128B
Deficiency	PANEL NOT CONNECTED TO DOE CENTRAL STATION
Deficiency Location/Instance	Custodian's office Room 139
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REWIRE
Urgency of Action	PRIORITY 4

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
SECURITY	
INTRUSION ALARM	
Central Control Panel	
Purpose of Action	LEVEL 3
Violations	No violations recorded
Infrared Sensor	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
Panic Switch	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
Remote Annunciator	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
Siren/Strobe	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	
Condition	Does not exist
IPDVS/CCTV SYSTEM	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
SERVICE SWITCH	
Instance	Inspected
Instance Condition	Electrical Room 053
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co. Inc.
EquipmentId	Switchboard East Section A
Capacity/Size	1200 Amps
Source of Capacity/Size	Fuse Size
Installation Year	1965
Source of Installation Year	Estimated
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room 053
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co. Inc.
EquipmentId	Switchboard East Section B
Capacity/Size	1200 Amps
Source of Capacity/Size	Fuse Size
Installation Year	1965
Source of Installation Year	Estimated
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
SERVICE SWITCH	
Instance	Electrical Room 053
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co. Inc.
EquipmentId	Switchboard West
Capacity/Size	4000 Amps
Source of Capacity/Size	Nameplate
Installation Year	1965
Source of Installation Year	Estimated
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room 053
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co. Inc.
EquipmentId	N/A
Capacity/Size	1200 Amps
Source of Capacity/Size	Nameplate
Installation Year	1959
Source of Installation Year	Estimated
Deficiency	SWITCH ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room B22A
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co. Inc.
EquipmentId	Switchboard West Section A
Capacity/Size	1600 Amps
Source of Capacity/Size	Fuse Size
Installation Year	1965
Source of Installation Year	Estimated
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
SERVICE SWITCH	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room B22A
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard Co. Inc.
EquipmentId	Switchboard West Section B
Capacity/Size	1600 Amps
Source of Capacity/Size	Fuse Size
Installation Year	1965
Source of Installation Year	Estimated
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SWIMMING POOL	Does not exist
SWITCHBOARD	Inspected
Water Penetration In Electrical Room?	No
Number of Spares	12
AIR CIRCUIT BREAKER TYPE	Does not exist
FUSED DISCONNECT SWITCH TYPE	Inspected
Instance	Fan Room 073G
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard Corp.
EquipmentId	LP-PP
Capacity/Size	1200 Amps total, 2 Sections
Source of Capacity/Size	Service Switch Size
Installation Year	2006
Source of Installation Year	Estimated
Deficiency	No deficiencies recorded
Instance	Electrical Room 053
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard Corp.
EquipmentId	East Distribution "A"
Capacity/Size	1200 Amps total, 2 Sections
Source of Capacity/Size	Service Switch Fuse Size
Installation Year	2006
Source of Installation Year	Estimated
Deficiency	No deficiencies recorded
Instance	Electrical Room 053
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard Corp.
EquipmentId	East Distribution "B"
Capacity/Size	1200 Amps total, 2 Sections
Source of Capacity/Size	Service Switch Fuse Size

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

K495

Question	Response
SWITCHBOARD	
FUSED DISCONNECT SWITCH TYPE	
Installation Year	2006
Source of Installation Year	Estimated
Deficiency	No deficiencies recorded
FUSED KNIFE SWITCH TYPE	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	Inspected
Instance	Electrical Room B22A
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard Corp.
EquipmentId	Dist. SWBD West (A)
Capacity/Size	1600 Amps total, 1 Section
Source of Capacity/Size	Service Switch Fuse Size
Installation Year	2006
Source of Installation Year	Estimated
Deficiency	No deficiencies recorded
Instance	Electrical Room B22A
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard Corp.
EquipmentId	Dist. SWBD West (B)
Capacity/Size	1600 Amps total, 1 Section
Source of Capacity/Size	Service Switch Fuse Size
Installation Year	2006
Source of Installation Year	Estimated
Deficiency	No deficiencies recorded
TELEPHONE	Inspected
PBX/INTERCOM	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
STANDARD	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TOILET ROOM - STUDENT	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2010-2011

Electrical Inspection

K495

Question	Response
TOILET ROOM - STUDENT	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable System Exist?	Yes
Operational?	Yes
Master Antenna System Exist?	Yes
Operational?	No
MAIN EQUIPMENT RACK	Does not exist