

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K496

School: **SHEEPSHEAD BAY AF - BROOKLYN, 3000 AVENUE X, BROOKLYN, NY, 11235**

InspectionId	Inspection Type	Time In	Last Edited
1247098	ELECTRICAL	2009-04-23 08:35AM	2009-05-26 10:55AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Partial Electrical Systems and Components Years: 1995 Systems: Local Sound System Years: 2004

Priority Condition

No condition recorded

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Inspected
Exterior Lighting	Inspected
Condition	3- Fair
Replacement Quantity	6
Replacement Uom	EACH
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Local Sound System	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Scoreboard	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
AUDITORIUM	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	Does not exist
CAFETERIA	Does not exist
CAFETERIA/MULTIPURPOSE ROOM	Does not exist
CITY FIRE ALARM SYSTEM	Does not exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
COMPUTER LAB	Does not exist
ELECTRIC SERVICE SWITCH	Does not exist
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not exist
EMERGENCY LIGHTING	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K496

Question	Response
EXIT LIGHT	Does not exist
FIRE ALARM SYSTEM	Does not exist
GROUNDING SYSTEM	Does not exist
GYMNASIUM	Does not exist
INTERCOM SYSTEM	Does not exist
KITCHEN/WARMING PANTRY	Does not exist
LAN	Does not exist
LIBRARY	Does not exist
LIGHTING - EXTERIOR SECURITY	Does not exist
LIGHTNING PROTECTION	Does not exist
LOCKER ROOM/SHOWER ROOM	Does not exist
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Does not exist
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Does not exist
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	Does not exist
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	Does not exist
SECURITY	Does not exist
SWIMMING POOL	Does not exist
SWITCHBOARD	Does not exist
TELEPHONE	Does not exist
TOILET ROOM - STAFF	Does not exist
TOILET ROOM - STUDENT	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Does not exist