

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

**School: SOUTH SHORE HS - K, 6565 FLATLANDS AVENUE, BROOKLYN, NY, 11236**

InspectionId	Inspection Type	Time In	Last Edited
2140085	ELECTRICAL	2011-01-25 08:42AM	2011-05-09 05:50AM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Clocks in corridors Years: 2010 Systems: Telephone System under construction Years: 2011 Systems: Fluorescent lighting in rooms 361, 363, 365, 463, 465, 467, 467C Years: 2010 Systems: Fire Alarm System Years: 2009 Systems: ATS (Transfer Switch) for Fire Alarm System, Battery Charger, Battery for Emergency Generator. Years: 2009 Systems: LAN System (wireless) Years: 2008 Systems: Science LAB, Science Demo Rooms, Prep Rooms. Years: 2007-2008 Systems: Security (exterior) lighting Years: 2008 Systems: Intrusion Alarm System Years: 2009 Systems: Security CCTV System Years: 2002 - 2003 Systems: Distribution Switchboard (1st floor electrical closet) Years: 2002 Systems: Emergency & Exit light fixtures. Years: 2002 Systems: Fluorescent Lighting Years: Approximately 1996 Type of Service Below Ground

**Priority Condition**

Condition Description	Component Affected	Location Description	Person(s) Notified
Emergency Generator is not operational	Emergency Generator	Room 023	John Gallagher, Custodian

**Inspection**

Question	Response
<b>ELECTRICAL</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance	1st floor
<b>HOUSE LIGHTING</b>	
Instance on 1st floor	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st floor	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>AUDITORIUM</b>	
<b>HOUSE LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Recessed Mounted</b>	
Instance on 1st floor	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	111
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	53
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>LOCAL SOUND SYSTEM</b>	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>PROJECTION SYSTEM</b>	
Instance on 1st floor	Does not exist
<b>THEATER LIGHTING SYSTEM</b>	
Instance on 1st floor	Inspected
<b>Dimming System</b>	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	DIMMING RACK BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>AUDITORIUM</b>	
<b>THEATER LIGHTING SYSTEM</b>	
<b>Theater Lighting</b>	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	170
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>CAFETERIA</b>	
Instance	Inspected
Instance	1st floor - East
Instance	1st floor West
Instance	Room 137 Teacher's
<b>LIGHTING</b>	
Instance on 1st floor - East	Inspected
Instance on 1st floor West	Inspected
Instance on Room 137 Teacher's	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st floor - East	Inspected
Instance on 1st floor West	Inspected
Instance on Room 137 Teacher's	Inspected
<b>Pendant Mounted</b>	
Instance on 1st floor - East	Does not exist
Instance on 1st floor West	Does not exist
Instance on Room 137 Teacher's	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 1st floor - East	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on 1st floor West	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 137 Teacher's	Does not exist
<b>Surface Mounted</b>	
Instance on 1st floor - East	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 1st floor West	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LENS MISSING

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>CAFETERIA</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 137 Teacher's	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st floor - East	Does not exist
Instance on 1st floor West	Does not exist
Instance on Room 137 Teacher's	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st floor - East	Does not exist
Instance on 1st floor West	Does not exist
Instance on Room 137 Teacher's	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on 1st floor - East	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 1st floor West	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 137 Teacher's	Does not exist
<b>CITY FIRE ALARM SYSTEM</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Deficiency Quantity	140
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Inspected	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	40
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Inspected	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	
Inspected	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	110
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Does not exist	Does not exist
<b>Surface Mounted</b>	
Inspected	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	45
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Surface Mounted</b>	
Violations	No violations recorded
<b>SMART BOARD</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>COMPUTER LAB</b>	Inspected
Instance	Room 210
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room 311
Has LAN/Modem access	Yes
Power Panel?	No
<b>LIGHTING</b>	
Instance on Room 210	Inspected
Instance on Room 311	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 210	Inspected
Instance on Room 311	Inspected
<b>Pendant Mounted</b>	
Instance on Room 210	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 311	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 210	Does not exist
Instance on Room 311	Does not exist
<b>Surface Mounted</b>	
Instance on Room 210	Does not exist
Instance on Room 311	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 210	Does not exist
Instance on Room 311	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 210	Does not exist
Instance on Room 311	Does not exist
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room 210	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 311	Does not exist
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Inspected
<b>AUTOMATIC TRANSFER SWITCH (ATS)</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>EMERGENCY GENERATOR SET</b>	
<b>AUTOMATIC TRANSFER SWITCH (ATS)</b>	
Instance	Room 023
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ASCO
EquipmentId	No ID
Capacity/Size	200 Amps.
Installation Year	1970
Source of Installation Year	Documented
Deficiency	ATS ID MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Room 023
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ASCO
EquipmentId	No ID
Capacity/Size	70 Amps.
Installation Year	2009
Source of Installation Year	Documented
Deficiency	ATS ID MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>BATTERY CHARGER</b>	Inspected
Instance	Room 023
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	SENS
EquipmentId	Regulated Battery Charger
Capacity/Size	10 AmpsDC, 12 VDC
Installation Year	2009
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>DIESEL</b>	Does not exist
<b>NATURAL GAS</b>	Inspected
Instance	Room 023
Instance Condition	5- Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Onan
EquipmentId	Emergency Generator
Capacity/Size	68.675 kVA, 55 kW, 91 Amps.
Installation Year	1970
Source of Installation Year	Documented

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>EMERGENCY GENERATOR SET</b>	
<b>NATURAL GAS</b>	
Deficiency	LEAKING FUEL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	Inspected
<b>BATTERY PACK</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	Inspected
<b>BATTERY PACK</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EXIT/EMERGENCY LIGHT</b>	Does not exist
<b>FIRE ALARM SYSTEM</b>	Inspected
<b>AREA SMOKE DETECTOR</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>BELL/HORN</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>DUCT SMOKE DETECTOR</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>ELEVATOR RECALL</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>FAN SHUTDOWN CONTROL</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>FIRE ALARM DIGITAL COMMUNICATOR</b>	Does not exist
<b>FUSED CUTOFF PANEL</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>HEAT DETECTOR</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>MAGNETIC DOOR HOLDER CONTACTOR</b>	Does not exist
<b>MAIN PANEL</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	1- Good

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>MAIN PANEL</b>	
<b>Bell At Panel</b>	
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Inspected
Instance	1st floor - Main Lobby
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	GE
Model	EST-2
EquipmentId	FACP
Capacity/Size	12 zone
Installation Year	2009
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Standard)</b>	Does not exist
<b>MANUAL PULL STATION</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>REMOTE ANNUNCIATOR</b>	Inspected
<b>Display Monitor</b>	Does not exist
<b>Panel</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Printer</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Punch Register</b>	Does not exist
<b>SPRINKLER FLOW/AIR PRESSURE SWITCH</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>STROBE</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>SUB-PANEL</b>	Does not exist
<b>TAMPER FLOW SWITCH/CHAIN</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GROUNDING SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	Inspected
Instance	2nd floor - GYM "A-B"
Instance	2nd floor -GYM "C"
Instance	2nd floor - GYM "D"
<b>LIGHTING</b>	
Instance on 2nd floor - GYM "A-B"	Inspected
Instance on 2nd floor -GYM "C"	Inspected
Instance on 2nd floor - GYM "D"	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 2nd floor - GYM "A-B"	Does not exist
Instance on 2nd floor -GYM "C"	Does not exist
Instance on 2nd floor - GYM "D"	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>GYMNASIUM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - HID</b>	
Instance on 2nd floor - GYM "A-B"	Inspected
Instance on 2nd floor -GYM "C"	Inspected
Instance on 2nd floor - GYM "D"	Inspected
<b>Pendant Mounted</b>	
Instance on 2nd floor - GYM "A-B"	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on 2nd floor -GYM "C"	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd floor - GYM "D"	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on 2nd floor - GYM "A-B"	Does not exist
Instance on 2nd floor -GYM "C"	Does not exist
Instance on 2nd floor - GYM "D"	Does not exist
<b>Surface Mounted</b>	
Instance on 2nd floor - GYM "A-B"	Does not exist
Instance on 2nd floor -GYM "C"	Does not exist
Instance on 2nd floor - GYM "D"	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 2nd floor - GYM "A-B"	Does not exist
Instance on 2nd floor -GYM "C"	Does not exist
Instance on 2nd floor - GYM "D"	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on 2nd floor - GYM "A-B"	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd floor -GYM "C"	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>GYMNASIUM</b>	
<b>LOCAL SOUND SYSTEM</b>	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd floor - GYM "D"	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SCOREBOARD</b>	
Instance on 2nd floor - GYM "A-B"	Does not exist
Instance on 2nd floor -GYM "C"	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on 2nd floor - GYM "D"	Does not exist
<b>THEATER LIGHTING SYSTEM</b>	
Instance on 2nd floor - GYM "A-B"	Does not exist
Instance on 2nd floor -GYM "C"	Does not exist
Instance on 2nd floor - GYM "D"	Does not exist
<b>INTERCOM SYSTEM</b>	Inspected
<b>ELEVATOR</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>HOLDING AREA</b>	Does not exist
<b>KITCHEN/WARMING PANTRY</b>	Inspected
Instance	1st floor
<b>LIGHTING</b>	
Instance on 1st floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st floor	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on 1st floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st floor	Does not exist
<b>LAN</b>	Inspected
<b>LOCAL DISTRIBUTION FRAME (I/LDF)</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>MAIN EQUIPMENT RACK (MDF)</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>LIBRARY</b>	Inspected
Instance	Room 280
Has LAN/Modem access	Yes
<b>LIGHTING</b>	
Instance on Room 280	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 280	Inspected
<b>Pendant Mounted</b>	
Instance on Room 280	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 280	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on Room 280	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on Room 280	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 280	Inspected
<b>Pendant Mounted</b>	
Instance on Room 280	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 280	Does not exist
<b>Surface Mounted</b>	
Instance on Room 280	Does not exist
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room 280	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>SMART BOARD</b>	
Instance on Room 280	Does not exist
<b>LIGHTING - SECURITY LIGHTS</b>	Inaccessible
<b>LIGHTNING PROTECTION</b>	Does not exist
<b>LOCKER ROOM</b>	
Instance on Room 116 - Girls	Inspected
Alternative Use	Yes
Instance on 1st floor - Boys Locker Room	Inspected
Alternative Use	No
<b>LIGHTING</b>	
Instance on Room 116 - Girls	Inspected
Instance on 1st floor - Boys Locker Room	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 116 - Girls	Inspected
Instance on 1st floor - Boys Locker Room	Inspected
<b>Pendant Mounted</b>	
Instance on Room 116 - Girls	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE LENS MISSING

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>LOCKER ROOM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Deficiency Quantity	45
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 1st floor - Boys Locker Room	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	47
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	78
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 116 - Girls	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	49
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 1st floor - Boys Locker Room	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on Room 116 - Girls	Does not exist
Instance on 1st floor - Boys Locker Room	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>LOCKER ROOM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	13
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
Instance on Room 116 - Girls	Does not exist
Instance on 1st floor - Boys Locker Room	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 116 - Girls	Inspected
Instance on 1st floor - Boys Locker Room	Does not exist
<b>Pendant Mounted</b>	
Instance on Room 116 - Girls	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 116 - Girls	Does not exist
<b>Surface Mounted</b>	
Instance on Room 116 - Girls	Inspected
Instance Condition	5- Poor
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	24
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER NOT OPERATIONAL
Deficiency Location/Instance	Kitchen FAN room - HV- No12, FAN room 479 - Exh. No 28, 58, 56, 59. FAN room 288 - TE Exh. No 14, Gen. Exh. No 15, HV No 15.
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MULTIPURPOSE ROOM</b>	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>FUSED DISCONNECT SWITCH TYPE</b>	Does not exist
<b>FUSED KNIFE SWITCH TYPE</b>	Does not exist
<b>FUSED TOGGLE SWITCH TYPE</b>	Does not exist
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>PANEL BOARD</b>	
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	
Condition	3- Fair
Deficiency	CIRCUIT BREAKER NOT OPERATIONAL
Deficiency Location/Instance	Corridors
Deficiency Quantity	35
Quantity Uom	EACH
Potential Action	REPLACE CIRCUIT BREAKER
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>PUBLIC ADDRESS SYSTEM</b>	
Instance	Room 105
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Commercial Radio Sound Corp.
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Room 105
Deficiency Quantity	404,000
Quantity Uom	S.F.
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SCIENCE DEMO ROOM</b>	
Instance on Room 321	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 323	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 332	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 340	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 342	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 329	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 421	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
Instance on Room 423	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 432	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 437	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 439.	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 440	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 441	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 429	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Room 321	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 323	Inspected
Instance Condition	1- Good
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 332	Inspected
Instance Condition	1- Good
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 340	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Room 342	Inspected
Instance Condition	1- Good
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 329	Inspected
Instance Condition	1- Good
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 421	Inspected
Instance Condition	1- Good
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 423	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 432	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 437	Inspected
Instance Condition	1- Good
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 439.	Inspected
Instance Condition	1- Good
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 440	Inspected
Instance Condition	1- Good
Deficiency	NOT IN USE

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 441	Inspected
Instance Condition	1- Good
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 429	Inspected
Instance Condition	1- Good
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>EMERGENCY SHUT-OFF POWER</b>	
Instance on Room 321	Does not exist
Instance on Room 323	Does not exist
Instance on Room 332	Does not exist
Instance on Room 340	Does not exist
Instance on Room 342	Inspected
Instance Condition	1- Good
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 329	Does not exist
Instance on Room 421	Inspected
Instance Condition	1- Good
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 423	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 432	Does not exist
Instance on Room 437	Does not exist
Instance on Room 439.	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>EMERGENCY SHUT-OFF POWER</b>	
Instance on Room 440	Does not exist
Instance on Room 441	Does not exist
Instance on Room 429	Does not exist
<b>LIGHTING</b>	
Instance on Room 321	Inspected
Instance on Room 323	Inspected
Instance on Room 332	Inspected
Instance on Room 340	Inspected
Instance on Room 342	Inspected
Instance on Room 329	Inspected
Instance on Room 421	Inspected
Instance on Room 423	Inspected
Instance on Room 432	Inspected
Instance on Room 437	Inspected
Instance on Room 439.	Inspected
Instance on Room 440	Inspected
Instance on Room 441	Inspected
Instance on Room 429	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 321	Inspected
Instance on Room 323	Inspected
Instance on Room 332	Inspected
Instance on Room 340	Inspected
Instance on Room 342	Inspected
Instance on Room 329	Inspected
Instance on Room 421	Inspected
Instance on Room 423	Inspected
Instance on Room 432	Inspected
Instance on Room 437	Inspected
Instance on Room 439.	Inspected
Instance on Room 440	Inspected
Instance on Room 441	Inspected
Instance on Room 429	Inspected
<b>Pendant Mounted</b>	
Instance on Room 321	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	44
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 323	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Instance on Room 332	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	40
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 340	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 342	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 329	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 421	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 423	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 432	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	44
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 437	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 439.	Inspected
Instance Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	44
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 440	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 441	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 429	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 321	Does not exist
Instance on Room 323	Does not exist
Instance on Room 332	Does not exist
Instance on Room 340	Does not exist
Instance on Room 342	Does not exist
Instance on Room 329	Does not exist
Instance on Room 421	Does not exist
Instance on Room 423	Does not exist
Instance on Room 432	Does not exist
Instance on Room 437	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 439.	Does not exist
Instance on Room 440	Does not exist
Instance on Room 441	Does not exist
Instance on Room 429	Does not exist
<b>Surface Mounted</b>	
Instance on Room 321	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 323	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 332	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	1
Quantity Uom	EACH

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 340	Does not exist
Instance on Room 342	Does not exist
Instance on Room 329	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 421	Does not exist
Instance on Room 423	Does not exist
Instance on Room 432	Does not exist
Instance on Room 437	Does not exist
Instance on Room 439.	Does not exist
Instance on Room 440	Does not exist
Instance on Room 441	Does not exist
Instance on Room 429	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 321	Does not exist
Instance on Room 323	Does not exist
Instance on Room 332	Does not exist
Instance on Room 340	Does not exist
Instance on Room 342	Does not exist
Instance on Room 329	Does not exist
Instance on Room 421	Does not exist
Instance on Room 423	Does not exist
Instance on Room 432	Does not exist
Instance on Room 437	Does not exist
Instance on Room 439.	Does not exist
Instance on Room 440	Does not exist
Instance on Room 441	Does not exist
Instance on Room 429	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 321	Inspected
Instance on Room 323	Inspected
Instance on Room 332	Does not exist
Instance on Room 340	Inspected
Instance on Room 342	Inspected
Instance on Room 329	Inspected
Instance on Room 421	Inspected
Instance on Room 423	Inspected
Instance on Room 432	Does not exist
Instance on Room 437	Does not exist
Instance on Room 439.	Inspected
Instance on Room 440	Inspected
Instance on Room 441	Inspected
Instance on Room 429	Inspected
<b>Pendant Mounted</b>	
Instance on Room 321	Inspected
Instance Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Pendant Mounted</b>	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 323	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 340	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 342	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 329	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 421	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

Question	Response
<b>SCIENCE DEMO ROOM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Pendant Mounted</b>	
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 423	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 439.	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 440	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 441	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 429	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Pendant Mounted</b>	
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 321	Does not exist
Instance on Room 323	Does not exist
Instance on Room 340	Does not exist
Instance on Room 342	Does not exist
Instance on Room 329	Does not exist
Instance on Room 421	Does not exist
Instance on Room 423	Does not exist
Instance on Room 439.	Does not exist
Instance on Room 440	Does not exist
Instance on Room 441	Does not exist
Instance on Room 429	Does not exist
<b>Surface Mounted</b>	
Instance on Room 321	Does not exist
Instance on Room 323	Does not exist
Instance on Room 340	Does not exist
Instance on Room 342	Does not exist
Instance on Room 329	Does not exist
Instance on Room 421	Does not exist
Instance on Room 423	Does not exist
Instance on Room 439.	Does not exist
Instance on Room 440	Does not exist
Instance on Room 441	Does not exist
Instance on Room 429	Does not exist
<b>POWER SUPPLY</b>	
Instance on Room 321	Inspected
Instance on Room 323	Inspected
Instance on Room 332	Inspected
Instance on Room 340	Inspected
Instance on Room 342	Inspected
Instance on Room 329	Inspected
Instance on Room 421	Inspected
Instance on Room 423	Inspected
Instance on Room 432	Inspected
Instance on Room 437	Inspected
Instance on Room 439.	Inspected
Instance on Room 440	Inspected
Instance on Room 441	Inspected
Instance on Room 429	Inspected
<b>Instructor Unit</b>	
Instance on Room 321	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 323	Inspected
Instance Condition	1- Good
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>POWER SUPPLY</b>	
<b>Instructor Unit</b>	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 332	Inspected
Instance Condition	1- Good
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 340	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 342	Inspected
Instance Condition	1- Good
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 329	Inspected
Instance Condition	1- Good
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 421	Inspected
Instance Condition	1- Good
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 423	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 432	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 437	Inspected
Instance Condition	1- Good
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>POWER SUPPLY</b>	
<b>Instructor Unit</b>	
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 439.	Inspected
Instance Condition	1- Good
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 440	Inspected
Instance Condition	1- Good
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 441	Inspected
Instance Condition	1- Good
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 429	Inspected
Instance Condition	1- Good
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>Meter Demonstration Unit</b>	
Instance on Room 321	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 323	Inspected
Instance Condition	1- Good
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>POWER SUPPLY</b>	
<b>Meter Demonstration Unit</b>	
Instance on Room 332	Inspected
Instance Condition	1- Good
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 340	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 342	Inspected
Instance Condition	1- Good
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 329	Inspected
Instance Condition	1- Good
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 421	Inspected
Instance Condition	1- Good
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 423	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 432	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 437	Inspected
Instance Condition	1- Good
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>POWER SUPPLY</b>	
<b>Meter Demonstration Unit</b>	
Violations	No violations recorded
Instance on Room 439.	Inspected
Instance Condition	1- Good
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 440	Inspected
Instance Condition	1- Good
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 441	Inspected
Instance Condition	1- Good
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 429	Inspected
Instance Condition	1- Good
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>PROJECTION SYSTEM</b>	
Instance on Room 321	Does not exist
Instance on Room 323	Does not exist
Instance on Room 332	Does not exist
Instance on Room 340	Does not exist
Instance on Room 342	Does not exist
Instance on Room 329	Does not exist
Instance on Room 421	Does not exist
Instance on Room 423	Does not exist
Instance on Room 432	Does not exist
Instance on Room 437	Does not exist
Instance on Room 439.	Does not exist
Instance on Room 440	Does not exist
Instance on Room 441	Does not exist
Instance on Room 429	Does not exist
<b>SMART BOARD</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>SMART BOARD</b>	
Instance on Room 321	Does not exist
Instance on Room 323	Does not exist
Instance on Room 332	Does not exist
Instance on Room 340	Does not exist
Instance on Room 342	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 329	Does not exist
Instance on Room 421	Does not exist
Instance on Room 423	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 432	Does not exist
Instance on Room 437	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 439.	Does not exist
Instance on Room 440	Does not exist
Instance on Room 441	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 429	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>SCIENCE LAB</b>	
Instance on Room 326, 330, 427, 430.	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 327	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Room 326, 330, 427, 430.	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 327	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>EMERGENCY SHUT-OFF POWER</b>	
Instance on Room 326, 330, 427, 430.	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 327	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>LIGHTING</b>	
Instance on Room 326, 330, 427, 430.	Inspected
Instance on Room 327	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 326, 330, 427, 430.	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

Question	Response
<b>SCIENCE LAB</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 327	Inspected
<b>Pendant Mounted</b>	
Instance on Room 326, 330, 427, 430.	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 327	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 326, 330, 427, 430.	Does not exist
Instance on Room 327	Does not exist
<b>Surface Mounted</b>	
Instance on Room 326, 330, 427, 430.	Does not exist
Instance on Room 327	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on Room 326, 330, 427, 430.	Does not exist
Instance on Room 327	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 326, 330, 427, 430.	Inspected
Instance on Room 327	Inspected
<b>Pendant Mounted</b>	
Instance on Room 326, 330, 427, 430.	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 327	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 326, 330, 427, 430.	Does not exist
Instance on Room 327	Does not exist
<b>Surface Mounted</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

Question	Response
<b>SCIENCE LAB</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Surface Mounted</b>	
Instance on Room 326, 330, 427, 430.	Does not exist
Instance on Room 327	Does not exist
<b>POWER SUPPLY</b>	
Instance on Room 326, 330, 427, 430.	Inspected
Instance on Room 327	Inspected
<b>Instructor Unit</b>	
Instance on Room 326, 330, 427, 430.	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 327	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Meter Demonstration Unit</b>	
Instance on Room 326, 330, 427, 430.	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 327	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Student Unit</b>	
Instance on Room 326, 330, 427, 430.	Does not exist
Instance on Room 327	Does not exist
<b>PROJECTION SYSTEM</b>	
Instance on Room 326, 330, 427, 430.	Does not exist
Instance on Room 327	Does not exist
<b>SMART BOARD</b>	
Instance on Room 326, 330, 427, 430.	Does not exist
Instance on Room 327	Does not exist
<b>SCIENCE PREP ROOM</b>	
Instance on Room 337	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 333, 433	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 335	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Room 337	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 333, 433	Inspected
Instance Condition	1- Good
Deficiency	NOT IN USE
Deficiency Quantity	2
Quantity Uom	EACH

NYC Department of Education  
 Building Condition Assessment Survey 2010-2011

*Electrical Inspection*

K515

Question	Response
<b>SCIENCE PREP ROOM</b>	
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 335	Does not exist
<b>EMERGENCY SHUT-OFF POWER</b>	
Instance on Room 337	Does not exist
Instance on Room 333, 433	Does not exist
Instance on Room 335	Does not exist
<b>LIGHTING</b>	
Instance on Room 337	Inspected
Instance on Room 333, 433	Inspected
Instance on Room 335	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 337	Inspected
Instance on Room 333, 433	Inspected
Instance on Room 335	Inspected
<b>Pendant Mounted</b>	
Instance on Room 337	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 333, 433	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 335	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 337	Does not exist
Instance on Room 333, 433	Does not exist
Instance on Room 335	Does not exist
<b>Surface Mounted</b>	
Instance on Room 337	Does not exist
Instance on Room 333, 433	Does not exist
Instance on Room 335	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 337	Does not exist
Instance on Room 333, 433	Does not exist
Instance on Room 335	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 337	Does not exist
Instance on Room 333, 433	Does not exist
Instance on Room 335	Does not exist
<b>POWER SUPPLY</b>	
Instance on Room 337	Does not exist
Instance on Room 333, 433	Does not exist
Instance on Room 335	Inspected
<b>Instructor Unit</b>	
Instance on Room 335	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>SCIENCE PREP ROOM</b>	
<b>POWER SUPPLY</b>	
<b>Instructor Unit</b>	
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>SECURITY</b>	Inspected
<b>INTRUSION ALARM</b>	Inspected
<b>Central Control Panel</b>	Inspected
Instance	Room 182
Instance Condition	5- Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista 128B
Deficiency	PANEL NOT OPERATIONAL
Deficiency Location/Instance	Room 182
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
<b>Infrared Sensor</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	Inaccessible
<b>Ultrasonic Sensor</b>	Does not exist
<b>IPDVS/CCTV SYSTEM</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>SERVICE SWITCH</b>	Inspected
Instance	Room 021
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific
EquipmentId	Main Switch
Capacity/Size	4000 Amps.
Source of Capacity/Size	Nameplate
Installation Year	1970
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Room 021
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific
EquipmentId	Main BPS

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>SERVICE SWITCH</b>	
Capacity/Size	4000 Amps.
Source of Capacity/Size	Nameplate
Installation Year	1970
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Room 021
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific
EquipmentId	Sub Distr. BD #1
Capacity/Size	3000 Amps/ 2500 Amps fuses.
Source of Capacity/Size	Nameplate
Installation Year	1970
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Room 021
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific
EquipmentId	Sub Distr. BD #2
Capacity/Size	3000 Amps/2500 fuses
Source of Capacity/Size	Nameplate
Installation Year	1970
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Room 021
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific
EquipmentId	Kitchen Distr. Panel
Capacity/Size	600 Amps.
Source of Capacity/Size	Nameplate
Installation Year	1970
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>SWIMMING POOL</b>	Does not exist
<b>SWITCHBOARD</b>	Inspected
Water Penetration In Electrical Room?	No
Number of Spares	1
<b>AIR CIRCUIT BREAKER TYPE</b>	Does not exist
<b>FUSED DISCONNECT SWITCH TYPE</b>	Inspected
Instance	Room 021
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific
EquipmentId	Main Distr. BD #1
Capacity/Size	2500 Amps total, 2 sections
Source of Capacity/Size	Service Switch Fuse Size
Installation Year	1970
Source of Installation Year	Documented
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>SWITCHBOARD</b>	
<b>FUSED DISCONNECT SWITCH TYPE</b>	
Instance	Room 021
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific
EquipmentId	Main Distr. BD #2
Capacity/Size	2500 Amps total, 3 sections
Source of Capacity/Size	Service Switch Fuse Size
Installation Year	1970
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Room 182
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific
EquipmentId	No ID
Capacity/Size	4000 Amps total, 3 sections
Source of Capacity/Size	Service Switch Size
Installation Year	1970
Source of Installation Year	Documented
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical closet next to room 158
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Electrotech
EquipmentId	No ID
Capacity/Size	4000 Amps total, 3 sections
Source of Capacity/Size	Service Switch Size
Installation Year	2002
Source of Installation Year	Documented
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**K515**

<b>Question</b>	<b>Response</b>
<b>SWITCHBOARD</b>	
<b>FUSED DISCONNECT SWITCH TYPE</b>	
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Room 021
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific
EquipmentId	Kitchen Distr. Panel
Capacity/Size	600 Amps total, 1 section.
Source of Capacity/Size	Switchboard Mains Size
Installation Year	1970
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>FUSED KNIFE SWITCH TYPE</b>	Does not exist
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	Does not exist
<b>TELEPHONE</b>	Under construction
<b>TOILET ROOM - STAFF</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TRANSFORMER</b>	Does not exist
<b>TV SYSTEM</b>	Inspected
Cable System Exist?	Yes
Operational?	Yes
Master Antenna System Exist?	Yes
Operational?	No
<b>MAIN EQUIPMENT RACK</b>	Does not exist