

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K805

School: SCIENCE SKILLS CENTER HS - K, 49 FLATBUSH AVENUE EXT., BROOKLYN, NY, 11201

InspectionId	Inspection Type	Time In	Last Edited
1254150	ELECTRICAL	2009-05-18 12:09PM	2009-05-27 02:48PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Emergency Generator Set Years: Under Construction Systems: All Electrical equipments on 7th and 8th Floors, Telephone System Years: 2005 Systems: Panel Boards, Partial Switchboards, Main Service Switch, Lighting, Intrusion Alarm System, Fire Alarm System, PA System, Local Sound System Years: 1995 Systems: Security Cameras, LAN Years: 1998 Systems: Exit Lights(battery pack) Years: 2008 Systems: Motor Control Center Years: 1980's

Priority Condition

No condition recorded

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	Does not exist
CAFETERIA	Inspected
Instance	Third Floor
Instance	Seventh Floor
Instance	Basement
Lighting	
Instance on Third Floor	Inspected
Instance on Seventh Floor	Inspected
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Third Floor	Inspected
Instance on Seventh Floor	Inspected
Instance on Basement	Inspected
Pendant Mounted	
Instance on Third Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Seventh Floor	Does not exist
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Third Floor	Does not exist
Instance on Seventh Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Basement	Does not exist
Surface Mounted	

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K805

Question	Response
CAFETERIA	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Instance on Third Floor	Does not exist
Instance on Seventh Floor	Does not exist
Instance on Basement	Does not exist
Lighting Fixture - HID	
Instance on Third Floor	Does not exist
Instance on Seventh Floor	Does not exist
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Third Floor	Does not exist
Instance on Seventh Floor	Does not exist
Instance on Basement	Does not exist
Local Sound System	
Instance on Third Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Seventh Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA/MULTIPURPOSE ROOM	Does not exist
CITY FIRE ALARM SYSTEM	Inspected
Condition	5- Poor
Deficiency	NOT OPERATIONAL
Deficiency Location/Instance	1st Floor
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	10

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K805

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
COMPUTER LAB	Inspected
Instance	Room 208, 303, 506
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room 611
Has LAN/Modem access	No
Power Panel?	Yes
Lighting	
Instance on Room 208, 303, 506	Inspected
Instance on Room 611	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 208, 303, 506	Inspected
Instance on Room 611	Inspected
Pendant Mounted	
Instance on Room 208, 303, 506	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 611	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K805

Question	Response
COMPUTER LAB	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Instance on Room 208, 303, 506	Does not exist
Instance on Room 611	Does not exist
Surface Mounted	
Instance on Room 208, 303, 506	Does not exist
Instance on Room 611	Does not exist
Lighting Fixture - HID	
Instance on Room 208, 303, 506	Does not exist
Instance on Room 611	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 208, 303, 506	Does not exist
Instance on Room 611	Does not exist
Raceway With Receptacles	
Instance on Room 208, 303, 506	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 611	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
ELECTRIC SERVICE SWITCH	Inspected
Instance	Electrical Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard
Model	All City Switchboard
EquipmentId	Main Service Switch
Capacity/Size	4000 Amps
Installation Year	1995
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Under construction
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Connected To Emergency Generator System	Under construction
Connected To Emergency Light/Exit Light Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Relay Test Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Connected To Emergency Generator System	Under construction

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K805

Question	Response
EXIT LIGHT	
Connected To Emergency Light/Exit Light Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
FIRE ALARM SYSTEM	Inspected
Replacement Quantity	173,000
Replacement Uom	S.F.
Area Smoke Detector	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Bell/Horn	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Duct Smoke Detector	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Elevator Recall	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not exist
Fused Cutout Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Heat Detector	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Magnetic Door Holder Contactor	Inspected
Condition	4- Between Fair and Poor
Deficiency	CONTACTOR NOT OPERATIONAL
Deficiency Location/Instance	Corridors
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Main Panel	Inspected
Bell At Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Room 101
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards
Model	CM1
EquipmentId	Fire Alarm Control
Capacity/Size	24 zones
Installation Year	1995
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K805

Question	Response
FIRE ALARM SYSTEM	
Manual Pull Station	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Display Monitor	Does not exist
Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	5- Poor
Deficiency	PRINTER NOT OPERATIONAL
Deficiency Location/Instance	Custodian Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Punch Register	Does not exist
Sprinkler Flow/Air Pressure Switch	Does not exist
Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Sub-Panel	Does not exist
Tamper Flow Switch/Chain	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	Inspected
Instance	Room 109
Lighting	
Instance on Room 109	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 109	Does not exist
Lighting Fixture - HID	
Instance on Room 109	Inspected
Pendant Mounted	
Instance on Room 109	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room 109	Does not exist
Surface Mounted	
Instance on Room 109	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 109	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K805

Question	Response
GYMNASIUM	
Local Sound System	
Instance on Room 109	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Scoreboard	
Instance on Room 109	Does not exist
Theater Lighting System	
Instance on Room 109	Does not exist
INTERCOM SYSTEM	
Elevator	
Condition	3- Fair
Deficiency	No deficiencies recorded
Holding Area	
	Does not exist
KITCHEN/WARMING PANTRY	
Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	
	Does not exist
Recessed Mounted	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
	Does not exist
Lighting Fixture - HID	
	Does not exist
Lighting Fixture - Incandescent	
	Does not exist
LAN	
	Inspected
Local Distribution Frame (I/LDF)	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIBRARY	
Instance	Room 302, 606
Has LAN/Modem access	Yes
Lighting	
Instance on Room 302, 606	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 302, 606	Inspected
Pendant Mounted	
Instance on Room 302, 606	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 302, 606	Does not exist
Surface Mounted	
Instance on Room 302, 606	Does not exist
Lighting Fixture - HID	
Instance on Room 302, 606	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 302, 606	Does not exist
Raceway With Receptacles	
Instance on Room 302, 606	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K805

Question	Response
LIGHTING - EXTERIOR SECURITY	Inspected
Condition	3- Fair
Replacement Quantity	4
Replacement Uom	EACH
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Building Perimeter
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 3
Violations	No violations recorded
LIGHTNING PROTECTION	Does not exist
LOCKER ROOM/SHOWER ROOM	Inspected
Instance	First Floor - Boys, Girls (shower only)
Alternative Use	Yes
Instance	Basement - Boys, Girls and First Floor - Girls (locker only)
Alternative Use	No
Lighting	
Instance on First Floor - Boys, Girls (shower only)	Not required
Instance on Basement - Boys, Girls and First Floor - Girls (locker only)	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement - Boys, Girls and First Floor - Girls (locker only)	Inspected
Pendant Mounted	
Instance on Basement - Boys, Girls and First Floor - Girls (locker only)	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Basement - Boys, Girls and First Floor - Girls (locker only)	Does not exist
Surface Mounted	
Instance on Basement - Boys, Girls and First Floor - Girls (locker only)	Does not exist
Lighting Fixture - HID	
Instance on Basement - Boys, Girls and First Floor - Girls (locker only)	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement - Boys, Girls and First Floor - Girls (locker only)	Does not exist
MOTOR CONTROL CENTER	Inspected
Instance	Next to Custodian Office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Westinghouse
EquipmentId	N/A
Capacity/Size	600 Amps, 4 sections
Installation Year	1980
Deficiency	MCC ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K805

Question	Response
MULTIPURPOSE ROOM	Inspected
Instance	Room B13/B15
Lighting	
Instance on Room B13/B15	Inspected
Lighting Fixture - Fluorescent	
Instance on Room B13/B15	Does not exist
Lighting Fixture - HID	
Instance on Room B13/B15	Inspected
Pendant Mounted	
Instance on Room B13/B15	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room B13/B15	Does not exist
Surface Mounted	
Instance on Room B13/B15	Does not exist
Lighting Fixture - Incandescent	
Instance on Room B13/B15	Does not exist
Local Sound System	
Instance on Room B13/B15	Does not exist
Theater Lighting System	
Instance on Room B13/B15	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Electrical Room, Boiler Room
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fused Toggle Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	Inspected
Replacement Quantity	173,000
Replacement Uom	S.F.
Instance	1st Floor-Communication Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Rauland TC2100
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K805

Question	Response
SCIENCE DEMO ROOM	Inspected
Instance	Room 204
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	Room 401,416
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on Room 204	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 401,416	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 204	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 401,416	Does not exist
Lighting	
Instance on Room 204	Inspected
Instance on Room 401,416	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 204	Inspected
Instance on Room 401,416	Inspected
Pendant Mounted	
Instance on Room 204	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 401,416	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 204	Does not exist
Instance on Room 401,416	Does not exist
Surface Mounted	
Instance on Room 204	Does not exist
Instance on Room 401,416	Does not exist
Lighting Fixture - HID	
Instance on Room 204	Does not exist
Instance on Room 401,416	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 204	Does not exist
Instance on Room 401,416	Does not exist
Power Supply	
Instance on Room 204	Inspected
Instance on Room 401,416	Inspected
Instructor Unit	
Instance on Room 204	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 401,416	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K805

Question	Response
SCIENCE DEMO ROOM	
Power Supply	
Instructor Unit	
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 204	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 401,416	Does not exist
SCIENCE LAB	Inspected
Instance	Room 202,404,410
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance	Room 607,617
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance	Room 817,819
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance	Room 509
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance	Room 511
Has LAN/Modem access	No
Power Panel?	Yes
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on Room 202,404,410	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 607,617	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 817,819	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 509	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 511	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 202,404,410	Does not exist
Instance on Room 607,617	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 817,819	Inspected
Instance Condition	1- Good

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K805

Question	Response
SCIENCE LAB	
Emergency Shut-Off Power	
Deficiency	No deficiencies recorded
Instance on Room 509	Does not exist
Instance on Room 511	Does not exist
Lighting	
Instance on Room 202,404,410	Inspected
Instance on Room 607,617	Inspected
Instance on Room 817,819	Inspected
Instance on Room 509	Inspected
Instance on Room 511	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 202,404,410	Inspected
Instance on Room 607,617	Inspected
Instance on Room 817,819	Inspected
Instance on Room 509	Inspected
Instance on Room 511	Inspected
Pendant Mounted	
Instance on Room 202,404,410	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 607,617	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 817,819	Does not exist
Instance on Room 509	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 511	Does not exist
Recessed Mounted	
Instance on Room 202,404,410	Does not exist
Instance on Room 607,617	Does not exist
Instance on Room 817,819	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 509	Does not exist
Instance on Room 511	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 202,404,410	Does not exist
Instance on Room 607,617	Does not exist
Instance on Room 817,819	Does not exist
Instance on Room 509	Does not exist
Instance on Room 511	Does not exist
Lighting Fixture - HID	
Instance on Room 202,404,410	Does not exist
Instance on Room 607,617	Does not exist
Instance on Room 817,819	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K805

Question	Response
SCIENCE LAB	
Lighting	
Lighting Fixture - HID	
Instance on Room 509	Does not exist
Instance on Room 511	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 202,404,410	Does not exist
Instance on Room 607,617	Does not exist
Instance on Room 817,819	Does not exist
Instance on Room 509	Does not exist
Instance on Room 511	Does not exist
Power Supply	
Instance on Room 202,404,410	Inspected
Instance on Room 607,617	Inspected
Instance on Room 817,819	Inspected
Instance on Room 509	Inspected
Instance on Room 511	Inspected
Instructor Unit	
Instance on Room 202,404,410	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 607,617	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 817,819	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 509	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 511	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 202,404,410	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 607,617	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 817,819	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 509	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 511	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Student Unit	
Instance on Room 202,404,410	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 607,617	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K805

Question	Response
SCIENCE LAB	
Power Supply	
Student Unit	
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 817,819	Does not exist
Instance on Room 509	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 511	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SCIENCE PREP ROOM	
Instance	Inspected
Has LAN/Modem access	Room 408
Power Panel?	No
Alternative Use	No
Instance	Room 821
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on Room 408	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 821	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 408	Does not exist
Instance on Room 821	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Lighting	
Instance on Room 408	Inspected
Instance on Room 821	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 408	Inspected
Instance on Room 821	Inspected
Pendant Mounted	
Instance on Room 408	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 821	Does not exist
Recessed Mounted	
Instance on Room 408	Does not exist
Instance on Room 821	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 408	Does not exist
Instance on Room 821	Does not exist
Lighting Fixture - HID	
Instance on Room 408	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K805

Question	Response
SCIENCE PREP ROOM	
Lighting	
Lighting Fixture - HID	
Instance on Room 821	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 408	Does not exist
Instance on Room 821	Does not exist
Power Supply	
Instance on Room 408	Inspected
Instance on Room 821	Does not exist
Instructor Unit	
Instance on Room 408	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SECURITY	
	Inspected
Replacement Quantity	173,000
Replacement Uom	S.F.
Intrusion Alarm	
	Inspected
Central Control Panel	
	Inspected
Instance	Custodian Office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Ademco Vista-50P
Deficiency	No deficiencies recorded
Infrared Sensor	
	Inspected
Condition	3- Fair
Deficiency	SENSOR POORLY MOUNTED
Deficiency Location/Instance	Room 404
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
Panic Switch	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	
	Does not exist
IPDVS/CCTV System	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SWIMMING POOL	
	Does not exist
SWITCHBOARD	
	Inspected
Air Circuit Breaker Type	
	Does not exist
Fused Disconnect Switch Type	
	Inspected
Instance	Room 804
Instance Condition	1- Good

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K805

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Siemens
EquipmentId	MDB-8
Capacity/Size	N/A, 2 sections
Installation Year	2005
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Near bathroom #628
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Siemens
EquipmentId	DP-6
Capacity/Size	800 Amps total, 1 section
Installation Year	1995
Deficiency	No deficiencies recorded
Instance	Near bathroom #226
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Siemens
EquipmentId	DP-2
Capacity/Size	800 Amps total, 1 section
Installation Year	1995
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Siemens
EquipmentId	DP-B
Capacity/Size	800 Amps total, 1 section
Installation Year	1995
Deficiency	No deficiencies recorded
Instance	Electrical Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard
EquipmentId	N/A
Capacity/Size	4000 Amps total, 4 sections
Installation Year	1995
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

K805

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Electrotech
EquipmentId	N/A
Capacity/Size	1600 Amps total, 1 section
Installation Year	2005
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Does not exist
TELEPHONE	Inspected
PBX/Intercom	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2008-2009

Electrical Inspection

K805

Question	Response
TOILET ROOM - STUDENT	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Does not exist