

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**M060**

School: **J.H.S. 60 - MANHATTAN, 420 EAST 12 STREET, MANHATTAN, NY, 10009**

InspectionId	Inspection Type	Time In	Last Edited
1181070	ELECTRICAL	2009-02-26 09:01AM	2009-07-10 11:29AM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: PA SYSTEM,LOCAL SOUND SYSTEMS,BELL SYSTEM Years: UNDER CONSTRUCTION Systems: ELEVATOR Years: 2003 Systems: INTERCOM/PBX Years: 2005 Systems: PARTIAL EXTERIOR SECURITY LTS Years: 2008

**Priority Condition**

No condition recorded

**Inspection**

Question	Response
<b>ELECTRICAL</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance	BASEMENT
<b>House Lighting</b>	
Instance on BASEMENT	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on BASEMENT	Inspected
<b>Pendant Mounted</b>	
Instance on BASEMENT	Does not exist
<b>Recessed Mounted</b>	
Instance on BASEMENT	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	34
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on BASEMENT	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on BASEMENT	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on BASEMENT	Inspected
<b>Pendant Mounted</b>	
Instance on BASEMENT	Does not exist
<b>Recessed Mounted</b>	
Instance on BASEMENT	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	42
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**M060**

<b>Question</b>	<b>Response</b>
<b>AUDITORIUM</b>	
<b>House Lighting</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Recessed Mounted</b>	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on BASEMENT	Does not exist
<b>Local Sound System</b>	
Instance on BASEMENT	Under construction
<b>Projection System</b>	
Instance on BASEMENT	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Theater Lighting System</b>	
Instance on BASEMENT	Inspected
<b>Dimming System</b>	
Instance on BASEMENT	Inspected
Instance Condition	3- Fair
Deficiency	DIMMING RACK BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Theater Lighting</b>	
Instance on BASEMENT	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	55
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	
	Under construction
<b>CAFETERIA</b>	
	Does not exist
<b>CAFETERIA/MULTIPURPOSE ROOM</b>	
Instance	Inspected
	1ST FLOOR
<b>Lighting</b>	
Instance on 1ST FLOOR	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1ST FLOOR	Inspected
<b>Pendant Mounted</b>	
Instance on 1ST FLOOR	Does not exist
<b>Recessed Mounted</b>	
Instance on 1ST FLOOR	Does not exist
<b>Surface Mounted</b>	
Instance on 1ST FLOOR	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**M060**

Question	Response
<b>CAFETERIA/MULTIPURPOSE ROOM</b>	
<b>Lighting</b>	
<b>Lighting Fixture - HID</b>	
Instance on 1ST FLOOR	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1ST FLOOR	Does not exist
<b>Local Sound System</b>	
Instance on 1ST FLOOR	Under construction
<b>Theater Lighting System</b>	
Instance on 1ST FLOOR	Does not exist
<b>CITY FIRE ALARM SYSTEM</b>	
Condition	Inspected
Deficiency	3- Fair
	No deficiencies recorded
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency Quantity	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Quantity Uom	1,000
Potential Action	EACH
Urgency of Action	REPLACE-UPGRADE
Purpose of Action	PRIORITY 1
Violations	LEVEL 2
	No violations recorded
<b>Recessed Mounted</b>	
Condition	Inspected
Deficiency	2- Between Good and Fair
	No deficiencies recorded
<b>Surface Mounted</b>	
Condition	Inspected
Deficiency	3- Fair
	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
	Does not exist
<b>Lighting Fixture - Incandescent</b>	
<b>Pendant Mounted</b>	
	Does not exist
<b>Recessed Mounted</b>	
	Does not exist
<b>Surface Mounted</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	60
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>COMPUTER LAB</b>	
Instance	Inspected
Has LAN/Modem access	ROOM 417
Power Panel?	Yes
	Yes
<b>Lighting</b>	
Instance on ROOM 417	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on ROOM 417	Inspected
<b>Pendant Mounted</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**M060**

Question	Response
<b>COMPUTER LAB</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Instance on ROOM 417	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on ROOM 417	Does not exist
<b>Surface Mounted</b>	
Instance on ROOM 417	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on ROOM 417	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on ROOM 417	Does not exist
<b>Raceway With Receptacles</b>	
Instance on ROOM 417	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>ELECTRIC SERVICE SWITCH</b>	Inspected
Instance	ELECTRICAL ROOM
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	METROPOLITAN
Model	METROPOLITAN
EquipmentId	MAIN DISCONNECT
Capacity/Size	2500 AMPS
Installation Year	1968
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	ELECTRICAL ROOM
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	ELECTRICAL ROOM
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ELECTROTECH
Model	ELECTROTECH
EquipmentId	DISCONNECT DP-A
Capacity/Size	800 AMPS
Installation Year	2004
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**M060**

<b>Question</b>	<b>Response</b>
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Connected To Emergency Generator System</b>	Does not exist
<b>Connected To Emergency Light/Exit Light Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Relay Test Switch</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	Inspected
<b>Battery Pack</b>	Does not exist
<b>Connected To Emergency Generator System</b>	Does not exist
<b>Connected To Emergency Light/Exit Light Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>FIRE ALARM SYSTEM</b>	Inspected
Replacement Quantity	121,000
Replacement Uom	S.F.
<b>Area Smoke Detector</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Bell/Horn</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Duct Smoke Detector</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Elevator Recall</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fan Shutdown Control</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Digital Communicator</b>	Inspected
Instance	BOILER ROOM
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ADEMCO
EquipmentId	FIRE ALARM COMMUNICATOR
Capacity/Size	5 ZONES
Installation Year	2003
Deficiency	No deficiencies recorded
<b>Fused Cutout Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Heat Detector</b>	Does not exist
<b>Magnetic Door Holder Contactor</b>	Does not exist
<b>Main Panel</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**M060**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>Main Panel</b>	
<b>Bell At Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Does not exist
<b>Fire Alarm Control Panel (Standard)</b>	Inspected
Instance	BOILER ROOM
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	FACP
Capacity/Size	7 CIRCUITS
Installation Year	1968
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Manual Pull Station</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	Inspected
<b>Display Monitor</b>	Does not exist
<b>Panel</b>	Does not exist
<b>Printer</b>	Does not exist
<b>Punch Register</b>	Inspected
Condition	5- Poor
Deficiency	REGISTER NOT OPERATIONAL
Deficiency Location/Instance	SNOW EQUIPMENT ROOM
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Sprinkler Flow/Air Pressure Switch</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Strobe</b>	Does not exist
<b>Sub-Panel</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Inspected
Instance	BOILER ROOM
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	EDWARDS
Model	EST 2
EquipmentId	ELEVATOR SMOKE DETECTION PANEL
Capacity/Size	6 ZONES

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**M060**

Question	Response
<b>FIRE ALARM SYSTEM</b>	
<b>Sub-Panel</b>	
<b>Fire Alarm Control Panel (Electronic)</b>	
Installation Year	2003
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Standard)</b>	
	Inspected
Instance	BOILER ROOM
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	SMOKE DETECTION CONTROL BOARD
Capacity/Size	3 CIRCUITS
Installation Year	1968
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	BOILER ROOM
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	SPRINKLER ALARM PANEL
Capacity/Size	2 CIRCUITS
Installation Year	1968
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	ELECTRICAL ROOM
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	REGISTER CONTROL BOARD
Capacity/Size	1 CIRCUIT
Installation Year	1968
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Tamper Flow Switch/Chain</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GROUNDING SYSTEM</b>	
	Inspected
Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**M060**

<b>Question</b>	<b>Response</b>
<b>GROUNDING SYSTEM</b>	
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	Inspected
Instance	5 TH FLOOR BOYS & GIRLS
<b>Lighting</b>	
Instance on 5 TH FLOOR BOYS & GIRLS	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 5 TH FLOOR BOYS & GIRLS	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 5 TH FLOOR BOYS & GIRLS	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 5 TH FLOOR BOYS & GIRLS	Inspected
<b>Pendant Mounted</b>	
Instance on 5 TH FLOOR BOYS & GIRLS	Does not exist
<b>Recessed Mounted</b>	
Instance on 5 TH FLOOR BOYS & GIRLS	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	40
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on 5 TH FLOOR BOYS & GIRLS	Does not exist
<b>Local Sound System</b>	
Instance on 5 TH FLOOR BOYS & GIRLS	Under construction
<b>Scoreboard</b>	
Instance on 5 TH FLOOR BOYS & GIRLS	Does not exist
<b>Theater Lighting System</b>	
Instance on 5 TH FLOOR BOYS & GIRLS	Does not exist
<b>INTERCOM SYSTEM</b>	Inspected
<b>Elevator</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Holding Area</b>	Does not exist
<b>KITCHEN/WARMING PANTRY</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>LAN</b>	Inspected
<b>Local Distribution Frame (I/LDF)</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Main Equipment Rack (MDF)</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**M060**

<b>Question</b>	<b>Response</b>
<b>LIBRARY</b>	Inspected
Instance	ROOM 302
Has LAN/Modem access	Yes
<b>Lighting</b>	
Instance on ROOM 302	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on ROOM 302	Inspected
<b>Pendant Mounted</b>	
Instance on ROOM 302	Does not exist
<b>Recessed Mounted</b>	
Instance on ROOM 302	Does not exist
<b>Surface Mounted</b>	
Instance on ROOM 302	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on ROOM 302	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on ROOM 302	Does not exist
<b>Raceway With Receptacles</b>	
Instance on ROOM 302	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>LIGHTING - EXTERIOR SECURITY</b>	Inspected
Condition	3- Fair
Replacement Quantity	18
Replacement Uom	EACH
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	EXTERIOR
Deficiency Quantity	14
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 3
Violations	No violations recorded
<b>LIGHTNING PROTECTION</b>	Does not exist
<b>LOCKER ROOM/SHOWER ROOM</b>	Does not exist
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	MECHANICAL SPACES
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MULTIPURPOSE ROOM</b>	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>Fused Disconnect Switch Type</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**M060**

<b>Question</b>	<b>Response</b>
<b>PANEL BOARD</b>	
<b>Fused Knife Switch Type</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	OLD ELECTRIC ROOM
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Fused Toggle Switch Type</b>	Does not exist
<b>Molded Case Circuit Breaker Type</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	CORRIDORS, PA SPACES
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>PUBLIC ADDRESS SYSTEM</b>	Under construction
<b>SCIENCE DEMO ROOM</b>	Inspected
Instance	Rooms 202, 204 and 205
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
<b>Emergency Gas Shut-Off Valve</b>	
Instance on Rooms 202, 204 and 205	Does not exist
<b>Emergency Shut-Off Power</b>	
Instance on Rooms 202, 204 and 205	Does not exist
<b>Lighting</b>	
Instance on Rooms 202, 204 and 205	Not required
<b>Power Supply</b>	
Instance on Rooms 202, 204 and 205	Does not exist
<b>SCIENCE LAB</b>	Does not exist
<b>SCIENCE PREP ROOM</b>	Does not exist
<b>SECURITY</b>	Inspected
Replacement Quantity	121,000
Replacement Uom	S.F.
<b>Intrusion Alarm</b>	Inspected
<b>Central Control Panel</b>	Inspected
Instance	CUSTODIAN OFFICE
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	VISTA 50 P
Deficiency	No deficiencies recorded
<b>Infrared Sensor</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**M060**

<b>Question</b>	<b>Response</b>
<b>SECURITY</b>	
<b>Intrusion Alarm</b>	
<b>Remote Annunciator</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Ultrasonic Sensor</b>	Does not exist
<b>IPDVS/CCTV System</b>	Does not exist
<b>SWIMMING POOL</b>	Does not exist
<b>SWITCHBOARD</b>	Inspected
<b>Air Circuit Breaker Type</b>	Does not exist
<b>Fused Disconnect Switch Type</b>	Inspected
Instance	ELECTRICAL ROOM
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ALL CITY SWBD
EquipmentId	SWBD
Capacity/Size	2500 AMPERES TOTAL,4 SECTIONS
Installation Year	1968
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Fused Knife Switch Type</b>	Does not exist
<b>Molded Case Circuit Breaker Type</b>	Does not exist
<b>TELEPHONE</b>	Inspected
<b>PBX/Intercom</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Standard</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>TOILET ROOM - STAFF</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded

NYC Department of Education  
 Building Condition Assessment Survey 2008-2009

*Electrical Inspection*

**M060**

Question	Response
<b>TOILET ROOM - STUDENT</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>TRANSFORMER</b>	Does not exist
<b>TV SYSTEM</b>	Inspected
<b>Cable Service</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Main Equipment Rack</b>	Does not exist
<b>Master Antenna System</b>	Does not exist