

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M110**

School: **P.S. 110 - MANHATTAN, 285 DELANCY STREET, MANHATTAN, NY, 10002**

InspectionId	Inspection Type	Time In	Last Edited
1530059	ELECTRICAL	2010-12-06 01:03PM	2011-05-09 05:50AM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Smart Board Years: 2007, 2008, 2009, 2010 Systems: LAN Years: 2008 Systems: Library Years: 2008 Systems: Intrusion Alarm System Years: 2006 Systems: Service Switch Years: 2006 Systems: Molded Case Circuit Breaker Panel Boards Years: 1990, 2006, 2008 Systems: Exit and Emergency Lights Years: 2005 Systems: Science Rooms Years: 2004 Systems: Telephone System Years: 2001 Systems: Security Lights, Interiors Fluorescent Lighting Years: 2001 Systems: Motor Starters Years: 1989
Type of Service	Below Ground

**Priority Condition**

No condition recorded

**Inspection**

Question	Response
<b>ELECTRICAL</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Does not exist
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>CAFETERIA</b>	Inspected
Instance	1st Floor
<b>LIGHTING</b>	
Instance on 1st Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	3
Quantity Uom	EACH

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M110**

<b>Question</b>	<b>Response</b>
<b>CAFETERIA</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on 1st Floor	Does not exist
<b>CITY FIRE ALARM SYSTEM</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	
Does a Chandelier Exist?	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	29
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Does not exist	
<b>Surface Mounted</b>	
Inspected	
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
Does not exist	
<b>Lighting Fixture - Incandescent</b>	
Does not exist	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M110**

<b>Question</b>	<b>Response</b>
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>SMART BOARD</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>COMPUTER LAB</b>	Inspected
Instance	Room 502
Has LAN/Modem access	Yes
Power Panel?	Yes
<b>LIGHTING</b>	
Instance on Room 502	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 502	Inspected
<b>Pendant Mounted</b>	
Instance on Room 502	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 502	Does not exist
<b>Surface Mounted</b>	
Instance on Room 502	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 502	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 502	Does not exist
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room 502	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	LESS THAN 20% SPARE CIRCUIT BREAKERS
Deficiency Location/Instance	Basement
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL NEW PANEL BOARD
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>EMERGENCY LIGHTING</b>	Inspected
<b>BATTERY PACK</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	Inspected
<b>BATTERY PACK</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M110**

<b>Question</b>	<b>Response</b>
<b>EXIT LIGHT</b>	
<b>BATTERY PACK</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Does not exist
<b>EXIT/EMERGENCY LIGHT</b>	Does not exist
<b>FIRE ALARM SYSTEM</b>	Inspected
<b>AREA SMOKE DETECTOR</b>	Does not exist
<b>BELL/HORN</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>DUCT SMOKE DETECTOR</b>	Does not exist
<b>ELEVATOR RECALL</b>	Does not exist
<b>FAN SHUTDOWN CONTROL</b>	Does not exist
<b>FIRE ALARM DIGITAL COMMUNICATOR</b>	Does not exist
<b>FUSED CUTOOUT PANEL</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>HEAT DETECTOR</b>	Does not exist
<b>MAGNETIC DOOR HOLDER CONTACTOR</b>	Does not exist
<b>MAIN PANEL</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Does not exist
<b>Fire Alarm Control Panel (Standard)</b>	Inspected
Instance	Basement
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards
EquipmentId	N/A
Capacity/Size	4 circuits
Installation Year	1955
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	52,000
Quantity Uom	S.F.
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PANEL ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MANUAL PULL STATION</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>REMOTE ANNUNCIATOR</b>	Does not exist
<b>SPRINKLER FLOW/AIR PRESSURE SWITCH</b>	Inspected
Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M110**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>SPRINKLER FLOW/AIR PRESSURE SWITCH</b>	
Deficiency	No deficiencies recorded
<b>STROBE</b>	Does not exist
<b>SUB-PANEL</b>	Does not exist
<b>TAMPER FLOW SWITCH/CHAIN</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GROUNDING SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	Does not exist
<b>INTERCOM SYSTEM</b>	Does not exist
<b>KITCHEN/WARMING PANTRY</b>	Inspected
Instance	1st Floor
<b>LIGHTING</b>	
Instance on 1st Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not exist
<b>LAN</b>	Inspected
<b>LOCAL DISTRIBUTION FRAME (I/LDF)</b>	Does not exist
<b>MAIN EQUIPMENT RACK (MDF)</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>LIBRARY</b>	Inspected
Instance	Room 305
Has LAN/Modem access	Yes
<b>LIGHTING</b>	
Instance on Room 305	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 305	Inspected
<b>Pendant Mounted</b>	
Instance on Room 305	Inspected
Instance Condition	1- Good
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M110**

<b>Question</b>	<b>Response</b>
<b>LIBRARY</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 305	Inspected
Instance Condition	1- Good
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on Room 305	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 305	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 305	Does not exist
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room 305	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>SMART BOARD</b>	
Instance on Room 305	Does not exist
<b>LIGHTING - SECURITY LIGHTS</b>	
Condition	Inspected
Replacement Quantity	3- Fair
Replacement Uom	13
Deficiency	EACH
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Side of Building
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 3
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Mounted to Parapet
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
<b>LIGHTNING PROTECTION</b>	
Does not exist	
<b>LOCKER ROOM</b>	
Does not exist	
<b>MOTOR CONTROL CENTER</b>	
Does not exist	
<b>MOTOR STARTER/CONTACTOR</b>	
Inspected	
Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M110**

<b>Question</b>	<b>Response</b>
<b>MOTOR STARTER/CONTACTOR</b>	
Deficiency	No deficiencies recorded
<b>MULTIPURPOSE ROOM</b>	
Instance	Inspected
Instance	1st Floor
Instance	2nd Floor
<b>LIGHTING</b>	
Instance on 1st Floor	Inspected
Instance on 2nd Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Inspected
Instance on 2nd Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not exist
Instance on 2nd Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not exist
Instance on 2nd Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on 2nd Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
Instance on 2nd Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not exist
Instance on 2nd Floor	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on 1st Floor	Does not exist
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>PROJECTION SYSTEM</b>	
Instance on 1st Floor	Does not exist
Instance on 2nd Floor	Does not exist
<b>THEATER LIGHTING SYSTEM</b>	
Instance on 1st Floor	Does not exist
Instance on 2nd Floor	Does not exist
<b>PANEL BOARD</b>	
	Inspected
<b>FUSED DISCONNECT SWITCH TYPE</b>	
	Does not exist
<b>FUSED KNIFE SWITCH TYPE</b>	
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Basement
Deficiency Quantity	1
Quantity Uom	EACH

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M110**

<b>Question</b>	<b>Response</b>
<b>PANEL BOARD</b>	
<b>FUSED KNIFE SWITCH TYPE</b>	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>FUSED TOGGLE SWITCH TYPE</b>	
Condition	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Cafeteria, 1st Floor Multipurpose Room, 2nd Floor Multipurpose Room, 2nd Floor Corridor, 3rd Floor Corridor, 4th Floor Corridor, 5th Floor Corridor
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	
Condition	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>PUBLIC ADDRESS SYSTEM</b>	
Instance	Inspected
Instance	Main Office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Commercial Radio Sound Corp.
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Main Office
Deficiency Quantity	52,000
Quantity Uom	S.F.
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SPEAKER NOT OPERATIONAL
Deficiency Location/Instance	1st Floor Multipurpose Room, 2nd Floor Multipurpose Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	3rd Floor Corridor, 4th Floor Corridor
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SCIENCE DEMO ROOM</b>	
Instance on Room 309, 505	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M110**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Room 309, 505	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	NOT IN USE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>EMERGENCY SHUT-OFF POWER</b>	
Instance on Room 309, 505	Does not exist
<b>LIGHTING</b>	
Instance on Room 309, 505	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 309, 505	Inspected
<b>Pendant Mounted</b>	
Instance on Room 309, 505	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 309, 505	Does not exist
<b>Surface Mounted</b>	
Instance on Room 309, 505	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 309, 505	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 309, 505	Does not exist
<b>POWER SUPPLY</b>	
Instance on Room 309, 505	Does not exist
<b>PROJECTION SYSTEM</b>	
Instance on Room 309, 505	Does not exist
<b>SMART BOARD</b>	
Instance on Room 309, 505	Does not exist
<b>SCIENCE LAB</b>	
Does not exist	
<b>SCIENCE PREP ROOM</b>	
Does not exist	
<b>SECURITY</b>	
Inspected	
<b>INTRUSION ALARM</b>	
Inspected	
<b>Central Control Panel</b>	
Inspected	
Instance	Custodian's Office
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista 128B
Deficiency	No deficiencies recorded
<b>Infrared Sensor</b>	
Inspected	
Condition	2- Between Good and Fair
Deficiency	SENSOR NOT OPERATIONAL
Deficiency Location/Instance	Computer Room 502
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M110**

<b>Question</b>	<b>Response</b>
<b>SECURITY</b>	
<b>INTRUSION ALARM</b>	
<b>Infrared Sensor</b>	
Violations	No violations recorded
<b>Panic Switch</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Ultrasonic Sensor</b>	Does not exist
<b>IPDVS/CCTV SYSTEM</b>	Does not exist
<b>SERVICE SWITCH</b>	Inspected
Instance	Basement
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Electrotech
EquipmentId	N/A
Capacity/Size	800 Amps
Source of Capacity/Size	Nameplate
Installation Year	2006
Source of Installation Year	Documented
Deficiency	SWITCH ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SWIMMING POOL</b>	Does not exist
<b>SWITCHBOARD</b>	Inspected
Water Penetration In Electrical Room?	No
Number of Spares	0
<b>AIR CIRCUIT BREAKER TYPE</b>	Does not exist
<b>FUSED DISCONNECT SWITCH TYPE</b>	Does not exist
<b>FUSED KNIFE SWITCH TYPE</b>	Inspected
Instance	Basement
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Empire Switchboard
EquipmentId	N/A
Capacity/Size	562 Amps total, 1 section
Source of Capacity/Size	Switchboard Mains Size
Installation Year	1955
Source of Installation Year	Documented
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M110**

<b>Question</b>	<b>Response</b>
<b>SWITCHBOARD</b>	
<b>FUSED KNIFE SWITCH TYPE</b>	
Violations	No violations recorded
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	
	Does not exist
<b>TELEPHONE</b>	
	Inspected
<b>PBX/INTERCOM</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>STANDARD</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>TOILET ROOM - STAFF</b>	
	Inspected
<b>LIGHTING</b>	
	Inspected
<b>Lighting Fixture - Fluorescent</b>	
	Inspected
<b>Pendant Mounted</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
	Does not exist
<b>Surface Mounted</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
	Does not exist
<b>Lighting Fixture - Incandescent</b>	
	Inspected
<b>Pendant Mounted</b>	
	Does not exist
<b>Recessed Mounted</b>	
	Does not exist
<b>Surface Mounted</b>	
Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>TOILET ROOM - STUDENT</b>	
	Inspected
<b>LIGHTING</b>	
	Inspected
<b>Lighting Fixture - Fluorescent</b>	
	Inspected
<b>Pendant Mounted</b>	
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M110**

<b>Question</b>	<b>Response</b>
<b>TOILET ROOM - STUDENT</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TRANSFORMER</b>	Does not exist
<b>TV SYSTEM</b>	Inspected
Cable System Exist?	Yes
Operational?	No
Master Antenna System Exist?	No
<b>MAIN EQUIPMENT RACK</b>	Does not exist