

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M136

School: **I.S. 136 - MANHATTAN, 6 EDGECOMBE AVENUE, MANHATTAN, NY, 10030**

InspectionId	Inspection Type	Time In	Last Edited
1600047	ELECTRICAL	2010-11-23 08:27AM	2011-05-09 05:50AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Interior Lighting Years: 1998 Systems: Local Area Network Years: 2009 Systems: Public Address System, Local Sound System Years: 2009 Systems: Exit, Emergency Lighting Years: 1998 Systems: 3rd Floor Gymnasium Scoreboard Years: 2008 Systems: Auditorium- Theater Lighting System, House Lighting (Except Incandescent Lighting) Years: 2010 Systems: Raceway in Computer Lab 307 Years: 2007 Systems: 5th Floor Gymnasium Lighting Years: 2009 Systems: Lighting in Locker Room (3rd Floor Stair H) Years: 2008 Systems: Science Lab Room 301, 303. Science Prep Room 305 Years: 2000 Systems: IPDVS/CCTV System Years: 2010 Systems: Motor Starters-Partial Upgrade Years: 2008 Systems: Security Lighting- Partial Upgrade Years: 2009 Systems: Panel Board- Partial Upgrade Years: 1998/2010
Type of Service	Below Ground

Priority Condition

Condition Description	Component Affected	Location Description	Person(s) Notified
Chain Missing	Fire Alarm System Tamper Flow Switch/Chain	Boiler Room-Crawl Space	Philip Lane

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	1st Floor
HOUSE LIGHTING	
Instance on 1st Floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M136

Question	Response
AUDITORIUM	
HOUSE LIGHTING	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
PROJECTION SYSTEM	
Instance on 1st Floor	Does not exist
THEATER LIGHTING SYSTEM	
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA	
Instance	1st Floor
LIGHTING	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M136

Question	Response
CAFETERIA	
LIGHTING	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
CITY FIRE ALARM SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
LIGHTING	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
SMART BOARD	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
COMPUTER LAB	Inspected
Instance	Room 502
Has LAN/Modem access	Yes
Power Panel?	No
Instance	Room 307
Has LAN/Modem access	Yes
Power Panel?	Yes
LIGHTING	
Instance on Room 502	Inspected
Instance on Room 307	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 502	Inspected
Instance on Room 307	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M136

Question	Response
COMPUTER LAB	
LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Instance on Room 502	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 307	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 502	Does not exist
Instance on Room 307	Does not exist
Surface Mounted	
Instance on Room 502	Does not exist
Instance on Room 307	Does not exist
Lighting Fixture - HID	
Instance on Room 502	Does not exist
Instance on Room 307	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 502	Does not exist
Instance on Room 307	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 502	Does not exist
Instance on Room 307	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
BATTERY PACK	Inspected
Condition	3- Fair
Deficiency	BATTERY NOT OPERATIONAL
Deficiency Location/Instance	3rd Floor Slop Sink, Room 461, Boiler Room-North Side, Vestibule Exit 9, Stair H 5th Floor, 5th Floor Corridor Stair F&G
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE BATTERY
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
BATTERY PACK	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M136

Question	Response
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
AREA SMOKE DETECTOR	Does not exist
BELL/HORN	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
DUCT SMOKE DETECTOR	Does not exist
ELEVATOR RECALL	Does not exist
FAN SHUTDOWN CONTROL	Does not exist
FIRE ALARM DIGITAL COMMUNICATOR	Does not exist
FUSED CUTOFF PANEL	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
HEAT DETECTOR	Does not exist
MAGNETIC DOOR HOLDER CONTACTOR	Does not exist
MAIN PANEL	Inspected
Bell At Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Does not exist
Fire Alarm Control Panel (Standard)	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Fire Alarm Control Board
Capacity/Size	5 circuits
Installation Year	1968
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	113,000
Quantity Uom	S.F.
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MANUAL PULL STATION	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
REMOTE ANNUNCIATOR	Inspected
Display Monitor	Does not exist
Panel	Does not exist
Printer	Does not exist
Punch Register	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
SPRINKLER FLOW/AIR PRESSURE SWITCH	Does not exist
STROBE	Does not exist
SUB-PANEL	Inspected
Bell At Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Does not exist
Fire Alarm Control Panel (Standard)	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M136

Question	Response
FIRE ALARM SYSTEM	
SUB-PANEL	
Fire Alarm Control Panel (Standard)	
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Register Control Board
Capacity/Size	2 circuits
Installation Year	1968
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TAMPER FLOW SWITCH/CHAIN	
Condition	Inspected
Deficiency	3- Fair
Deficiency	CHAIN MISSING
Deficiency Location/Instance	Boiler Room-Crawl Space
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL CHAIN
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
GROUNDING SYSTEM	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	
Instance	Inspected
Instance	5th Floor
Instance	3rd Floor
LIGHTING	
Instance on 5th Floor	Inspected
Instance on 3rd Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 5th Floor	Inspected
Instance on 3rd Floor	Does not exist
Pendant Mounted	
Instance on 5th Floor	Does not exist
Recessed Mounted	
Instance on 5th Floor	Does not exist
Surface Mounted	
Instance on 5th Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 5th Floor	Does not exist
Instance on 3rd Floor	Inspected
Pendant Mounted	
Instance on 3rd Floor	Does not exist
Recessed Mounted	
Instance on 3rd Floor	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M136

Question	Response
GYMNASIUM	
LIGHTING	
Lighting Fixture - HID	
Recessed Mounted	
Surface Mounted	
Instance on 3rd Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	17
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - Incandescent	
Instance on 5th Floor	Does not exist
Instance on 3rd Floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 5th Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on 3rd Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
SCOREBOARD	
Instance on 5th Floor	Does not exist
Instance on 3rd Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
THEATER LIGHTING SYSTEM	
Instance on 5th Floor	Does not exist
Instance on 3rd Floor	Does not exist
INTERCOM SYSTEM	
Instance	Does not exist
KITCHEN/WARMING PANTRY	
Instance	Inspected
Instance	1st Floor
LIGHTING	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M136

Question	Response
KITCHEN/WARMING PANTRY	
LIGHTING	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
LAN	Inspected
LOCAL DISTRIBUTION FRAME (I/LDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
MAIN EQUIPMENT RACK (MDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	Room 404
Has LAN/Modem access	Yes
Instance	Room 207
Has LAN/Modem access	Yes
LIGHTING	
Instance on Room 404	Inspected
Instance on Room 207	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 404	Inspected
Instance on Room 207	Inspected
Pendant Mounted	
Instance on Room 404	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 207	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 404	Does not exist
Instance on Room 207	Does not exist
Surface Mounted	
Instance on Room 404	Does not exist
Instance on Room 207	Does not exist
Lighting Fixture - HID	
Instance on Room 404	Does not exist
Instance on Room 207	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 404	Does not exist
Instance on Room 207	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 404	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M136

Question	Response
LIBRARY	
RACEWAY WITH RECEPTACLES	
Deficiency	No deficiencies recorded
Instance on Room 207	Does not exist
SMART BOARD	
Instance on Room 404	Does not exist
Instance on Room 207	Does not exist
LIGHTING - SECURITY LIGHTS	
Condition	Inspected
Replacement Quantity	2- Between Good and Fair
Replacement Uom	25
Deficiency	EACH
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	
Does not exist	
LOCKER ROOM	
Instance on 3rd Floor- Gymnasium	Inspected
Alternative Use	No
Instance on 3rd Floor- Stair H	Inspected
Alternative Use	No
LIGHTING	
Instance on 3rd Floor- Gymnasium	Inspected
Instance on 3rd Floor- Stair H	Inspected
Lighting Fixture - Fluorescent	
Instance on 3rd Floor- Gymnasium	Inspected
Instance on 3rd Floor- Stair H	Inspected
Pendant Mounted	
Instance on 3rd Floor- Gymnasium	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 3rd Floor- Stair H	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 3rd Floor- Gymnasium	Does not exist
Instance on 3rd Floor- Stair H	Does not exist
Surface Mounted	
Instance on 3rd Floor- Gymnasium	Does not exist
Instance on 3rd Floor- Stair H	Does not exist
Lighting Fixture - HID	
Instance on 3rd Floor- Gymnasium	Does not exist
Instance on 3rd Floor- Stair H	Does not exist
Lighting Fixture - Incandescent	
Instance on 3rd Floor- Gymnasium	Does not exist
Instance on 3rd Floor- Stair H	Does not exist
MOTOR CONTROL CENTER	
Does not exist	
MOTOR STARTER/CONTACTOR	
Inspected	
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Boiler Room

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M136

Question	Response
MOTOR STARTER/CONTACTOR	
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
FUSED DISCONNECT SWITCH TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED KNIFE SWITCH TYPE	Does not exist
FUSED TOGGLE SWITCH TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MOLDED CASE CIRCUIT BREAKER TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Corridors, Library, Kitchen, Boiler Room
Deficiency Quantity	25
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PANEL BOARD DOOR LOCK IS MISSING
Deficiency Location/Instance	4th Floor Corridor
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	Inspected
Instance	General Office- Room 212
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Dukane 250
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M136

Question	Response
SCIENCE DEMO ROOM	
Instance on Room 409	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 309	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 409	Does not exist
Instance on Room 309	Does not exist
EMERGENCY SHUT-OFF POWER	
Instance on Room 409	Does not exist
Instance on Room 309	Does not exist
LIGHTING	
Instance on Room 409	Inspected
Instance on Room 309	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 409	Inspected
Instance on Room 309	Inspected
Pendant Mounted	
Instance on Room 409	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 309	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 409	Does not exist
Instance on Room 309	Does not exist
Surface Mounted	
Instance on Room 409	Does not exist
Instance on Room 309	Does not exist
Lighting Fixture - HID	
Instance on Room 409	Does not exist
Instance on Room 309	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 409	Does not exist
Instance on Room 309	Does not exist
POWER SUPPLY	
Instance on Room 409	Does not exist
Instance on Room 309	Does not exist
PROJECTION SYSTEM	
Instance on Room 409	Does not exist
Instance on Room 309	Does not exist
SMART BOARD	
Instance on Room 409	Does not exist
Instance on Room 309	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M136

Question	Response
SCIENCE DEMO ROOM	
SMART BOARD	
Instance Condition	1- Good
Deficiency	No deficiencies recorded
SCIENCE LAB	
Instance on Room 403, 401	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 303	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 301	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 403, 401	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 303	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 301	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room 403, 401	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 303	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 301	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Room 403, 401	Inspected
Instance on Room 303	Inspected
Instance on Room 301	Inspected
Lighting Fixture - Fluorescent	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M136

Question	Response
SCIENCE LAB	
LIGHTING	
Lighting Fixture - Fluorescent	
Instance on Room 403, 401	Inspected
Instance on Room 303	Inspected
Instance on Room 301	Inspected
Pendant Mounted	
Instance on Room 403, 401	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 303	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 301	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 403, 401	Does not exist
Instance on Room 303	Does not exist
Instance on Room 301	Does not exist
Surface Mounted	
Instance on Room 403, 401	Does not exist
Instance on Room 303	Does not exist
Instance on Room 301	Does not exist
Lighting Fixture - HID	
Instance on Room 403, 401	Does not exist
Instance on Room 303	Does not exist
Instance on Room 301	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 403, 401	Does not exist
Instance on Room 303	Does not exist
Instance on Room 301	Does not exist
POWER SUPPLY	
Instance on Room 403, 401	Does not exist
Instance on Room 303	Does not exist
Instance on Room 301	Does not exist
PROJECTION SYSTEM	
Instance on Room 403, 401	Does not exist
Instance on Room 303	Does not exist
Instance on Room 301	Does not exist
SMART BOARD	
Instance on Room 403, 401	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 303	Does not exist
Instance on Room 301	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
SCIENCE PREP ROOM	
Instance on Room 402A	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 305	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M136

Question	Response
SCIENCE PREP ROOM	
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 402A	Does not exist
Instance on Room 305	Does not exist
EMERGENCY SHUT-OFF POWER	
Instance on Room 402A	Does not exist
Instance on Room 305	Does not exist
LIGHTING	
Instance on Room 402A	Inspected
Instance on Room 305	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 402A	Inspected
Instance on Room 305	Inspected
Pendant Mounted	
Instance on Room 402A	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 305	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 402A	Does not exist
Instance on Room 305	Does not exist
Surface Mounted	
Instance on Room 402A	Does not exist
Instance on Room 305	Does not exist
Lighting Fixture - HID	
Instance on Room 402A	Does not exist
Instance on Room 305	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 402A	Does not exist
Instance on Room 305	Does not exist
POWER SUPPLY	
Instance on Room 402A	Does not exist
Instance on Room 305	Does not exist
SECURITY	
INTRUSION ALARM	
Central Control Panel	
Instance	Room 108
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Ademco
Deficiency	No deficiencies recorded
Infrared Sensor	
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	
	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M136

Question	Response
SECURITY	
INTRUSION ALARM	
Remote Annunciator	
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	
	Does not exist
IPDVS/CCTV SYSTEM	
Condition	Inspected
Deficiency	1- Good
Deficiency	No deficiencies recorded
SERVICE SWITCH	
	Inspected
Instance	Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	American Switchboard Co.
EquipmentId	N/A
Capacity/Size	4000 Amps
Source of Capacity/Size	Nameplate
Installation Year	1968
Source of Installation Year	Documented
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCH ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
SWIMMING POOL	
	Does not exist
SWITCHBOARD	
	Inspected
Water Penetration In Electrical Room?	No
Number of Spares	1
AIR CIRCUIT BREAKER TYPE	
	Does not exist
FUSED DISCONNECT SWITCH TYPE	
	Inspected
Instance	Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	American Switchboard Co.
EquipmentId	N/A
Capacity/Size	4000 Amps total, 4 sections
Source of Capacity/Size	Service Switch Size
Installation Year	1968
Source of Installation Year	Documented
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M136

Question	Response
SWITCHBOARD	
FUSED DISCONNECT SWITCH TYPE	
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED KNIFE SWITCH TYPE	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	Does not exist
TELEPHONE	Inspected
PBX/INTERCOM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
STANDARD	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TOILET ROOM - STUDENT	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M136

Question	Response
TOILET ROOM - STUDENT	
LIGHTING	
Lighting Fixture - Incandescent	
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable System Exist?	Yes
Operational?	Yes
Master Antenna System Exist?	Yes
Operational?	No
MAIN EQUIPMENT RACK	Does not exist