

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M271

School: P.S./I.S. 217 - MANHATTAN, 645 MAIN STREET, MANHATTAN, NY, 10044

InspectionId	Inspection Type	Time In	Last Edited
49590	ELECTRICAL	2008-11-04 08:21AM	2009-02-12 10:34AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Battery charger for Generator Years: 2008 Systems: LAN and PBX/ Intercom Years: 2004/2005 Systems: All other systems Years: 1991/1992

Priority Condition

Condition Description	Component Affected	Location Description	Person(s) Notified
Not Operational	Elevator Intercom	Freight and Passenger Elevators	Jeff Atkinson - Custodian

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Under construction
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Condition	3- Fair
Replacement Quantity	98,000
Replacement Uom	S.F.
Deficiency	No deficiencies recorded
CAFETERIA	Inspected
Instance	First Floor
Lighting	
Instance on First Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on First Floor	Inspected
Pendant Mounted	
Instance on First Floor	Does not exist
Recessed Mounted	
Instance on First Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on First Floor	Does not exist
Lighting Fixture - HID	
Instance on First Floor	Inspected
Pendant Mounted	
Instance on First Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on First Floor	Does not exist
Surface Mounted	
Instance on First Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on First Floor	Inspected
Pendant Mounted	
Instance on First Floor	Does not exist
Recessed Mounted	
Instance on First Floor	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M271

Question	Response
CAFETERIA	
Lighting	
Lighting Fixture - Incandescent	
Surface Mounted	
Instance on First Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Local Sound System	
Instance on First Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA/MULTIPURPOSE ROOM	Does not exist
CITY FIRE ALARM SYSTEM	Inspected
Condition	5- Poor
Deficiency	NOT OPERATIONAL
Deficiency Location/Instance	First Floor Corridor
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
COMPUTER LAB	Inspected
Instance	Rooms 404 and 314
Has LAN/Modem access	Yes
Power Panel?	Yes
Lighting	
Instance on Rooms 404 and 314	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M271

Question	Response
COMPUTER LAB	
Lighting	
Lighting Fixture - Fluorescent	
Instance on Rooms 404 and 314	Inspected
Pendant Mounted	
Instance on Rooms 404 and 314	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Rooms 404 and 314	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Rooms 404 and 314	Does not exist
Lighting Fixture - HID	
Instance on Rooms 404 and 314	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms 404 and 314	Does not exist
Raceway With Receptacles	
Instance on Rooms 404 and 314	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
ELECTRIC SERVICE SWITCH	
Instance	Inspected
Instance	Electrical Room B14
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Mac Power Corp
Model	Mac Power Corp
EquipmentId	Service Disconnect
Capacity/Size	2500 Amps
Installation Year	1992
Deficiency	No deficiencies recorded
Instance	Electrical Room B14
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Mac Power Corp
Model	Mac Power Corp
EquipmentId	Main Disconnect
Capacity/Size	4000 Amps
Installation Year	1992
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	
	Does not exist
EMERGENCY GENERATOR SET	
	Inspected
Automatic Transfer Switch (ATS)	
	Inspected
Instance	Electrical Room B14
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ASCO
EquipmentId	Emergency transformer 2nd floor. Transformer switch #1 EMDP
Capacity/Size	400 Amps
Installation Year	1992
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M271

Question	Response
EMERGENCY GENERATOR SET	
Automatic Transfer Switch (ATS)	
Instance	Electrical Room B14
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ASCO
EquipmentId	Not labeled
Capacity/Size	30 Amps
Installation Year	1992
Deficiency	No deficiencies recorded
Instance	Auditorium North Side of Stage
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ASCO
EquipmentId	Not labeled
Capacity/Size	30 Amps
Installation Year	1992
Deficiency	No deficiencies recorded
Battery Charger	Inspected
Instance	Room 250
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	SENS
EquipmentId	Regulated Battery Charger
Capacity/Size	10 Amps, 24VDC
Installation Year	2008
Deficiency	No deficiencies recorded
Diesel	Inspected
Instance	Room 250
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ONAN
EquipmentId	Emergency Generator
Capacity/Size	219KVA, 175KW, 609 Amps
Installation Year	1992
Deficiency	No deficiencies recorded
Natural Gas	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not exist
EMERGENCY LIGHTING	Inspected
Battery Pack	Does not exist
Connected To Emergency Generator System	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Connected To Emergency Light/Exit Light Panel	Does not exist
Relay Test Switch	Does not exist
EXIT LIGHT	Inspected
Battery Pack	Does not exist
Connected To Emergency Generator System	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Connected To Emergency Light/Exit Light Panel	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M271

Question	Response
FIRE ALARM SYSTEM	Inspected
Replacement Quantity	98,000
Replacement Uom	S.F.
Area Smoke Detector	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Bell/Horn	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Duct Smoke Detector	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Elevator Recall	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not exist
Fused Cutout Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Heat Detector	Does not exist
Magnetic Door Holder Contactor	Does not exist
Main Panel	Inspected
Bell At Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	FAST
Model	Not Available
EquipmentId	Fire, Smoke and Sprinkler Alarm Panel
Capacity/Size	7 Zones
Installation Year	1992
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist
Manual Pull Station	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Does not exist
Sprinkler Flow/Air Pressure Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Sub-Panel	Inspected
Bell At Panel	Does not exist
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M271

Question	Response
FIRE ALARM SYSTEM	
Sub-Panel	
Fire Alarm Control Panel (Electronic)	
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	FAST
Model	Not Available
EquipmentId	Purge and Damper Control Panel
Capacity/Size	8 zones
Installation Year	1992
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist
Tamper Flow Switch/Chain	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	Inspected
Instance	Basement
Lighting	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Does not exist
Lighting Fixture - HID	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
Local Sound System	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Scoreboard	
Instance on Basement	Does not exist
Theater Lighting System	
Instance on Basement	Does not exist
INTERCOM SYSTEM	Inspected
Elevator	Inspected
Condition	5- Poor
Deficiency	INTERCOM CABINET NOT OPERATIONAL
Deficiency Location/Instance	Freight and Passenger Elevators
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M271

Question	Response
INTERCOM SYSTEM	
Holding Area	Does not exist
KITCHEN/WARMING PANTRY	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
LAN	Inspected
Local Distribution Frame (I/LDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	Room 260
Has LAN/Modem access	Yes
Lighting	
Instance on Room 260	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 260	Inspected
Pendant Mounted	
Instance on Room 260	Does not exist
Recessed Mounted	
Instance on Room 260	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 260	Does not exist
Lighting Fixture - HID	
Instance on Room 260	Inspected
Pendant Mounted	
Instance on Room 260	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 260	Does not exist
Surface Mounted	
Instance on Room 260	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 260	Inspected
Pendant Mounted	
Instance on Room 260	Does not exist
Recessed Mounted	

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M271

Question	Response
LIBRARY	
Lighting	
Lighting Fixture - Incandescent	
Recessed Mounted	
Instance on Room 260	Does not exist
Surface Mounted	
Instance on Room 260	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Raceway With Receptacles	
Instance on Room 260	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
LIGHTING - EXTERIOR SECURITY	
Condition	Inspected
Replacement Quantity	3- Fair
Replacement Uom	68
Deficiency	EACH
Deficiency Location/Instance	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	Outside West Side Adjacent to Library
Quantity Uom	4
Potential Action	EACH
Urgency of Action	REPAIR
Purpose of Action	PRIORITY 4
Violations	LEVEL 3
	No violations recorded
LIGHTNING PROTECTION	
	Does not exist
LOCKER ROOM/SHOWER ROOM	
Instance	Inspected
Alternative Use	Room B44 Girls
Instance	No
Alternative Use	Room B42 Boys
Instance	No
Alternative Use	No
Lighting	
Instance on Room B44 Girls	Inspected
Instance on Room B42 Boys	Inspected
Lighting Fixture - Fluorescent	
Instance on Room B44 Girls	Inspected
Instance on Room B42 Boys	Inspected
Pendant Mounted	
Instance on Room B44 Girls	Does not exist
Instance on Room B42 Boys	Does not exist
Recessed Mounted	
Instance on Room B44 Girls	Does not exist
Instance on Room B42 Boys	Does not exist
Surface Mounted	
Instance on Room B44 Girls	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room B42 Boys	Inspected
Instance Condition	4- Between Fair and Poor

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M271

Question	Response
LOCKER ROOM/SHOWER ROOM	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Room B44 Girls	Does not exist
Instance on Room B42 Boys	Does not exist
Lighting Fixture - Incandescent	
Instance on Room B44 Girls	Does not exist
Instance on Room B42 Boys	Does not exist
MOTOR CONTROL CENTER	Inspected
Instance	Room 410
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Allen Bradley
EquipmentId	MCC-2
Capacity/Size	H - 600Amps, V - 300Amps, 3 sections
Installation Year	1992
Deficiency	No deficiencies recorded
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD DIRECTORY REQUIRES UPDATING
Deficiency Location/Instance	Throughout Building
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	Inspected
Replacement Quantity	98,000
Replacement Uom	S.F.
Instance	General Office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Bogen - Multicom 2000

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M271

Question	Response
PUBLIC ADDRESS SYSTEM	
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Inspected
Instance	Rooms 313 and 308
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on Rooms 313 and 308	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Rooms 313 and 308	Does not exist
Lighting	
Instance on Rooms 313 and 308	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms 313 and 308	Inspected
Pendant Mounted	
Instance on Rooms 313 and 308	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Rooms 313 and 308	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Rooms 313 and 308	Does not exist
Lighting Fixture - HID	
Instance on Rooms 313 and 308	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms 313 and 308	Does not exist
Power Supply	
Instance on Rooms 313 and 308	Does not exist
SCIENCE PREP ROOM	Inspected
Instance	Room 309
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on Room 309	Does not exist
Emergency Shut-Off Power	
Instance on Room 309	Does not exist
Lighting	
Instance on Room 309	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 309	Inspected
Pendant Mounted	
Instance on Room 309	Does not exist
Recessed Mounted	
Instance on Room 309	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M271

Question	Response
SCIENCE PREP ROOM	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Instance on Room 309	Does not exist
Lighting Fixture - HID	
Instance on Room 309	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 309	Does not exist
Power Supply	
Instance on Room 309	Does not exist
SECURITY	Inspected
Replacement Quantity	98,000
Replacement Uom	S.F.
Intrusion Alarm	Inspected
Central Control Panel	Inspected
Instance	Custodians Office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Omegalarm D8112
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	Does not exist
Remote Annunciator	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	Does not exist
IPDVS/CCTV System	Does not exist
SWIMMING POOL	Does not exist
SWITCHBOARD	Inspected
Air Circuit Breaker Type	Does not exist
Fused Disconnect Switch Type	Inspected
Instance	Electrical Room B14
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Mac Power Corp
EquipmentId	Not labeled
Capacity/Size	2500 Amps, 3 Sections
Installation Year	1991
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room B14
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M271

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Mac Power Corp
EquipmentId	Not labeled
Capacity/Size	400 Amps, 1 Section
Installation Year	1991
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room B14
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Mac Power Corp
EquipmentId	Not labeled
Capacity/Size	2500 Amps, 2 Sections
Installation Year	1991
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Does not exist
TELEPHONE	Inspected
PBX/Intercom	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Inspected
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M271

Question	Response
TOILET ROOM - STUDENT	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TRANSFORMER	Inspected
Dry Type	Inspected
Instance	Electrical Room B14
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Square D
EquipmentId	Digital Temperature Controller
Capacity/Size	750/1000 KVA
Installation Year	1991
Deficiency	No deficiencies recorded
Instance	Electrical Room B14
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Square D
EquipmentId	Not labeled
Capacity/Size	75 KVA
Installation Year	1991
Deficiency	TRANSFORMER ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room B14
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Square D
EquipmentId	Not labeled
Capacity/Size	10KVA
Installation Year	1991
Deficiency	TRANSFORMER ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room B14
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Eaton

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M271

Question	Response
TRANSFORMER	
Dry Type	
EquipmentId	Not labeled
Capacity/Size	3KVA
Installation Year	1991
Deficiency	TRANSFORMER ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Room 250
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Hevi Duty
EquipmentId	Not labeled
Capacity/Size	30KVA
Installation Year	1991
Deficiency	TRANSFORMER ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Liquid Type	Does not exist
TV SYSTEM	Inspected
Cable Service	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Main Equipment Rack	Does not exist
Master Antenna System	Does not exist