

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

School: MANHTN CT FOR MATH & SCI. HS - M, 260 PLEASANT AVENUE, MANHATTAN, NY, 10029

InspectionId	Inspection Type	Time In	Last Edited
1920111	ELECTRICAL	2011-03-01 09:18AM	2011-03-24 07:33PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: CCTV System, Elevator Intercom Years: 2010 Systems: Smart boards, Projector Systems, Fire Alarm System Years: 2008 Systems: LAN Years: 2006 Systems: Lighting in Boiler Room / Elevator Machine Room, Boiler Room Exit lighting Years: 2009 Systems: Main Service Switch / Switchboard Years: 1995 Systems: Public Address System, Local Sound Systems, Security Lights, Telephone System, Auxiliary Bell System, Auditorium: Theater Lighting System Years: 2007 Systems: Fluorescent lighting (Girls Locker Room, partial - corridors and science labs), Science Rooms: Power Supply Years: 2000 Systems: Intrusion Alarm System Years: Approx 1995 Systems: Raceway in Computer Lab Room 360 Years: 2008 Systems: Panelboards Years: 1988 Systems: Partial Motor Starters Years: 2000
Type of Service	Below Ground

Priority Condition

Condition Description	Component Affected	Location Description	Person(s) Notified
Not Operational	Public Address Speakers	Basement, 1st Floor Gymnasium	Edward Syvarth - Custodian
Not Operational	Emergency Gas Shut Off, Emergency Power Shut Off	Science Lab Rooms 305, 306, 313, Science Demo Room 380	Edward Syvarth - Custodian
Contactors Missing	Fire Alarm System - Magnetic Door Holder Contactor	Basement - 3rd floor Corridors	Edward Syvarth - Custodian

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	1st floor
Instance	2nd floor (Room 280)
HOUSE LIGHTING	
Instance on 1st floor	Inspected
Does a Chandelier Exist?	No
Instance on 2nd floor (Room 280)	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on 1st floor	Inspected
Instance on 2nd floor (Room 280)	Inspected
Pendant Mounted	
Instance on 1st floor	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
AUDITORIUM	
HOUSE LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Instance on 2nd floor (Room 280)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 1st floor	Does not exist
Instance on 2nd floor (Room 280)	Does not exist
Surface Mounted	
Instance on 1st floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on 2nd floor (Room 280)	Does not exist
Lighting Fixture - HID	
Instance on 1st floor	Does not exist
Instance on 2nd floor (Room 280)	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st floor	Inspected
Instance on 2nd floor (Room 280)	Inspected
Pendant Mounted	
Instance on 1st floor	Does not exist
Instance on 2nd floor (Room 280)	Does not exist
Recessed Mounted	
Instance on 1st floor	Does not exist
Instance on 2nd floor (Room 280)	Does not exist
Surface Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	91
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	MAINTENANCE

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
AUDITORIUM	
HOUSE LIGHTING	
Lighting Fixture - Incandescent	
Surface Mounted	
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd floor (Room 280)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
LOCAL SOUND SYSTEM	
Instance on 1st floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on 2nd floor (Room 280)	Does not exist
PROJECTION SYSTEM	
Instance on 1st floor	Inspected
Instance Condition	2- Between Good and Fair
Is the projector on a cart or installed on the ceiling?	Cart
Deficiency	No deficiencies recorded
Instance on 2nd floor (Room 280)	Does not exist
THEATER LIGHTING SYSTEM	
Instance on 1st floor	Inspected
Instance on 2nd floor (Room 280)	Inspected
Dimming System	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on 2nd floor (Room 280)	Inspected
Instance Condition	3- Fair
Deficiency	DIMMING RACK BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Theater Lighting	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
AUDITORIUM	
THEATER LIGHTING SYSTEM	
Theater Lighting	
Instance on 2nd floor (Room 280)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	26
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	Inspected
Deficiency	1- Good
Deficiency	No deficiencies recorded
CAFETERIA	
Instance	Inspected
Instance	Basement
LIGHTING	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	169
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	INSTALL LENS

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
CAFETERIA	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
LOCAL SOUND SYSTEM	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
CITY FIRE ALARM SYSTEM	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Does a Chandelier Exist?	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Pendant Mounted	
Condition	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	710
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Condition	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	24
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	175
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	25
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Lighting Fixture - Incandescent	
Surface Mounted	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	60
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SMART BOARD	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
COMPUTER LAB	
	Inspected
Instance	Room 250
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room 360
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room 362
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room 350
Has LAN/Modem access	Yes
Power Panel?	Yes
LIGHTING	
Instance on Room 250	Inspected
Instance on Room 360	Inspected
Instance on Room 362	Inspected
Instance on Room 350	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 250	Inspected
Instance on Room 360	Inspected
Instance on Room 362	Inspected
Instance on Room 350	Inspected
Pendant Mounted	
Instance on Room 250	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
COMPUTER LAB	
LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Instance on Room 360	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	27
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 362	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	27
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 350	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	27

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
COMPUTER LAB	
LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room 250	Does not exist
Instance on Room 360	Does not exist
Instance on Room 362	Does not exist
Instance on Room 350	Does not exist
Surface Mounted	
Instance on Room 250	Does not exist
Instance on Room 360	Does not exist
Instance on Room 362	Does not exist
Instance on Room 350	Does not exist
Lighting Fixture - HID	
Instance on Room 250	Does not exist
Instance on Room 360	Does not exist
Instance on Room 362	Does not exist
Instance on Room 350	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 250	Does not exist
Instance on Room 360	Does not exist
Instance on Room 362	Does not exist
Instance on Room 350	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 250	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 360	Inspected
Instance Condition	1- Good

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
COMPUTER LAB	
RACEWAY WITH RECEPTACLES	
Deficiency	No deficiencies recorded
Instance on Room 362	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 350	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	
	Does not exist
EMERGENCY GENERATOR SET	
	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	
Condition	Inspected
Deficiency	3- Fair
Deficiency	PANEL BOARD DIRECTORY MISSING OR REQUIRES UPDATING
Deficiency Location/Instance	Electrical Room (Room B56)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
EMERGENCY LIGHTING	
	Inspected
BATTERY PACK	
Condition	Inspected
Condition	3- Fair
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Basement corridor
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Non Battery Pack	
Condition	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	
	Inspected
BATTERY PACK	
Condition	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Non Battery Pack	
Condition	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT/EMERGENCY LIGHT	
Condition	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
FIRE ALARM SYSTEM	
	Inspected
AREA SMOKE DETECTOR	
Condition	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
BELL/HORN	
Condition	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
DUCT SMOKE DETECTOR	
Condition	Inspected
Condition	1- Good

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
FIRE ALARM SYSTEM	
DUCT SMOKE DETECTOR	
Deficiency	No deficiencies recorded
ELEVATOR RECALL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
FAN SHUTDOWN CONTROL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
FIRE ALARM DIGITAL COMMUNICATOR	Does not exist
FUSED CUTOFF PANEL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
HEAT DETECTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
MAGNETIC DOOR HOLDER CONTACTOR	Inspected
Condition	4- Between Fair and Poor
Deficiency	CONTACTOR MISSING
Deficiency Location/Instance	Basement - 3rd floor corridors
Deficiency Quantity	14
Quantity Uom	EACH
Potential Action	INSTALL CONTACTOR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
MAIN PANEL	Inspected
Bell At Panel	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main lobby
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards
Model	EST 2
EquipmentId	Fire Alarm Control
Capacity/Size	26 zones
Installation Year	2008
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist
MANUAL PULL STATION	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
REMOTE ANNUNCIATOR	Inspected
Display Monitor	Does not exist
Panel	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Punch Register	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
FIRE ALARM SYSTEM	
SPRINKLER FLOW/AIR PRESSURE SWITCH	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
STROBE	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
SUB-PANEL	Inspected
Bell At Panel	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main lobby
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards
Model	EST 2
EquipmentId	Horn / Strobe Control Panel
Capacity/Size	N/A zones
Installation Year	2008
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist
TAMPER FLOW SWITCH/CHAIN	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	Inspected
Instance	1st floor
Instance	Basement
LIGHTING	
Instance on 1st floor	Inspected
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st floor	Does not exist
Instance on Basement	Does not exist
Lighting Fixture - HID	
Instance on 1st floor	Inspected
Instance on Basement	Inspected
Pendant Mounted	
Instance on 1st floor	Does not exist
Instance on Basement	Does not exist
Recessed Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	40
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
GYMNASIUM	
LIGHTING	
Lighting Fixture - HID	
Recessed Mounted	
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 1st floor	Does not exist
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st floor	Inspected
Instance on Basement	Does not exist
Pendant Mounted	
Instance on 1st floor	Does not exist
Recessed Mounted	
Instance on 1st floor	Does not exist
Surface Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
GYMNASIUM	
LIGHTING	
Lighting Fixture - Incandescent	
Surface Mounted	
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
LOCAL SOUND SYSTEM	
Instance on 1st floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SCOREBOARD	
Instance on 1st floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Basement	Does not exist
THEATER LIGHTING SYSTEM	
Instance on 1st floor	Does not exist
Instance on Basement	Does not exist
INTERCOM SYSTEM	
	Inspected
ELEVATOR	
Condition	1- Good
Deficiency	No deficiencies recorded
HOLDING AREA	
	Does not exist
KITCHEN/WARMING PANTRY	
Instance	Basement
LIGHTING	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Does not exist
Recessed Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	93
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	5
Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
KITCHEN/WARMING PANTRY	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
LAN	Inspected
LOCAL DISTRIBUTION FRAME (I/LDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
MAIN EQUIPMENT RACK (MDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	1st floor
Has LAN/Modem access	Yes
LIGHTING	
Instance on 1st floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on 1st floor	Does not exist
Recessed Mounted	
Instance on 1st floor	Does not exist
Surface Mounted	
Instance on 1st floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st floor	Inspected
Pendant Mounted	
Instance on 1st floor	Does not exist
Recessed Mounted	
Instance on 1st floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	35
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
LIBRARY	
LIGHTING	
Lighting Fixture - Incandescent	
Recessed Mounted	
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 1st floor	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on 1st floor	Does not exist
SMART BOARD	
Instance on 1st floor	Does not exist
LIGHTING - SECURITY LIGHTS	
Inspected	Inspected
Condition	1- Good
Replacement Quantity	60
Replacement Uom	EACH
Deficiency	TIME CLOCK NOT OPERATIONAL
Deficiency Location/Instance	4th floor
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
LIGHTNING PROTECTION	
Does not exist	
LOCKER ROOM	
Instance on 1st floor - Girls	Inspected
Alternative Use	No
Instance on Basement - Boys	Inspected
Alternative Use	No
LIGHTING	
Instance on 1st floor - Girls	Inspected
Instance on Basement - Boys	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st floor - Girls	Inspected
Instance on Basement - Boys	Inspected
Pendant Mounted	
Instance on 1st floor - Girls	Does not exist
Instance on Basement - Boys	Does not exist
Recessed Mounted	
Instance on 1st floor - Girls	Does not exist
Instance on Basement - Boys	Does not exist
Surface Mounted	
Instance on 1st floor - Girls	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING

NYC Department of Education
 Building Condition Assessment Survey 2010-2011

Electrical Inspection

M435

Question	Response
LOCKER ROOM	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Basement - Boys	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	21
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on 1st floor - Girls	Does not exist
Instance on Basement - Boys	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st floor - Girls	Does not exist
Instance on Basement - Boys	Inspected
Pendant Mounted	
Instance on Basement - Boys	Does not exist
Recessed Mounted	
Instance on Basement - Boys	Does not exist
Surface Mounted	
Instance on Basement - Boys	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	26
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	26
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Mechanical Rooms
Deficiency Quantity	26
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
MOTOR STARTER/CONTACTOR	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
FUSED DISCONNECT SWITCH TYPE	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
FUSED KNIFE SWITCH TYPE	Does not exist
FUSED TOGGLE SWITCH TYPE	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	Inspected
Instance	Principals office (Room 149)
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Teac Telecor II
Deficiency	SPEAKER NOT OPERATIONAL
Deficiency Location/Instance	Classrooms, 1st Floor Gymnasium, Basement Gymnasium
Deficiency Quantity	14
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
SCIENCE DEMO ROOM	
Instance on Rooms 301, 302, 315, 378	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 316	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 323	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 381	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 304, 367	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 380	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
SCIENCE DEMO ROOM	
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Rooms 301, 302, 315, 378	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 316	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 323	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 381	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 304, 367	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 380	Inspected
Instance Condition	5- Poor
Deficiency	NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
EMERGENCY SHUT-OFF POWER	
Instance on Rooms 301, 302, 315, 378	Does not exist
Instance on Room 316	Does not exist
Instance on Room 323	Does not exist
Instance on Room 381	Does not exist
Instance on Room 304, 367	Does not exist
Instance on Room 380	Does not exist
LIGHTING	
Instance on Rooms 301, 302, 315, 378	Inspected
Instance on Room 316	Inspected
Instance on Room 323	Inspected
Instance on Room 381	Inspected
Instance on Room 304, 367	Inspected
Instance on Room 380	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms 301, 302, 315, 378	Inspected
Instance on Room 316	Inspected
Instance on Room 323	Inspected
Instance on Room 381	Inspected
Instance on Room 304, 367	Inspected
Instance on Room 380	Inspected
Pendant Mounted	
Instance on Rooms 301, 302, 315, 378	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	24
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
SCIENCE DEMO ROOM	
LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 316	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 323	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 381	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 304, 367	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 380	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Rooms 301, 302, 315, 378	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
SCIENCE DEMO ROOM	
LIGHTING	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Instance on Room 316	Does not exist
Instance on Room 323	Does not exist
Instance on Room 381	Does not exist
Instance on Room 304, 367	Does not exist
Instance on Room 380	Does not exist
Surface Mounted	
Instance on Rooms 301, 302, 315, 378	Does not exist
Instance on Room 316	Does not exist
Instance on Room 323	Does not exist
Instance on Room 381	Does not exist
Instance on Room 304, 367	Does not exist
Instance on Room 380	Does not exist
Lighting Fixture - HID	
Instance on Rooms 301, 302, 315, 378	Does not exist
Instance on Room 316	Does not exist
Instance on Room 323	Does not exist
Instance on Room 381	Does not exist
Instance on Room 304, 367	Does not exist
Instance on Room 380	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms 301, 302, 315, 378	Does not exist
Instance on Room 316	Does not exist
Instance on Room 323	Does not exist
Instance on Room 381	Does not exist
Instance on Room 304, 367	Does not exist
Instance on Room 380	Does not exist
POWER SUPPLY	
Instance on Rooms 301, 302, 315, 378	Inspected
Instance on Room 316	Inspected
Instance on Room 323	Inspected
Instance on Room 381	Inspected
Instance on Room 304, 367	Inspected
Instance on Room 380	Does not exist
Instructor Unit	
Instance on Rooms 301, 302, 315, 378	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 316	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 323	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 381	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 304, 367	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
SCIENCE DEMO ROOM	
POWER SUPPLY	
Meter Demonstration Unit	
Instance on Rooms 301, 302, 315, 378	Does not exist
Instance on Room 316	Does not exist
Instance on Room 323	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 381	Does not exist
Instance on Room 304, 367	Does not exist
PROJECTION SYSTEM	
Instance on Rooms 301, 302, 315, 378	Does not exist
Instance on Room 316	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 323	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 381	Does not exist
Instance on Room 304, 367	Does not exist
Instance on Room 380	Does not exist
SMART BOARD	
Instance on Rooms 301, 302, 315, 378	Does not exist
Instance on Room 316	Does not exist
Instance on Room 323	Does not exist
Instance on Room 381	Does not exist
Instance on Room 304, 367	Does not exist
Instance on Room 380	Does not exist
SCIENCE LAB	
Instance on Room 258	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 305	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 306	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 313	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 314	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 258	Does not exist
Instance on Room 305	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
SCIENCE LAB	
EMERGENCY GAS SHUT-OFF VALVE	
Deficiency	No deficiencies recorded
Instance on Room 306	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 313	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 314	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room 258	Does not exist
Instance on Room 305	Inspected
Instance Condition	5- Poor
Deficiency	NOT OPERATIONAL
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Instance on Room 306	Inspected
Instance Condition	5- Poor
Deficiency	NOT OPERATIONAL
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Instance on Room 313	Inspected
Instance Condition	5- Poor
Deficiency	NOT OPERATIONAL
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Instance on Room 314	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Room 258	Inspected
Instance on Room 305	Inspected
Instance on Room 306	Inspected
Instance on Room 313	Inspected
Instance on Room 314	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 258	Inspected
Instance on Room 305	Inspected
Instance on Room 306	Inspected
Instance on Room 313	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
SCIENCE LAB	
LIGHTING	
Lighting Fixture - Fluorescent	
Instance on Room 314	Inspected
Pendant Mounted	
Instance on Room 258	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	25
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 305	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 306	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 313	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 314	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 258	Does not exist
Instance on Room 305	Does not exist
Instance on Room 306	Does not exist
Instance on Room 313	Does not exist
Instance on Room 314	Does not exist
Surface Mounted	
Instance on Room 258	Does not exist
Instance on Room 305	Does not exist
Instance on Room 306	Does not exist
Instance on Room 313	Does not exist
Instance on Room 314	Does not exist
Lighting Fixture - HID	
Instance on Room 258	Does not exist
Instance on Room 305	Does not exist
Instance on Room 306	Does not exist
Instance on Room 313	Does not exist
Instance on Room 314	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 258	Does not exist
Instance on Room 305	Inspected
Instance on Room 306	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
SCIENCE LAB	
LIGHTING	
Lighting Fixture - Incandescent	
Instance on Room 313	Does not exist
Instance on Room 314	Does not exist
Pendant Mounted	
Instance on Room 305	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 305	Does not exist
Surface Mounted	
Instance on Room 305	Does not exist
POWER SUPPLY	
Instance on Room 258	Does not exist
Instance on Room 305	Inspected
Instance on Room 306	Inspected
Instance on Room 313	Inspected
Instance on Room 314	Inspected
Instructor Unit	
Instance on Room 305	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 306	Does not exist
Instance on Room 313	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 314	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 305	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 306	Does not exist
Instance on Room 313	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 314	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Student Unit	
Instance on Room 305	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 306	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 313	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 314	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
SCIENCE LAB	
PROJECTION SYSTEM	
Instance on Room 258	Does not exist
Instance on Room 305	Does not exist
Instance on Room 306	Does not exist
Instance on Room 313	Does not exist
Instance on Room 314	Does not exist
SMART BOARD	
Instance on Room 258	Does not exist
Instance on Room 305	Does not exist
Instance on Room 306	Does not exist
Instance on Room 313	Does not exist
Instance on Room 314	Does not exist
SCIENCE PREP ROOM	
Instance on Room 307	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 311	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 312	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 307	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 311	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 312	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room 307	Does not exist
Instance on Room 311	Does not exist
Instance on Room 312	Does not exist
LIGHTING	
Instance on Room 307	Inspected
Instance on Room 311	Inspected
Instance on Room 312	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 307	Inspected
Instance on Room 311	Inspected
Instance on Room 312	Inspected

NYC Department of Education
Building Condition Assessment Survey 2010-2011

Electrical Inspection

M435

Question	Response
SCIENCE PREP ROOM	
LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Instance on Room 307	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 311	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 312	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 307	Does not exist
Instance on Room 311	Does not exist
Instance on Room 312	Does not exist
Surface Mounted	
Instance on Room 307	Does not exist
Instance on Room 311	Does not exist
Instance on Room 312	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Room 307	Does not exist
Instance on Room 311	Does not exist
Instance on Room 312	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 307	Does not exist
Instance on Room 311	Inspected
Instance on Room 312	Does not exist
Pendant Mounted	
Instance on Room 311	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room 311	Does not exist
Surface Mounted	
Instance on Room 311	Does not exist
POWER SUPPLY	
Instance on Room 307	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
SCIENCE PREP ROOM	
POWER SUPPLY	
Instance on Room 311	Inspected
Instance on Room 312	Inspected
Instructor Unit	
Instance on Room 307	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 311	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 312	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SECURITY	
INTRUSION ALARM	
Central Control Panel	
Instance	Inspected
Instance Condition	Custodians office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista 128B
Deficiency	No deficiencies recorded
Infrared Sensor	
Condition	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	
Condition	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	
Condition	Inspected
Condition	3- Fair
Deficiency	ANNUNCIATOR NOT OPERATIONAL
Deficiency Location/Instance	In Stair 6
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
Siren/Stroke	
Condition	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	
Condition	Inspected
Condition	3- Fair
Deficiency	SENSOR NOT IN USE
Deficiency Location/Instance	Kitchen
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
SECURITY	
INTRUSION ALARM	
Ultrasonic Sensor	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
IPDVS/CCTV SYSTEM	
Condition	Inspected
Deficiency	1- Good
SERVICE SWITCH	
Instance	Inspected
Instance Condition	Electrical Room (Room B56)
Instance Quantity	2- Between Good and Fair
Instance Quantity Uom	1
Manufacturer	EACH
EquipmentId	All City Switchboard
Capacity/Size	Main Switchboard 1A
Source of Capacity/Size	1200 Amps
Installation Year	Nameplate
Source of Installation Year	1995
Deficiency	Documented
Instance	No deficiencies recorded
Instance Condition	Electrical Room (Room B56)
Instance Quantity	2- Between Good and Fair
Instance Quantity Uom	1
Manufacturer	EACH
EquipmentId	All City Switchboard
Capacity/Size	Main Switchboard 1B
Source of Capacity/Size	1200 Amps
Installation Year	Nameplate
Source of Installation Year	1995
Deficiency	Documented
Instance	No deficiencies recorded
SWIMMING POOL	
Does not exist	Does not exist
SWITCHBOARD	
Water Penetration In Electrical Room?	Inspected
Number of Spares	No
AIR CIRCUIT BREAKER TYPE	20
Does not exist	Does not exist
FUSED DISCONNECT SWITCH TYPE	
Instance	Inspected
Instance Condition	Electrical Room (Room B56)
Instance Quantity	2- Between Good and Fair
Instance Quantity Uom	1
Manufacturer	EACH
EquipmentId	All City Switchboard
Capacity/Size	N/A
Source of Capacity/Size	1200 Amps total, 4 sections
Installation Year	Service Switch Size
Source of Installation Year	1995
Deficiency	Documented
Deficiency Quantity	SWITCHBOARD ID IS MISSING
Quantity Uom	1
Potential Action	EACH
Urgency of Action	MAINTENANCE
Purpose of Action	PRIORITY 2
Violations	LEVEL 2
Deficiency	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
SWITCHBOARD	
FUSED DISCONNECT SWITCH TYPE	
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room (Room B10)
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard
EquipmentId	N/A
Capacity/Size	1200 Amps total, 4 sections
Source of Capacity/Size	Service Switch Size
Installation Year	1995
Source of Installation Year	Documented
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED KNIFE SWITCH TYPE	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	Does not exist
TELEPHONE	Inspected
PBX/INTERCOM	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
STANDARD	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
TOILET ROOM - STAFF	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	14
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TOILET ROOM - STUDENT	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M435

Question	Response
TOILET ROOM - STUDENT	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable System Exist?	Yes
Operational?	Yes
Master Antenna System Exist?	No
MAIN EQUIPMENT RACK	Does not exist