

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M506

School: EDWARD A. REYNOLDS WEST SIDE HS-M, 140 WEST 102 STREET, MANHATTAN, NY, 10025

InspectionId	Inspection Type	Time In	Last Edited
49532	ELECTRICAL	2008-11-05 08:39AM	2008-12-19 12:01PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Local Sound Systems Years: 2007 Systems: Exterior Lighting - Time Clock Years: 2008 Systems: CCTV System Years: Under Construction

Priority Condition

No condition recorded

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Condition	2- Between Good and Fair
Replacement Quantity	85,000
Replacement Uom	S.F.
Deficiency	No deficiencies recorded
CAFETERIA	Inspected
Instance	Basement
Lighting	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Does not exist
Recessed Mounted	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
Local Sound System	
Instance on Basement	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
CAFETERIA/MULTIPURPOSE ROOM	Does not exist
CITY FIRE ALARM SYSTEM	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M506

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
COMPUTER LAB	
	Inspected
Instance	Room 203
Has LAN/Modem access	Yes
Power Panel?	No
Instance	Room 227, 327
Has LAN/Modem access	Yes
Power Panel?	Yes
Lighting	
Instance on Room 203	Inspected
Instance on Room 227, 327	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 203	Inspected
Instance on Room 227, 327	Inspected
Pendant Mounted	
Instance on Room 203	Does not exist
Instance on Room 227, 327	Does not exist
Recessed Mounted	
Instance on Room 203	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 227, 327	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 203	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 227, 327	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room 203	Does not exist
Instance on Room 227, 327	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 203	Does not exist
Instance on Room 227, 327	Does not exist
Raceway With Receptacles	
Instance on Room 203	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M506

Question	Response
COMPUTER LAB	
Raceway With Receptacles	
Instance on Room 227, 327	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
ELECTRIC SERVICE SWITCH	
Instance	Inspected
Instance Condition	Electrical Room
Instance Quantity	2- Between Good and Fair
Instance Quantity Uom	1
Manufacturer	EACH
Model	Cutler-Hammer
EquipmentId	Cutler-Hammer
Capacity/Size	MAIN
Installation Year	4000 Amps
Deficiency	1999
	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	
	Does not exist
EMERGENCY GENERATOR SET	
Automatic Transfer Switch (ATS)	
Instance	Inspected
Instance Condition	Electrical Room
Instance Quantity	2- Between Good and Fair
Instance Quantity Uom	1
Manufacturer	EACH
EquipmentId	Onan
Capacity/Size	Transfer Switch (for Fire Alarm)
Installation Year	40 Amps
Deficiency	1999
	No deficiencies recorded
Instance	Electrical Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Onan
EquipmentId	Transfer Switch
Capacity/Size	600 Amps
Installation Year	1999
Deficiency	No deficiencies recorded
Battery Charger	
Instance	Inspected
Instance Condition	Room 313
Instance Quantity	2- Between Good and Fair
Instance Quantity Uom	1
Manufacturer	EACH
EquipmentId	Onan
Capacity/Size	Float Battery Charger
Installation Year	12 VDC
Deficiency	1999
	No deficiencies recorded
Diesel	
Instance	Inspected
Instance Condition	Roof
Instance Quantity	2- Between Good and Fair
Instance Quantity Uom	1
Manufacturer	EACH
EquipmentId	Onan
Capacity/Size	N/A
	187.5 kVA, 150 kW, 418.8 Amps

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M506

Question	Response
EMERGENCY GENERATOR SET	
Diesel	
Installation Year	1999
Deficiency	No deficiencies recorded
Natural Gas	
	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	
Condition	Inspected
Deficiency	2- Between Good and Fair
	No deficiencies recorded
EMERGENCY LIGHTING	
Battery Pack	
	Does not exist
Connected To Emergency Generator System	
Condition	Inspected
Deficiency	2- Between Good and Fair
	No deficiencies recorded
Connected To Emergency Light/Exit Light Panel	
Condition	Inspected
Deficiency	2- Between Good and Fair
	No deficiencies recorded
Relay Test Switch	
	Does not exist
EXIT LIGHT	
Battery Pack	
Condition	Inspected
Deficiency	2- Between Good and Fair
	No deficiencies recorded
Connected To Emergency Generator System	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	FIXTURE LENS MISSING
Deficiency Location/Instance	3rd Floor Corridor, Cafeteria
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Connected To Emergency Light/Exit Light Panel	
Condition	Inspected
Deficiency	2- Between Good and Fair
	No deficiencies recorded
FIRE ALARM SYSTEM	
Replacement Quantity	Inspected
Replacement Uom	85,000
	S.F.
Area Smoke Detector	
Condition	Inspected
Deficiency	2- Between Good and Fair
	No deficiencies recorded
Bell/Horn	
Condition	Inspected
Deficiency	2- Between Good and Fair
	No deficiencies recorded
Duct Smoke Detector	
Condition	Inspected
Deficiency	2- Between Good and Fair
	No deficiencies recorded
Elevator Recall	
Condition	Inspected
Deficiency	2- Between Good and Fair
	No deficiencies recorded
Fan Shutdown Control	
Condition	Inspected
Deficiency	2- Between Good and Fair
	No deficiencies recorded
Fire Alarm Digital Communicator	
	Does not exist
Fused Cutout Panel	
Condition	Inspected
	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M506

Question	Response
FIRE ALARM SYSTEM	
Fused Cutout Panel	
Deficiency	No deficiencies recorded
Heat Detector	
Condition	Inspected
Deficiency	2- Between Good and Fair
Magnetic Door Holder Contactor	
Condition	Inspected
Deficiency	2- Between Good and Fair
Main Panel	
Condition	Inspected
Bell At Panel	
Condition	Inspected
Deficiency	2- Between Good and Fair
Fire Alarm Control Panel (Electronic)	
Instance	No deficiencies recorded
Instance Condition	Inspected
Instance Quantity	Lobby
Instance Quantity Uom	2- Between Good and Fair
Manufacturer	1
Model	EACH
EquipmentId	Edwards Systems Technology
Capacity/Size	EST-2
Installation Year	Fire Alarm Control Panel
Deficiency	12 zones
Fire Alarm Control Panel (Standard)	
Condition	1999
Deficiency	No deficiencies recorded
Manual Pull Station	
Condition	Does not exist
Deficiency	Inspected
Remote Annunciator	
Condition	Inspected
Display Monitor	
Condition	Inspected
Deficiency	5- Poor
Deficiency Location/Instance	MONITOR NOT OPERATIONAL
Deficiency Quantity	General Office
Quantity Uom	1
Potential Action	EACH
Urgency of Action	REPLACE
Purpose of Action	PRIORITY 5
Violations	LEVEL 2
Panel	
Condition	No violations recorded
Deficiency	Inspected
Printer	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Punch Register	
Condition	Does not exist
Sprinkler Flow/Air Pressure Switch	
Condition	Inspected
Deficiency	2- Between Good and Fair
Strobe	
Condition	No deficiencies recorded
Deficiency	Inspected
Sub-Panel	
Condition	Does not exist
Tamper Flow Switch/Chain	
Condition	Inspected
Deficiency	2- Between Good and Fair

NYC Department of Education
 Building Condition Assessment Survey 2008-2009

Electrical Inspection

M506

Question	Response
FIRE ALARM SYSTEM	
Tamper Flow Switch/Chain	
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	
Instance	Inspected
Instance	Basement
Lighting	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Does not exist
Recessed Mounted	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Basement	Does not exist
Lighting Fixture - HID	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
Local Sound System	
Instance on Basement	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Scoreboard	
Instance on Basement	Inspected
Instance Condition	5- Poor
Deficiency	NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Theater Lighting System	
Instance on Basement	Inspected
Dimming System	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M506

Question	Response
GYMNASIUM	
Theater Lighting System	
Theater Lighting	
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	Inspected
Elevator	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Holding Area	Does not exist
KITCHEN/WARMING PANTRY	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
LAN	Inspected
Local Distribution Frame (I/LDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	Room 100
Has LAN/Modem access	Yes
Lighting	
Instance on Room 100	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 100	Inspected
Pendant Mounted	
Instance on Room 100	Does not exist
Recessed Mounted	
Instance on Room 100	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 100	Does not exist
Lighting Fixture - HID	
Instance on Room 100	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 100	Does not exist
Raceway With Receptacles	
Instance on Room 100	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIGHTING - EXTERIOR SECURITY	Inspected
Condition	1- Good
Replacement Quantity	38
Replacement Uom	EACH
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M506

Question	Response
LIGHTNING PROTECTION	Does not exist
LOCKER ROOM/SHOWER ROOM	Inspected
Instance	Basement - Gym (Boys and Girls)
Alternative Use	No
Lighting	
Instance on Basement - Gym (Boys and Girls)	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement - Gym (Boys and Girls)	Inspected
Pendant Mounted	
Instance on Basement - Gym (Boys and Girls)	Does not exist
Recessed Mounted	
Instance on Basement - Gym (Boys and Girls)	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Basement - Gym (Boys and Girls)	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Basement - Gym (Boys and Girls)	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement - Gym (Boys and Girls)	Does not exist
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	Inspected
Replacement Quantity	85,000
Replacement Uom	S.F.
Instance	General Office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Rauland Telecenter 2100
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Corridor
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SPEAKER NOT OPERATIONAL
Deficiency Location/Instance	Custodian Office, Room 210
Deficiency Quantity	2

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M506

Question	Response
PUBLIC ADDRESS SYSTEM	
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
SCIENCE DEMO ROOM	
	Inspected
Instance	Room 214, 216
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance	Room 218
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on Room 214, 216	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 218	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 214, 216	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 218	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting	
Instance on Room 214, 216	Inspected
Instance on Room 218	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 214, 216	Inspected
Instance on Room 218	Inspected
Pendant Mounted	
Instance on Room 214, 216	Does not exist
Instance on Room 218	Does not exist
Recessed Mounted	
Instance on Room 214, 216	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 218	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 214, 216	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 218	Does not exist
Lighting Fixture - HID	
Instance on Room 214, 216	Does not exist
Instance on Room 218	Does not exist
Lighting Fixture - Incandescent	

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M506

Question	Response
SCIENCE DEMO ROOM	
Lighting	
Lighting Fixture - Incandescent	
Instance on Room 214, 216	Does not exist
Instance on Room 218	Does not exist
Power Supply	
Instance on Room 214, 216	Inspected
Instance on Room 218	Inspected
Instructor Unit	
Instance on Room 214, 216	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 218	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 214, 216	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 218	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE LAB	
Instance	Inspected
Instance	Room 202
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance	Room 210
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on Room 202	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 210	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 202	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 210	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting	
Instance on Room 202	Inspected
Instance on Room 210	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 202	Inspected
Instance on Room 210	Inspected
Pendant Mounted	
Instance on Room 202	Does not exist
Instance on Room 210	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M506

Question	Response
SCIENCE LAB	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Instance on Room 202	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 210	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 202	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 210	Does not exist
Lighting Fixture - HID	
Instance on Room 202	Does not exist
Instance on Room 210	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 202	Does not exist
Instance on Room 210	Does not exist
Power Supply	
Instance on Room 202	Inspected
Instance on Room 210	Inspected
Instructor Unit	
Instance on Room 202	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 210	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 202	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 210	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Student Unit	
Instance on Room 202	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 210	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE PREP ROOM	
Instance	Room 206
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on Room 206	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M506

Question	Response
SCIENCE PREP ROOM	
Emergency Shut-Off Power	
Instance on Room 206	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting	
Instance on Room 206	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 206	Inspected
Pendant Mounted	
Instance on Room 206	Does not exist
Recessed Mounted	
Instance on Room 206	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 206	Does not exist
Lighting Fixture - HID	
Instance on Room 206	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 206	Does not exist
Power Supply	
Instance on Room 206	Inspected
Instructor Unit	
Instance on Room 206	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SECURITY	Inspected
Replacement Quantity	85,000
Replacement Uom	S.F.
Intrusion Alarm	Inspected
Central Control Panel	Inspected
Instance	Custodian Office
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Ademco Vista 50P
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	Does not exist
IPDVS/CCTV System	Under construction
SWIMMING POOL	Does not exist
SWITCHBOARD	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

M506

Question	Response
SWITCHBOARD	
Air Circuit Breaker Type	Does not exist
Fused Disconnect Switch Type	Inspected
Instance	Electrical Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Cutler-Hammer
EquipmentId	N/A
Capacity/Size	4000 Amps total, 3 sections
Installation Year	1999
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Does not exist
TELEPHONE	Inspected
PBX/Intercom	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable Service	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Main Equipment Rack	Does not exist
Master Antenna System	Inspected
Condition	2- Between Good and Fair

NYC Department of Education
Building Condition Assessment Survey 2008-2009

Electrical Inspection

M506

Question	Response
TV SYSTEM	
Master Antenna System	
Deficiency	No deficiencies recorded