

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

School: **PARK WEST HS (ECF) - MANHATTAN, 525 WEST 50 STREET, MANHATTAN, NY, 10019**

InspectionId	Inspection Type	Time In	Last Edited
1570069	ELECTRICAL	2010-12-15 08:32AM	2011-05-06 10:46AM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Partial Panel Boards Years: 1998, 2007, 2010 Systems: Local Sound Systems in Auditorium, Cafeteria and Gymnasium Years: 2009 Systems: Auxiliary Bell System Years: 2010 Systems: Fire Alarm System Years: Under Construction Systems: Elevator Intercom System Years: Under Construction Systems: Lighting in the Library Years: 2009 Systems: Science Labs (Rooms 139,308 and 360), Computer Room G39, Gymnasiums Lighting and Auditorium Lighting Years: 2009 Systems: Partial General Interior Lighting Years: 2002, 2009 Systems: Public Address System Years: 2010 Systems: Emergency /Exit Light Panel and Emergency Lights and Exit Lights Years: 2000 Systems: Most Motor Starters and CCTV Years: 2005 Systems: Projector in Auditorium and Theater Lighting Years: 2003 Systems: Science Lab Room G 54 Years: 2007 Systems: Exit/Emergency Light Years: 2007
Type of Service	Below Ground

**Priority Condition**

No condition recorded

**Inspection**

Question	Response
<b>ELECTRICAL</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance	1st floor
<b>HOUSE LIGHTING</b>	
Instance on 1st floor	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st floor	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st floor	Inspected
Instance Condition	1- Good

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

Question	Response
<b>AUDITORIUM</b>	
<b>HOUSE LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Recessed Mounted</b>	
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on 1st floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st floor	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on 1st floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>PROJECTION SYSTEM</b>	
Instance on 1st floor	Inspected
Instance Condition	2- Between Good and Fair
Is the projector on a cart or installed on the ceiling?	Cart
Deficiency	No deficiencies recorded
<b>THEATER LIGHTING SYSTEM</b>	
Instance on 1st floor	Inspected
<b>Dimming System</b>	
Instance on 1st floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Theater Lighting</b>	
Instance on 1st floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>CAFETERIA</b>	
Instance	Inspected
Instance	Rooms 200 and 250
<b>LIGHTING</b>	
Instance on Rooms 200 and 250	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Rooms 200 and 250	Inspected
<b>Pendant Mounted</b>	
Instance on Rooms 200 and 250	Does not exist
<b>Recessed Mounted</b>	
Instance on Rooms 200 and 250	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	338
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

<b>Question</b>	<b>Response</b>
<b>CAFETERIA</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Recessed Mounted</b>	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on Rooms 200 and 250	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Rooms 200 and 250	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Rooms 200 and 250	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on Rooms 200 and 250	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>CITY FIRE ALARM SYSTEM</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	889
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

Question	Response
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Recessed Mounted</b>	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1,180
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	125
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	45
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

Question	Response
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Pendant Mounted</b>	
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Does not exist
<b>SMART BOARD</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>COMPUTER LAB</b>	Inspected
Instance	Room 349
Has LAN/Modem access	Yes
Power Panel?	No
Instance	Room G39
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Rooms 239, 351 and 459
Has LAN/Modem access	Yes
Power Panel?	Yes
<b>LIGHTING</b>	
Instance on Room 349	Inspected
Instance on Room G39	Inspected
Instance on Rooms 239, 351 and 459	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 349	Inspected
Instance on Room G39	Inspected
Instance on Rooms 239, 351 and 459	Inspected
<b>Pendant Mounted</b>	
Instance on Room 349	Does not exist
Instance on Room G39	Does not exist
Instance on Rooms 239, 351 and 459	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 349	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	25
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

<b>Question</b>	<b>Response</b>
<b>COMPUTER LAB</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Recessed Mounted</b>	
Instance on Room G39	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Rooms 239, 351 and 459	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	80
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on Room 349	Does not exist
Instance on Room G39	Does not exist
Instance on Rooms 239, 351 and 459	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 349	Does not exist
Instance on Room G39	Does not exist
Instance on Rooms 239, 351 and 459	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 349	Does not exist
Instance on Room G39	Does not exist
Instance on Rooms 239, 351 and 459	Does not exist
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room 349	Does not exist
Instance on Room G39	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Rooms 239, 351 and 459	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	
<b>EMERGENCY GENERATOR SET</b>	
<b>AUTOMATIC TRANSFER SWITCH (ATS)</b>	
Instance	Room MG01C in Basement
Instance Condition	3- Fair
Instance Quantity	2
Instance Quantity Uom	EACH
Manufacturer	ONAN
EquipmentId	N/A
Capacity/Size	60 Amps
Installation Year	1977
Source of Installation Year	Documented
Deficiency	ATS ID MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

<b>Question</b>	<b>Response</b>
<b>EMERGENCY GENERATOR SET</b>	
<b>AUTOMATIC TRANSFER SWITCH (ATS)</b>	
Violations	No violations recorded
Instance	Room MG01D in Basement
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ONAN
EquipmentId	N/A
Capacity/Size	1200 Amps
Installation Year	1977
Source of Installation Year	Documented
Deficiency	ATS ID MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>BATTERY CHARGER</b>	Inspected
Instance	Room MG01D in Basement
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ONAN
EquipmentId	Battery Charger
Capacity/Size	6 Amps DC, 24 VDC
Installation Year	1977
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>DIESEL</b>	Inspected
Instance	Room MG01D in Basement
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	Emergency Generator
Capacity/Size	N/A
Installation Year	1977
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>NATURAL GAS</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	Inspected
<b>BATTERY PACK</b>	Inspected
Condition	3- Fair
Deficiency	FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Front of Large Gymnasium
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

<b>Question</b>	<b>Response</b>
<b>EMERGENCY LIGHTING</b>	
<b>Non Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	Inspected
<b>BATTERY PACK</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Kitchen, G level stair D, Auditorium and Front of Room 227D)
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>EXIT/EMERGENCY LIGHT</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>FIRE ALARM SYSTEM</b>	Under construction
<b>GROUNDING SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	Inspected
Instance	5th floor - Large
Instance	5th floor -Small
<b>LIGHTING</b>	
Instance on 5th floor - Large	Inspected
Instance on 5th floor -Small	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 5th floor - Large	Inspected
Instance on 5th floor -Small	Inspected
<b>Pendant Mounted</b>	
Instance on 5th floor - Large	Does not exist
Instance on 5th floor -Small	Does not exist
<b>Recessed Mounted</b>	
Instance on 5th floor - Large	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on 5th floor -Small	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on 5th floor - Large	Does not exist
Instance on 5th floor -Small	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 5th floor - Large	Does not exist
Instance on 5th floor -Small	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 5th floor - Large	Does not exist
Instance on 5th floor -Small	Does not exist
<b>LOCAL SOUND SYSTEM</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

<b>Question</b>	<b>Response</b>
<b>GYMNASIUM</b>	
<b>LOCAL SOUND SYSTEM</b>	
Instance on 5th floor - Large	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on 5th floor -Small	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>SCOREBOARD</b>	
Instance on 5th floor - Large	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on 5th floor -Small	Does not exist
<b>THEATER LIGHTING SYSTEM</b>	
Instance on 5th floor - Large	Does not exist
Instance on 5th floor -Small	Does not exist
<b>INTERCOM SYSTEM</b>	
	Inspected
<b>ELEVATOR</b>	
	Under construction
<b>HOLDING AREA</b>	
	Does not exist
<b>KITCHEN/WARMING PANTRY</b>	
	Inspected
Instance	Room 254
<b>LIGHTING</b>	
Instance on Room 254	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 254	Inspected
<b>Pendant Mounted</b>	
Instance on Room 254	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 254	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	50
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE POORLY MOUNTED
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on Room 254	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 254	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 254	Does not exist
<b>LAN</b>	
	Inspected
<b>LOCAL DISTRIBUTION FRAME (I/LDF)</b>	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

<b>Question</b>	<b>Response</b>
<b>LAN</b>	
<b>MAIN EQUIPMENT RACK (MDF)</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>LIBRARY</b>	Inspected
Instance	Room 275
Has LAN/Modem access	Yes
<b>LIGHTING</b>	
Instance on Room 275	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 275	Inspected
<b>Pendant Mounted</b>	
Instance on Room 275	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 275	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on Room 275	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 275	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 275	Does not exist
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room 275	Does not exist
<b>SMART BOARD</b>	
Instance on Room 275	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>LIGHTING - SECURITY LIGHTS</b>	Inspected
Condition	3- Fair
Replacement Quantity	61
Replacement Uom	EACH
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Entrance
Deficiency Quantity	55
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 3
Violations	No violations recorded
<b>LIGHTNING PROTECTION</b>	Does not exist
<b>LOCKER ROOM</b>	
Instance on Rooms 509 Large Gym, 509 Small Gym and Room 555	Inspected
Alternative Use	No
Instance on Room 569B	Inspected
Alternative Use	Yes
<b>LIGHTING</b>	
Instance on Rooms 509 Large Gym, 509 Small Gym and Room 555	Inspected
Instance on Room 569B	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Rooms 509 Large Gym, 509 Small Gym and Room 555	Inspected
Instance on Room 569B	Inspected
<b>Pendant Mounted</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

Question	Response
<b>LOCKER ROOM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Instance on Rooms 509 Large Gym, 509 Small Gym and Room 555	Does not exist
Instance on Room 569B	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Rooms 509 Large Gym, 509 Small Gym and Room 555	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	86
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 569B	Does not exist
<b>Surface Mounted</b>	
Instance on Rooms 509 Large Gym, 509 Small Gym and Room 555	Does not exist
Instance on Room 569B	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Rooms 509 Large Gym, 509 Small Gym and Room 555	Does not exist
Instance on Room 569B	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Rooms 509 Large Gym, 509 Small Gym and Room 555	Does not exist
Instance on Room 569B	Does not exist
<b>MOTOR CONTROL CENTER</b>	
Instance	Room M523
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	N/A
Capacity/Size	N/A
Installation Year	1977
Source of Installation Year	Documented
Deficiency	MCC ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

<b>Question</b>	<b>Response</b>
<b>MOTOR CONTROL CENTER</b>	
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	MCC INDICATOR LIGHT NOT OPERATIONAL
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	MCC NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Room M503
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Metropolitan Electric
EquipmentId	N/A
Capacity/Size	N/A, 6 sections
Installation Year	1977
Source of Installation Year	Documented
Deficiency	MCC ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	MCC NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Fan Rooms
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MULTIPURPOSE ROOM</b>	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>FUSED DISCONNECT SWITCH TYPE</b>	Inspected
Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

<b>Question</b>	<b>Response</b>
<b>PANEL BOARD</b>	
<b>FUSED DISCONNECT SWITCH TYPE</b>	
Deficiency	No deficiencies recorded
<b>FUSED KNIFE SWITCH TYPE</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>FUSED TOGGLE SWITCH TYPE</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	PANEL BOARD COVER IS MISSING
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>PUBLIC ADDRESS SYSTEM</b>	
Instance	Inspected
Instance Condition	Room 227 D
Instance Quantity	1- Good
Instance Quantity Uom	1
Model	EACH
Model	Rauland Telecenter
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Most Classrooms
Deficiency Quantity	100
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SCIENCE DEMO ROOM</b>	
Instance on Rooms 423, 429, 431 and 435	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Rooms 329, 331 and 338	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Rooms 336, 333 and 425	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Rooms 423, 429, 431 and 435	Does not exist
Instance on Rooms 329, 331 and 338	Does not exist
Instance on Rooms 336, 333 and 425	Does not exist
<b>EMERGENCY SHUT-OFF POWER</b>	
Instance on Rooms 423, 429, 431 and 435	Does not exist
Instance on Rooms 329, 331 and 338	Does not exist
Instance on Rooms 336, 333 and 425	Does not exist
<b>LIGHTING</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>LIGHTING</b>	
Instance on Rooms 423, 429, 431 and 435	Inspected
Instance on Rooms 329, 331 and 338	Inspected
Instance on Rooms 336, 333 and 425	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Rooms 423, 429, 431 and 435	Inspected
Instance on Rooms 329, 331 and 338	Inspected
Instance on Rooms 336, 333 and 425	Inspected
<b>Pendant Mounted</b>	
Instance on Rooms 423, 429, 431 and 435	Does not exist
Instance on Rooms 329, 331 and 338	Does not exist
Instance on Rooms 336, 333 and 425	Does not exist
<b>Recessed Mounted</b>	
Instance on Rooms 423, 429, 431 and 435	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	84
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Rooms 329, 331 and 338	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	58
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Rooms 336, 333 and 425	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	60
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

Question	Response
<b>SCIENCE DEMO ROOM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Recessed Mounted</b>	
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on Rooms 423, 429, 431 and 435	Does not exist
Instance on Rooms 329, 331 and 338	Does not exist
Instance on Rooms 336, 333 and 425	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Rooms 423, 429, 431 and 435	Does not exist
Instance on Rooms 329, 331 and 338	Does not exist
Instance on Rooms 336, 333 and 425	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Rooms 423, 429, 431 and 435	Inspected
Instance on Rooms 329, 331 and 338	Inspected
Instance on Rooms 336, 333 and 425	Does not exist
<b>Pendant Mounted</b>	
Instance on Rooms 423, 429, 431 and 435	Does not exist
Instance on Rooms 329, 331 and 338	Does not exist
<b>Recessed Mounted</b>	
Instance on Rooms 423, 429, 431 and 435	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Rooms 329, 331 and 338	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on Rooms 423, 429, 431 and 435	Does not exist
Instance on Rooms 329, 331 and 338	Does not exist
<b>POWER SUPPLY</b>	
Instance on Rooms 423, 429, 431 and 435	Does not exist
Instance on Rooms 329, 331 and 338	Does not exist
Instance on Rooms 336, 333 and 425	Does not exist
<b>PROJECTION SYSTEM</b>	
Instance on Rooms 423, 429, 431 and 435	Does not exist
Instance on Rooms 329, 331 and 338	Does not exist
Instance on Rooms 336, 333 and 425	Does not exist
<b>SMART BOARD</b>	
Instance on Rooms 423, 429, 431 and 435	Does not exist
Instance on Rooms 329, 331 and 338	Inspected
Instance Condition	1- Good

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>SMART BOARD</b>	
Deficiency	No deficiencies recorded
Instance on Rooms 336, 333 and 425	Does not exist
<b>SCIENCE LAB</b>	
Instance on Room 426	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	Yes
Instance on Rooms 308 and 360	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 139	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 438	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Rooms 320 and 326	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 420	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room G54	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Room 426	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Rooms 308 and 360	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 139	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 438	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 320 and 326	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 420	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room G54	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>EMERGENCY SHUT-OFF POWER</b>	
Instance on Room 426	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Rooms 308 and 360	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 139	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 438	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 320 and 326	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 420	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room G54	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>LIGHTING</b>	
Instance on Room 426	Inspected
Instance on Rooms 308 and 360	Inspected
Instance on Room 139	Inspected
Instance on Room 438	Inspected
Instance on Rooms 320 and 326	Inspected
Instance on Room 420	Inspected
Instance on Room G54	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 426	Inspected
Instance on Rooms 308 and 360	Inspected
Instance on Room 139	Inspected
Instance on Room 438	Inspected
Instance on Rooms 320 and 326	Inspected
Instance on Room 420	Inspected
Instance on Room G54	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Instance on Room 426	Does not exist
Instance on Rooms 308 and 360	Does not exist
Instance on Room 139	Does not exist
Instance on Room 438	Does not exist
Instance on Rooms 320 and 326	Does not exist
Instance on Room 420	Does not exist
Instance on Room G54	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 426	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	30
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Rooms 308 and 360	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 139	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 438	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	30
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Rooms 320 and 326	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Recessed Mounted</b>	
Deficiency Quantity	60
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 420	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	31
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room G54	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on Room 426	Does not exist
Instance on Rooms 308 and 360	Does not exist
Instance on Room 139	Does not exist
Instance on Room 438	Does not exist
Instance on Rooms 320 and 326	Does not exist
Instance on Room 420	Does not exist
Instance on Room G54	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 426	Does not exist
Instance on Rooms 308 and 360	Does not exist
Instance on Room 139	Does not exist
Instance on Room 438	Does not exist
Instance on Rooms 320 and 326	Does not exist
Instance on Room 420	Does not exist
Instance on Room G54	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 426	Inspected
Instance on Rooms 308 and 360	Does not exist
Instance on Room 139	Inspected
Instance on Room 438	Inspected
Instance on Rooms 320 and 326	Inspected
Instance on Room 420	Does not exist
Instance on Room G54	Does not exist
<b>Pendant Mounted</b>	
Instance on Room 426	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Pendant Mounted</b>	
Instance on Room 139	Does not exist
Instance on Room 438	Does not exist
Instance on Rooms 320 and 326	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 426	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 139	Does not exist
Instance on Room 438	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Rooms 320 and 326	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on Room 426	Does not exist
Instance on Room 139	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 438	Does not exist
Instance on Rooms 320 and 326	Does not exist
<b>POWER SUPPLY</b>	
Instance on Room 426	Inspected
Instance on Rooms 308 and 360	Inspected
Instance on Room 139	Inspected
Instance on Room 438	Inspected
Instance on Rooms 320 and 326	Inspected
Instance on Room 420	Inspected
Instance on Room G54	Inspected
<b>Instructor Unit</b>	
Instance on Room 426	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>POWER SUPPLY</b>	
<b>Instructor Unit</b>	
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Rooms 308 and 360	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 139	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 438	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 320 and 326	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 420	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room G54	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Meter Demonstration Unit</b>	
Instance on Room 426	Does not exist
Instance on Rooms 308 and 360	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 139	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 438	Does not exist
Instance on Rooms 320 and 326	Does not exist
Instance on Room 420	Does not exist
Instance on Room G54	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Student Unit</b>	
Instance on Room 426	Does not exist
Instance on Rooms 308 and 360	Does not exist
Instance on Room 139	Does not exist
Instance on Room 438	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 320 and 326	Does not exist
Instance on Room 420	Does not exist
Instance on Room G54	Does not exist
<b>PROJECTION SYSTEM</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>PROJECTION SYSTEM</b>	
Instance on Room 426	Does not exist
Instance on Rooms 308 and 360	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 139	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 438	Does not exist
Instance on Rooms 320 and 326	Does not exist
Instance on Room 420	Does not exist
Instance on Room G54	Does not exist
<b>SMART BOARD</b>	
Instance on Room 426	Does not exist
Instance on Rooms 308 and 360	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 139	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 438	Does not exist
Instance on Rooms 320 and 326	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 420	Does not exist
Instance on Room G54	Does not exist
<b>SCIENCE PREP ROOM</b>	
Instance on Rooms 330A, 330B, 330, 430B, 430 and 434	Inspected
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	No
Instance on Room 430 A	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Rooms 330A, 330B, 330, 430B, 430 and 434	Does not exist
Instance on Room 430 A	Does not exist
<b>EMERGENCY SHUT-OFF POWER</b>	
Instance on Rooms 330A, 330B, 330, 430B, 430 and 434	Does not exist
Instance on Room 430 A	Does not exist
<b>LIGHTING</b>	
Instance on Rooms 330A, 330B, 330, 430B, 430 and 434	Inspected
Instance on Room 430 A	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Rooms 330A, 330B, 330, 430B, 430 and 434	Inspected
Instance on Room 430 A	Does not exist
<b>Pendant Mounted</b>	
Instance on Rooms 330A, 330B, 330, 430B, 430 and 434	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	83

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

<b>Question</b>	<b>Response</b>
<b>SCIENCE PREP ROOM</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Rooms 330A, 330B, 330, 430B, 430 and 434	Does not exist
<b>Surface Mounted</b>	
Instance on Rooms 330A, 330B, 330, 430B, 430 and 434	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Rooms 330A, 330B, 330, 430B, 430 and 434	Does not exist
Instance on Room 430 A	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Rooms 330A, 330B, 330, 430B, 430 and 434	Does not exist
Instance on Room 430 A	Inspected
<b>Pendant Mounted</b>	
Instance on Room 430 A	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 430 A	Does not exist
<b>Surface Mounted</b>	
Instance on Room 430 A	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>POWER SUPPLY</b>	
Instance on Rooms 330A, 330B, 330, 430B, 430 and 434	Does not exist
Instance on Room 430 A	Does not exist
<b>SECURITY</b>	Inspected
<b>INTRUSION ALARM</b>	Inspected
<b>Central Control Panel</b>	Inspected
Instance	Custodian's Office
Instance Condition	5- Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista 50P
Deficiency	PANEL NOT OPERATIONAL
Deficiency Location/Instance	Custodian's Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
<b>Infrared Sensor</b>	Inspected
Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

Question	Response
<b>SECURITY</b>	
<b>INTRUSION ALARM</b>	
<b>Infrared Sensor</b>	
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>Ultrasonic Sensor</b>	
Condition	Does not exist
<b>IPDVS/CCTV SYSTEM</b>	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>SERVICE SWITCH</b>	
Instance	Inspected
Instance	Room MGO1C- Basement
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Metropolitan Electric
EquipmentId	Serv SW.
Capacity/Size	3000 Amps
Source of Capacity/Size	Fuse Size
Installation Year	1977
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Room MGO1C- Basement
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Metropolitan Electric
EquipmentId	Serv SW for Swbd 1
Capacity/Size	3000 Amps
Source of Capacity/Size	Fuse Size
Installation Year	1977
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Room MGO1C- Basement
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific
EquipmentId	N/A
Capacity/Size	4000 Amps
Source of Capacity/Size	Nameplate
Installation Year	1977
Source of Installation Year	Documented
Deficiency	SWITCH ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

<b>Question</b>	<b>Response</b>
<b>SERVICE SWITCH</b>	
Violations	No violations recorded
<b>SWIMMING POOL</b>	Does not exist
<b>SWITCHBOARD</b>	Inspected
Water Penetration In Electrical Room?	No
Number of Spares	6
<b>AIR CIRCUIT BREAKER TYPE</b>	Does not exist
<b>FUSED DISCONNECT SWITCH TYPE</b>	Inspected
Instance	Room MG01C - Basement
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Metropolitan Electric
EquipmentId	N/A
Capacity/Size	3000 Amps total, 6 Sections
Source of Capacity/Size	Service Switch Fuse Size
Installation Year	1977
Source of Installation Year	Documented
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Room MG01C - Basement
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Metropolitan Electric
EquipmentId	Switchboard #1
Capacity/Size	3000 Amps total, 5 Sections
Source of Capacity/Size	Service Switch Fuse Size
Installation Year	1977
Source of Installation Year	Documented
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Room MG45 - Basement
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Metropolitan Electric
EquipmentId	Switchboard #3
Capacity/Size	4000 Amps total, 7 Sections
Source of Capacity/Size	Service Switch Size

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**M535**

<b>Question</b>	<b>Response</b>
<b>SWITCHBOARD</b>	
<b>FUSED DISCONNECT SWITCH TYPE</b>	
Installation Year	1977
Source of Installation Year	Documented
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Room MG01D - Basement (Generator Switchboard)
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Metropolitan Electric
EquipmentId	Emergency Distribution Panel
Capacity/Size	1600 Amps total, 3 sections
Source of Capacity/Size	Switchboard Mains Size
Installation Year	1977
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>FUSED KNIFE SWITCH TYPE</b>	Does not exist
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	Does not exist
<b>TELEPHONE</b>	Inspected
<b>PBX/INTERCOM</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	TELEPHONE NOT OPERATIONAL
Deficiency Location/Instance	1st floor Classes
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE TELEPHONE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>STANDARD</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>TOILET ROOM - STAFF</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	30
Quantity Uom	EACH

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

***Electrical Inspection***

**M535**

<b>Question</b>	<b>Response</b>
<b>TOILET ROOM - STAFF</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Recessed Mounted</b>	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	54
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TRANSFORMER</b>	Does not exist
<b>TV SYSTEM</b>	Inspected
Cable System Exist?	Yes
Operational?	Yes
Master Antenna System Exist?	No
<b>MAIN EQUIPMENT RACK</b>	Does not exist