

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

School: PARK WEST HS (ECF) - MANHATTAN, 525 WEST 50 STREET, MANHATTAN, NY, 10019

| InspectionId | Inspection Type | Time In | Last Edited |
|--------------|-----------------|--------------------|--------------------|
| 1640102 | MECHANICAL | 2010-12-15 08:13AM | 2011-04-20 11:40AM |

Asset Data

| Question | Answer |
|---|---|
| Have any Systems/Major Building Components been upgraded? | Systems: Chilled Water System for Auditorium, Cafeteria including DDC System, Fan Coil Units for 3rd & 4th Floor Classrooms (20), Terminal Unit Thermostatic Traps, Boiler Safety valves, Condensate Return System (2/5), Air Handling Units (2/33) Years: 2006 Systems: DX Split System for Rooms 370, 375, 470, 475 & GO 5, 7, 9, 11, 117, Air Handling Units (9/33), Sump Pumps, Sewage Ejector Pumps (2/4). Years: 2007 Systems: Science Rooms 139, 308, 360, G54 Years: 2008 Systems: Compressor for Climate Control System with Refrigerated Air Dryers. Years: 2009 |
| Are there fuel tanks? | Yes |
| Total # of above ground tanks | 2 |
| Total capacity of all above ground tanks in gal. | 40,000 |
| Total # of below ground tanks | 0 |
| Total capacity of all below ground tanks in gal. | 0 |

Priority Condition

No condition recorded

Inspection

| Question | Response |
|-----------------------------|--------------------------|
| MECHANICAL | |
| AIR CONDITIONING | Inspected |
| CHILLED WATER SYSTEM | Inspected |
| Absorption Chiller | Inspected |
| Instance | Penthouse |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | York |
| EquipmentId | # 1 |
| Capacity/Size | 750 Tons |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | Penthouse |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | York |
| EquipmentId | #2 |
| Capacity/Size | 750 Tons |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | Lower Roof (West Side) |
| Instance Condition | 1- Good |
| Instance Quantity | 1 |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|------------------------------------|--------------------------|
| AIR CONDITIONING | |
| CHILLED WATER SYSTEM | |
| Absorption Chiller | |
| Instance Quantity Uom | EACH |
| Manufacturer | Yazaki |
| EquipmentId | CHILLER 1 |
| Capacity/Size | 60 Tons(720000 BTU/ Hr) |
| Installation Year | 2006 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | Lower Roof (west Side) |
| Instance Condition | 1- Good |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | Yazaki |
| EquipmentId | CHILLER 2 |
| Capacity/Size | 60 Tons(720000 BTU/Hr) |
| Installation Year | 2006 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Air Cooled Chiller | Does not exist |
| Air Cooled Condenser | Does not exist |
| Air Separator | Inspected |
| Condition | 1- Good |
| Deficiency | No deficiencies recorded |
| Backflow Preventer | Inspected |
| Condition | 1- Good |
| Deficiency | No deficiencies recorded |
| Central Station Air Handler | Inspected |
| Instance | MER MG01B |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | AAF |
| EquipmentId | HVAC-1 |
| Capacity/Size | 12,300 CFM |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER MG01B |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | AAF |
| EquipmentId | HVAC-2 |
| Capacity/Size | 25,400 CFM |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER M503 |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | AAF |
| EquipmentId | HVAC-15 |
| Capacity/Size | 9,620 CFM |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|------------------------------------|--------------------------|
| AIR CONDITIONING | |
| CHILLED WATER SYSTEM | |
| Central Station Air Handler | |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER M503 |
| Instance Condition | 1- Good |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | YORK |
| EquipmentId | HVAC-14 |
| Capacity/Size | 10,500 CFM |
| Installation Year | 2007 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MFR M503 |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | AAF |
| EquipmentId | HVAC-13 |
| Capacity/Size | N/A |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER M503 |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | AAF |
| EquipmentId | HVAC-11 |
| Capacity/Size | 3,800 CFM |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER MG01B |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | AAF |
| EquipmentId | HVAC-12 |
| Capacity/Size | 4,990 CFM |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER MG01B |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | AAF |
| EquipmentId | HVAC-10 |
| Capacity/Size | 5,150 CFM |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|------------------------------------|--------------------------|
| AIR CONDITIONING | |
| CHILLED WATER SYSTEM | |
| Central Station Air Handler | |
| Instance | MER MG 01B |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | AAF |
| EquipmentId | HVAC-9 |
| Capacity/Size | 8,970 CFM |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER MG01B |
| Instance Condition | 1- Good |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | YORK |
| EquipmentId | HVAC-8 |
| Capacity/Size | 14,600 CFM |
| Installation Year | 2007 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER MG01B |
| Instance Condition | 1- Good |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | YORK |
| EquipmentId | HVAC-7 |
| Capacity/Size | 16,400 CFM |
| Installation Year | 2007 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER MG01B |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | AAF |
| EquipmentId | HVAC-6 |
| Capacity/Size | 16,800 CFM |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER MG01B |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | AAF |
| EquipmentId | HVAC-5 |
| Capacity/Size | 5,740 CFM |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER MG01B |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|------------------------------------|--------------------------|
| AIR CONDITIONING | |
| CHILLED WATER SYSTEM | |
| Central Station Air Handler | |
| Instance Quantity Uom | EACH |
| Manufacturer | AAF |
| EquipmentId | HVAC- 4 |
| Capacity/Size | 4,780 CFM |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER MG01B |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | AAF |
| EquipmentId | HVAC-3 |
| Capacity/Size | 6,200 CFM |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER MG01B |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | AAF |
| EquipmentId | HVAC-18 |
| Capacity/Size | 2,680 CFM |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER MG01B |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | AAF |
| EquipmentId | HVAC-19 |
| Capacity/Size | 10,920 CFM |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER MG01B |
| Instance Condition | 1- Good |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | YORK |
| EquipmentId | HVAC-29 |
| Capacity/Size | 5,500 CFM |
| Installation Year | 2007 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER MG01B |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | AAF |
| EquipmentId | HVAC-20 |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|------------------------------------|--------------------------|
| AIR CONDITIONING | |
| CHILLED WATER SYSTEM | |
| Central Station Air Handler | |
| Capacity/Size | 8,460 CFM |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER MG01B |
| Instance Condition | 1- Good |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | YORK |
| EquipmentId | HVAC-32 |
| Capacity/Size | 9,048 CFM |
| Installation Year | 2007 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER MG01B |
| Instance Condition | 1- Good |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | YORK |
| EquipmentId | HVAC-33 |
| Capacity/Size | 9,048 CFM |
| Installation Year | 2007 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER M557A |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | AAF |
| EquipmentId | HVAC-26 |
| Capacity/Size | 3,600 CFM |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER 161A |
| Instance Condition | 1- Good |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | McQuay |
| EquipmentId | AHU-1 |
| Capacity/Size | 6,000 CFM |
| Installation Year | 2006 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER M523 |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | AAF |
| EquipmentId | HVAC-24 |
| Capacity/Size | 12,490 CFM |
| Installation Year | 1977 |
| Source of Installation Year | Documented |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|------------------------------------|--------------------------|
| AIR CONDITIONING | |
| CHILLED WATER SYSTEM | |
| Central Station Air Handler | |
| Deficiency | No deficiencies recorded |
| Instance | MER M523 |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | AAF |
| EquipmentId | HVAC-23 |
| Capacity/Size | 8,820 CFM |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER M523 |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | AAF |
| EquipmentId | HVAC-22 |
| Capacity/Size | 9,060 CFM |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER M503 |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | AAF |
| EquipmentId | HVAC-17 |
| Capacity/Size | 5,200 CFM |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER M503 |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | AAF |
| EquipmentId | HVAC-16 |
| Capacity/Size | 5,200 CFM |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER MG51 |
| Instance Condition | 1- Good |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | YORK |
| EquipmentId | HVAC-31 |
| Capacity/Size | 5,000 CFM |
| Installation Year | 2007 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER MG49 |
| Instance Condition | 3- Fair |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|------------------------------------|------------------------------------|
| AIR CONDITIONING | |
| CHILLED WATER SYSTEM | |
| Central Station Air Handler | |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | AAF |
| EquipmentId | HVAC-21 |
| Capacity/Size | 4,000 CFM |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER MG47 |
| Instance Condition | 1- Good |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | YORK |
| EquipmentId | HVAC-25 |
| Capacity/Size | 3,140 CFM |
| Installation Year | 2007 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER MG20D |
| Instance Condition | 1- Good |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | YORK |
| EquipmentId | HVAC-30 |
| Capacity/Size | 13, 322 CFM |
| Installation Year | 2007 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | MER 161A |
| Instance Condition | 1- Good |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | McQuay |
| EquipmentId | AHU-2 |
| Capacity/Size | 4,000 CFM |
| Installation Year | 2006 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Chilled Water Piping | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | DAMAGED/MISSING INSULATION |
| Deficiency Location/Instance | Penthouse (Chiller #1 & # 2) |
| Deficiency Quantity | 30 |
| Quantity Uom | L.F. |
| Potential Action | MAINTENANCE |
| Urgency of Action | PRIORITY 3 |
| Purpose of Action | LEVEL 2 |
| Violations | No violations recorded |
| Chilled Water Pump | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | BEYOND USEFUL LIFE - NON DEFECTIVE |
| Deficiency Location/Instance | Penthouse (2 of 4) |
| Deficiency Quantity | 2 |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|--|------------------------------|
| AIR CONDITIONING | |
| CHILLED WATER SYSTEM | |
| Chilled Water Pump | |
| Quantity Uom | EACH |
| Potential Action | REPLACE |
| Urgency of Action | PRIORITY 1 |
| Purpose of Action | LEVEL 2 |
| Violations | No violations recorded |
| Chiller Emergency Stop Switch | |
| | Does not exist |
| Cold Water Piping (A/C Make-up) | |
| | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Expansion Tank | |
| | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Fan Coil Unit | |
| | Inspected |
| Condition | 1- Good |
| Deficiency | No deficiencies recorded |
| Packaged Air Cooled Chiller | |
| | Does not exist |
| Water Cooled Chiller | |
| | Does not exist |
| CONDENSER WATER PIPING | |
| | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| CONDENSER WATER PUMP | |
| | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| COOLING COILS IN DUCTWORK | |
| | Does not exist |
| COOLING TOWER | |
| | Inspected |
| Instance | Roof |
| Instance Condition | 5- Poor |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | Marvel |
| EquipmentId | N /A |
| Capacity/Size | 750 Tons |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | OVER 350 TONS:DEFECTIVE UNIT |
| Deficiency Quantity | 1 |
| Quantity Uom | EACH |
| Potential Action | REPLACE |
| Urgency of Action | PRIORITY 3 |
| Purpose of Action | LEVEL 2 |
| Violations | No violations recorded |
| Instance | Lower Roof (West Side) |
| Instance Condition | 1- Good |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | B.A.C. |
| EquipmentId | N/A |
| Capacity/Size | 120 Tons |
| Installation Year | 2006 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| DX SPLIT SYSTEM | |
| | Inspected |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|---|--|
| AIR CONDITIONING | |
| DX SPLIT SYSTEM | |
| Indoor Unit | Inspected |
| Condition | 1- Good |
| Deficiency | No deficiencies recorded |
| Outdoor Unit | Inspected |
| Condition | 1- Good |
| Deficiency | No deficiencies recorded |
| PACKAGED / ROOFTOP UNIT | Does not exist |
| PACKAGED TERMINAL A/C | Does not exist |
| REFRIGERANT PIPING | Inspected |
| Condition | 1- Good |
| Deficiency | No deficiencies recorded |
| RETURN FAN | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| CENTRAL ACID WASTE NEUTRALIZING TANK | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| CLIMATE CONTROL SYSTEM | Inspected |
| DDC SYSTEM | Inspected |
| Instance | Auditorium, Cafeteria and some Classrooms on 3rd and 4th Floors. |
| Instance Condition | 4- Between Fair and Poor |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Building Area Covered by Operational System | 0-20% |
| Deficiency | DEFECTIVE |
| Deficiency Location/Instance | Custodian's Office (Inoperable: Defective Computer) |
| Deficiency Quantity | 1 |
| Quantity Uom | EACH |
| Potential Action | REPAIR |
| Urgency of Action | PRIORITY 3 |
| Purpose of Action | LEVEL 2 |
| Violations | No violations recorded |
| ELECTRIC SYSTEM | Does not exist |
| HYBRID SYSTEM | Does not exist |
| PNEUMATIC SYSTEM | Inspected |
| Instance | Throughout |
| Instance Condition | 2- Between Good and Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Building Area Covered by Operational System | 81-100% |
| Deficiency | No deficiencies recorded |
| COMPACTOR | Does not exist |
| CONVEYING | Inspected |
| ASH HOIST | Does not exist |
| DUMBWAITERS | Inspected |
| Condition | 3- Fair |
| Deficiency | NOT IN USE |
| Deficiency Location/Instance | Room 223 |
| Deficiency Quantity | 1 |
| Quantity Uom | EACH |
| Potential Action | NO ACTION |
| Urgency of Action | PRIORITY 1 |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|--|--------------------------------|
| CONVEYING | |
| DUMBWAITERS | |
| Purpose of Action | LEVEL 1 |
| Violations | No violations recorded |
| ELEVATORS | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| ESCALATORS | Does not exist |
| Non-auditorium Handicap Lift - Stair | Does not exist |
| Non-auditorium Handicap Lift - Vertical | Does not exist |
| SIDEWALK ELEVATOR | Does not exist |
| DOMESTIC WATER SYSTEM | Inspected |
| DOMESTIC COLD WATER SYSTEM | Inspected |
| Gravity System | Does not exist |
| Pressure Booster System | Inspected |
| Electric Pressure Booster System | Inspected |
| Instance | MER MG01B (For Hot Water only) |
| Instance Condition | 4- Between Fair and Poor |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Manufacturer | Peerless |
| EquipmentId | N/A |
| Capacity/Size | 2 Pumps 5 HP each |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | PRE-CHARGED TANK RUSTY/LEAK |
| Deficiency Location/Instance | MER MG 01B |
| Deficiency Quantity | 1 |
| Quantity Uom | EACH |
| Potential Action | REPLACE |
| Urgency of Action | PRIORITY 3 |
| Purpose of Action | LEVEL 2 |
| Violations | No violations recorded |
| Hydraulic/Pneumatic Booster System | Inspected |
| Domestic Cold Water Tank | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Pressure Booster Pump | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Water Pressure Booster - Compressor | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Water Service | Inspected |
| Service Piping (Water Main) | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Water Main - Double Check Valve | Does not exist |
| Water Main - RPZ | Does not exist |
| DOMESTIC HOT WATER SYSTEM | Inspected |
| Domestic Hot Water Circulating Pump | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Domestic Hot Water Remote Storage Tank | Does not exist |
| Domestic Water Heat Exchanger | Inspected |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|--|------------------------------------|
| DOMESTIC WATER SYSTEM | |
| DOMESTIC HOT WATER SYSTEM | |
| Domestic Water Heat Exchanger | |
| Condition | 4- Between Fair and Poor |
| Deficiency | DAMAGED/MISSING INSULATION |
| Deficiency Location/Instance | MER MG01B (2 Units) |
| Deficiency Quantity | 400 |
| Quantity Uom | S.F. |
| Potential Action | REPLACE |
| Urgency of Action | PRIORITY 3 |
| Purpose of Action | LEVEL 2 |
| Violations | No violations recorded |
| Electric Domestic Water Heater | Does not exist |
| Gas Fired Domestic Water Heater | Does not exist |
| Oil Fired Domestic Water Heater | Does not exist |
| DOMESTIC WATER DISTRIBUTION PIPING | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| DRAIN/WASTE/VENT AND STORM SYSTEM | Inspected |
| HOUSE TRAP | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| INTERIOR FLOOR DRAIN | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| INTERIOR STORM PIPING | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| SEWAGE / WASTE PIPING | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| SEWAGE EJECTOR PUMP | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | BEYOND USEFUL LIFE - NON DEFECTIVE |
| Deficiency Location/Instance | Room G19 |
| Deficiency Quantity | 2 |
| Quantity Uom | EACH |
| Potential Action | REPLACE |
| Urgency of Action | PRIORITY 1 |
| Purpose of Action | LEVEL 2 |
| Violations | No violations recorded |
| SUMP PUMP | Inspected |
| Condition | 1- Good |
| Deficiency | No deficiencies recorded |
| VENT PIPING | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER) | Does not exist |
| FIXTURES | Inspected |
| STAFF AND OTHER | Inspected |
| Janitor Sink | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Lavatory/Sink | Inspected |
| Condition | 3- Fair |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|-------------------------------------|---|
| FIXTURES | |
| STAFF AND OTHER | |
| Lavatory/Sink | |
| Deficiency | No deficiencies recorded |
| Toilet | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Urinal | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| STUDENT | Inspected |
| Drinking Fountain | Inspected |
| Condition | 3- Fair |
| Deficiency | DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.) |
| Deficiency Location/Instance | 4th Floor Hallway near Exit E |
| Deficiency Quantity | 1 |
| Quantity Uom | EACH |
| Potential Action | MAINTENANCE |
| Urgency of Action | PRIORITY 3 |
| Purpose of Action | LEVEL 2 |
| Violations | No violations recorded |
| Lavatory/Sink | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Locker Room Shower | |
| Instance on Rooms 509 | Inaccessible |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Instance on Room 555 | Inspected |
| Instance Condition | 3- Fair |
| Instance Quantity | 1 |
| Instance Quantity Uom | EACH |
| Alternative Use | Yes |
| Deficiency | NOT IN USE |
| Deficiency Location/Instance | Room 555 |
| Deficiency Quantity | 1 |
| Quantity Uom | EACH |
| Potential Action | NO ACTION |
| Urgency of Action | PRIORITY 1 |
| Purpose of Action | LEVEL 1 |
| Violations | No violations recorded |
| Sink And Fountain Combo Unit | Does not exist |
| Toilet | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Urinal | Inspected |
| Condition | 3- Fair |
| Deficiency | CRACKED/PHYSICAL DAMAGE |
| Deficiency Location/Instance | Room 209B (Boys) |
| Deficiency Quantity | 1 |
| Quantity Uom | EACH |
| Potential Action | REPLACE |
| Urgency of Action | PRIORITY 3 |
| Purpose of Action | LEVEL 2 |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|--|--------------------------|
| FIXTURES | |
| STUDENT | |
| Urinal | |
| Violations | No violations recorded |
| GAS FIRED FURNACE | Does not exist |
| GAS SERVICE | Inspected |
| CO/GAS LEAK DETECTION | Does not exist |
| GAS DISTRIBUTION PIPING | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| GAS METER ROOM EXHAUST FAN | Inspected |
| Condition | 1- Good |
| Deficiency | No deficiencies recorded |
| GAS METER ROOM VENT | Inspected |
| Condition | 1- Good |
| Deficiency | No deficiencies recorded |
| GAS PRESSURE BOOSTER | Inspected |
| Instance | Lower Roof (West Side) |
| Instance Condition | 1- Good |
| Instance Quantity | 2 |
| Instance Quantity Uom | EACH |
| Manufacturer | Eclipse |
| EquipmentId | N/A |
| Capacity/Size | 5,400 SCFH each |
| Installation Year | 2006 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| HEATING | Inspected |
| BASEBOARD/FIN TUBE | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| HEATING COILS IN DUCTWORK | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| HYDRONIC HEATING | Inspected |
| Air Separator | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Expansion Tank | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Hot Water Heat Exchanger | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Hydronic Hot Water Circulating Pump | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Hydronic Hot Water Piping | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| RADIATOR / CONVECTOR | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| STEAM HEATING | Inspected |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|--|--------------------------|
| HEATING | |
| STEAM HEATING | |
| F&T/Steam Drip Trap | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| MER Steam and Condensate Piping | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Steam Condensate Return Piping | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Steam Condensate Return Pumping System | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Steam Piping | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Terminal Unit Thermostatic Trap | Inspected |
| Condition | 1- Good |
| Deficiency | No deficiencies recorded |
| STEAM SUPPLIED BY EXTERNAL SOURCES | Does not exist |
| UNIT HEATER/CABINET HEATER | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| HEATING PLANT | Inspected |
| Replacement Quantity | 41,272 |
| Replacement Uom | MBH |
| Instance | Basement |
| Burner Type | Oil |
| Heating Plant Oil Number | 6 |
| BOILER AUXILIARIES | |
| Instance on Basement | Inspected |
| Boiler Auxiliary Piping | |
| Instance on Basement | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Boiler Emergency Stop Switch | |
| Instance on Basement | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Boiler Feedwater System | |
| Instance on Basement | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Boiler Feedwater Treatment(Automatic) | |
| Instance on Basement | Does not exist |
| Boiler Flue Exhaust | |
| Instance on Basement | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Boiler Make-up Water Backflow Preventer | |
| Instance on Basement | Inspected |
| Instance Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|--|--------------------------|
| HEATING PLANT | |
| BOILER AUXILIARIES | |
| Boiler Room Steam And Condensate Piping | |
| Instance on Basement | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Boiler Safety Valve | |
| Instance on Basement | Inspected |
| Instance Condition | 1- Good |
| Deficiency | No deficiencies recorded |
| BOILER SYSTEM | |
| Instance on Basement | Inspected |
| Coal-fired Boiler | |
| Instance on Basement | Does not exist |
| Hot Water Boiler | |
| Instance on Basement | Does not exist |
| Modular Boiler | |
| Instance on Basement | Does not exist |
| Steam Boiler | |
| Instance on Basement | Inspected |
| Instance | Basement |
| Instance Condition | 3- Fair |
| Instance Quantity | 10,318 |
| Instance Quantity Uom | MBH |
| Manufacturer | Kewanee |
| EquipmentId | 66959-1 |
| Capacity/Size | 13,290 MBH(Gross) |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | Basement |
| Instance Condition | 3- Fair |
| Instance Quantity | 10,318 |
| Instance Quantity Uom | MBH |
| Manufacturer | Kewanee |
| EquipmentId | 66959-3 |
| Capacity/Size | 13,290 MBH (Gross) |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | Basement |
| Instance Condition | 3- Fair |
| Instance Quantity | 10,318 |
| Instance Quantity Uom | MBH |
| Manufacturer | Kewanee |
| EquipmentId | 66959-2 |
| Capacity/Size | 13,290 MBH (Gross) |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| Instance | Basement |
| Instance Condition | 3- Fair |
| Instance Quantity | 10,318 |
| Instance Quantity Uom | MBH |
| Manufacturer | Kewanee |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|--|---|
| HEATING PLANT | |
| BOILER SYSTEM | |
| Steam Boiler | |
| EquipmentId | 66959-4 |
| Capacity/Size | 13,290 MBH (Gross) |
| Installation Year | 1977 |
| Source of Installation Year | Documented |
| Deficiency | No deficiencies recorded |
| FUEL SYSTEMS | |
| Instance on Basement | Inspected |
| Boiler Fresh Air Louver/Damper | |
| Instance on Basement | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Burner/Burner Control Panel | |
| Instance on Basement | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | BURNER CONTROL PANEL:BEYOND USEFUL LIFE - NON DEFECTIVE |
| Deficiency Location/Instance | Boiler Room (Basement) |
| Deficiency Quantity | 4 |
| Quantity Uom | EACH |
| Potential Action | REPLACE |
| Urgency of Action | PRIORITY 1 |
| Purpose of Action | LEVEL 2 |
| Violations | No violations recorded |
| Deficiency | OIL BURNER:BEYOND USEFUL LIFE - NON DEFECTIVE |
| Deficiency Location/Instance | Boiler Room (Basement) |
| Deficiency Quantity | 4 |
| Quantity Uom | EACH |
| Potential Action | REPLACE |
| Urgency of Action | PRIORITY 1 |
| Purpose of Action | LEVEL 2 |
| Violations | No violations recorded |
| Fuel Oil Storage/Supply System | |
| Instance on Basement | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Gas Trains And Vent At The Boiler | |
| Instance on Basement | Does not exist |
| IDF (ENCLOSED ROOMS) | |
| Instance | Inspected |
| Instance | Closet M122 |
| Instance | Closets 160B, 424, 454, 324, 354 |
| A/C EQUIPMENT | |
| Instance on Closet M122 | Does not exist |
| Instance on Closets 160B, 424, 454, 324, 354 | Inspected |
| Instance Condition | 4- Between Fair and Poor |
| Deficiency | DOES NOT EXIST |
| Deficiency Location/Instance | Closets160B, 424, 454, 324, 354 |
| Deficiency Quantity | 5 |
| Quantity Uom | EACH |
| Potential Action | INSTALL |
| Urgency of Action | PRIORITY 3 |
| Purpose of Action | LEVEL 2 |
| Violations | No violations recorded |
| VENTILATION EQUIPMENT | |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|--|--------------------------|
| IDF (ENCLOSED ROOMS) | |
| VENTILATION EQUIPMENT | |
| Instance on Closet M122 | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Instance on Closets 160B, 424, 454, 324, 354 | Does not exist |
| KITCHEN | |
| Instance | Inspected |
| Instance | Room 254 |
| CO DETECTOR | |
| Instance on Room 254 | Inspected |
| Instance Condition | 1- Good |
| Deficiency | No deficiencies recorded |
| GAS SYSTEM | |
| Instance on Room 254 | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| GREASE TRAP | |
| Instance on Room 254 | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| HOOD | |
| Instance on Room 254 | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| HOOD EXHAUST DUCTWORK | |
| Instance on Room 254 | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| HOOD EXHAUST FAN | |
| Instance on Room 254 | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| HOOD FIRE SUPPRESSION SYSTEM | |
| Instance on Room 254 | Does not exist |
| HOT WATER TEMPERATURE BOOSTER | |
| Instance on Room 254 | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| KITCHEN SINK | |
| Instance on Room 254 | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| MDF ROOM | |
| Instance | Inspected |
| Instance | Rooms 547A, 251 |
| A/C EQUIPMENT | |
| Instance on Rooms 547A, 251 | Inspected |
| Instance Condition | 1- Good |
| Deficiency | No deficiencies recorded |
| VENTILATION EQUIPMENT | |
| Instance on Rooms 547A, 251 | Does not exist |
| SCIENCE DEMO ROOM | |
| Instance on Rooms 329,331, 333,336,338,425 | Inspected |
| Alternative Use | No |
| Instance on Rooms 429,431, 423, 435 | Inspected |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|--|--------------------------|
| SCIENCE DEMO ROOM | |
| Alternative Use | Yes |
| ACID WASTE NEUTRALIZING TANK | |
| Instance on Rooms 329,331, 333,336,338,425 | Does not exist |
| Instance on Rooms 429,431, 423, 435 | Does not exist |
| EMERGENCY SHOWER | |
| Instance on Rooms 329,331, 333,336,338,425 | Does not exist |
| Instance on Rooms 429,431, 423, 435 | Does not exist |
| EYE WASH | |
| Instance on Rooms 329,331, 333,336,338,425 | Does not exist |
| Instance on Rooms 429,431, 423, 435 | Does not exist |
| FIXED LABORATORY HOOD | |
| Instance on Rooms 329,331, 333,336,338,425 | Does not exist |
| Instance on Rooms 429,431, 423, 435 | Does not exist |
| LABORATORY SINK | |
| Instance on Rooms 329,331, 333,336,338,425 | Inspected |
| Instance Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Instance on Rooms 429,431, 423, 435 | Inspected |
| Instance Condition | 2- Between Good and Fair |
| Deficiency | NOT IN USE |
| Deficiency Location/Instance | Rooms 423, 429, 431, 435 |
| Deficiency Quantity | 4 |
| Quantity Uom | EACH |
| Potential Action | NO ACTION |
| Urgency of Action | PRIORITY 1 |
| Purpose of Action | LEVEL 1 |
| Violations | No violations recorded |
| PORTABLE LABORATORY HOOD | |
| Instance on Rooms 329,331, 333,336,338,425 | Does not exist |
| Instance on Rooms 429,431, 423, 435 | Does not exist |
| SCIENCE LAB | |
| Instance on Rooms 308,360, | Inspected |
| Alternative Use | No |
| Instance on Rooms 320, 326, 420,438 | Inspected |
| Alternative Use | No |
| Instance on Room 139 | Inspected |
| Alternative Use | No |
| Instance on Room 426 | Inspected |
| Alternative Use | Yes |
| Instance on Room G 54 | Inspected |
| Alternative Use | No |
| ACID WASTE NEUTRALIZING TANK | |
| Instance on Rooms 308,360, | Inspected |
| Instance Condition | 1- Good |
| Deficiency | No deficiencies recorded |
| Instance on Rooms 320, 326, 420,438 | Does not exist |
| Instance on Room 139 | Inspected |
| Instance Condition | 1- Good |
| Deficiency | No deficiencies recorded |
| Instance on Room 426 | Does not exist |
| Instance on Room G 54 | Inspected |
| Instance Condition | 1- Good |
| Deficiency | No deficiencies recorded |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|-------------------------------------|--------------------------|
| SCIENCE LAB | |
| CO DETECTOR | |
| Instance on Rooms 308,360, | Inspected |
| Instance Condition | 1- Good |
| Deficiency | No deficiencies recorded |
| Instance on Rooms 320, 326, 420,438 | Inspected |
| Instance Condition | 1- Good |
| Deficiency | No deficiencies recorded |
| Instance on Room 139 | Inspected |
| Instance Condition | 1- Good |
| Deficiency | No deficiencies recorded |
| Instance on Room 426 | Not required |
| Instance on Room G 54 | Inspected |
| Instance Condition | 1- Good |
| Deficiency | No deficiencies recorded |
| EMERGENCY SHOWER | |
| Instance on Rooms 308,360, | Does not exist |
| Instance on Rooms 320, 326, 420,438 | Does not exist |
| Instance on Room 139 | Does not exist |
| Instance on Room 426 | Does not exist |
| Instance on Room G 54 | Does not exist |
| EYE WASH | |
| Instance on Rooms 308,360, | Inspected |
| Instance Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Instance on Rooms 320, 326, 420,438 | Does not exist |
| Instance on Room 139 | Inspected |
| Instance Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Instance on Room 426 | Does not exist |
| Instance on Room G 54 | Inspected |
| Instance Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| FIXED LABORATORY HOOD | |
| Instance on Rooms 308,360, | Does not exist |
| Instance on Rooms 320, 326, 420,438 | Does not exist |
| Instance on Room 139 | Does not exist |
| Instance on Room 426 | Does not exist |
| Instance on Room G 54 | Does not exist |
| HOOD EXHAUST DUCTWORK | |
| Instance on Rooms 308,360, | Does not exist |
| Instance on Rooms 320, 326, 420,438 | Does not exist |
| Instance on Room 139 | Does not exist |
| Instance on Room 426 | Does not exist |
| Instance on Room G 54 | Does not exist |
| HOOD EXHAUST FAN | |
| Instance on Rooms 308,360, | Does not exist |
| Instance on Rooms 320, 326, 420,438 | Does not exist |
| Instance on Room 139 | Does not exist |
| Instance on Room 426 | Does not exist |
| Instance on Room G 54 | Does not exist |
| LABORATORY SINK | |
| Instance on Rooms 308,360, | Inspected |
| Instance Condition | 2- Between Good and Fair |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|-------------------------------------|--------------------------|
| SCIENCE LAB | |
| LABORATORY SINK | |
| Deficiency | No deficiencies recorded |
| Instance on Rooms 320, 326, 420,438 | Inspected |
| Instance Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Instance on Room 139 | Inspected |
| Instance Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Instance on Room 426 | Inspected |
| Instance Condition | 2- Between Good and Fair |
| Deficiency | NOT IN USE |
| Deficiency Location/Instance | Room 426 |
| Deficiency Quantity | 10 |
| Quantity Uom | EACH |
| Potential Action | NO ACTION |
| Urgency of Action | PRIORITY 1 |
| Purpose of Action | LEVEL 1 |
| Violations | No violations recorded |
| Instance on Room G 54 | Inspected |
| Instance Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| MAKE-UP AIR UNIT | |
| Instance on Rooms 308,360, | Does not exist |
| Instance on Rooms 320, 326, 420,438 | Does not exist |
| Instance on Room 139 | Does not exist |
| Instance on Room 426 | Does not exist |
| Instance on Room G 54 | Does not exist |
| PORTABLE LABORATORY HOOD | |
| Instance on Rooms 308,360, | Does not exist |
| Instance on Rooms 320, 326, 420,438 | Does not exist |
| Instance on Room 139 | Inspected |
| Instance Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Instance on Room 426 | Does not exist |
| Instance on Room G 54 | Inspected |
| Instance Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| SCIENCE PREP ROOM | |
| Instance on Room 330 | Inspected |
| Alternative Use | No |
| Instance on Rooms 330A, 330B | Inspected |
| Alternative Use | No |
| Instance on Room 430 | Inspected |
| Alternative Use | No |
| Instance on Room 430 A | Inspected |
| Alternative Use | No |
| Instance on Room 430 B | Inspected |
| Alternative Use | No |
| Instance on Room 434 | Inspected |
| Alternative Use | No |
| ACID WASTE NEUTRALIZING TANK | |
| Instance on Room 330 | Does not exist |
| Instance on Rooms 330A, 330B | Does not exist |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|-------------------------------------|--------------------------|
| SCIENCE PREP ROOM | |
| ACID WASTE NEUTRALIZING TANK | |
| Instance on Room 430 | Does not exist |
| Instance on Room 430 A | Does not exist |
| Instance on Room 430 B | Does not exist |
| Instance on Room 434 | Does not exist |
| EMERGENCY SHOWER | |
| Instance on Room 330 | Does not exist |
| Instance on Rooms 330A, 330B | Does not exist |
| Instance on Room 430 | Inspected |
| Instance Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Instance on Room 430 A | Does not exist |
| Instance on Room 430 B | Does not exist |
| Instance on Room 434 | Does not exist |
| EYE WASH | |
| Instance on Room 330 | Does not exist |
| Instance on Rooms 330A, 330B | Does not exist |
| Instance on Room 430 | Inspected |
| Instance Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Instance on Room 430 A | Does not exist |
| Instance on Room 430 B | Does not exist |
| Instance on Room 434 | Does not exist |
| FIXED LABORATORY HOOD | |
| Instance on Room 330 | Does not exist |
| Instance on Rooms 330A, 330B | Does not exist |
| Instance on Room 430 | Does not exist |
| Instance on Room 430 A | Does not exist |
| Instance on Room 430 B | Does not exist |
| Instance on Room 434 | Does not exist |
| HOOD EXHAUST DUCTWORK | |
| Instance on Room 330 | Does not exist |
| Instance on Rooms 330A, 330B | Does not exist |
| Instance on Room 430 | Does not exist |
| Instance on Room 430 A | Does not exist |
| Instance on Room 430 B | Does not exist |
| Instance on Room 434 | Does not exist |
| HOOD EXHAUST FAN | |
| Instance on Room 330 | Does not exist |
| Instance on Rooms 330A, 330B | Does not exist |
| Instance on Room 430 | Does not exist |
| Instance on Room 430 A | Does not exist |
| Instance on Room 430 B | Does not exist |
| Instance on Room 434 | Does not exist |
| LABORATORY SINK | |
| Instance on Room 330 | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Instance on Rooms 330A, 330B | Inspected |
| Instance Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Instance on Room 430 | Inspected |
| Instance Condition | 2- Between Good and Fair |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|---|------------------------------------|
| SCIENCE PREP ROOM | |
| LABORATORY SINK | |
| Deficiency | No deficiencies recorded |
| Instance on Room 430 A | Inspected |
| Instance Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Instance on Room 430 B | Inspected |
| Instance Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Instance on Room 434 | Inspected |
| Instance Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| MAKE-UP AIR UNIT | |
| Instance on Room 330 | Does not exist |
| Instance on Rooms 330A, 330B | Does not exist |
| Instance on Room 430 | Does not exist |
| Instance on Room 430 A | Does not exist |
| Instance on Room 430 B | Does not exist |
| Instance on Room 434 | Does not exist |
| PORTABLE LABORATORY HOOD | |
| Instance on Room 330 | Does not exist |
| Instance on Rooms 330A, 330B | Inspected |
| Instance Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| Instance on Room 430 | Does not exist |
| Instance on Room 430 A | Does not exist |
| Instance on Room 430 B | Does not exist |
| Instance on Room 434 | Does not exist |
| SPRINKLERS, STANDPIPE, FIRE SYSTEM | |
| | Inspected |
| DELUGE VALVE | |
| | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| FIRE BOOSTER PUMP ASSEMBLY | |
| | Inspected |
| Condition | 3- Fair |
| Deficiency | BEYOND USEFUL LIFE - NON DEFECTIVE |
| Deficiency Location/Instance | MER MG01A |
| Deficiency Quantity | 1 |
| Quantity Uom | EACH |
| Potential Action | REPLACE |
| Urgency of Action | PRIORITY 1 |
| Purpose of Action | LEVEL 2 |
| Violations | No violations recorded |
| ROOF TANK | |
| | Does not exist |
| SIAMESE CONNECTION | |
| | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| SPRINKLER ALARM VALVE ASSEMBLY | |
| | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| SPRINKLER HEAD | |
| | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| SPRINKLER PIPING | |
| | Inspected |
| Condition | 3- Fair |

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Mechanical Inspection

M535

| Question | Response |
|---|-----------------------------|
| SPRINKLERS, STANDPIPE, FIRE SYSTEM | |
| SPRINKLER PIPING | |
| Deficiency | No deficiencies recorded |
| STANDPIPE SYSTEM | Inspected |
| Hose Valve Assembly | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| Piping | Inspected |
| Condition | 3- Fair |
| Deficiency | No deficiencies recorded |
| WATER GONG | Does not exist |
| SWIMMING POOL | Does not exist |
| VENTILATION | Inspected |
| EXHAUST FAN | Inspected |
| Condition | 3- Fair |
| Deficiency | DEFECTIVE/DETERIORATED |
| Deficiency Location/Instance | Roof (1/15 O1d) |
| Deficiency Quantity | 1 |
| Quantity Uom | EACH |
| Potential Action | REPLACE |
| Urgency of Action | PRIORITY 3 |
| Purpose of Action | LEVEL 2 |
| Violations | No violations recorded |
| HEATING AND VENTILATING UNIT | Inspected |
| Condition | 2- Between Good and Fair |
| Deficiency | No deficiencies recorded |
| METAL DUCTWORK | Inspected |
| Condition | 3- Fair |
| Deficiency | DAMAGED FLEXIBLE CONNECTION |
| Deficiency Location/Instance | Roof (At Exhaust Fans) |
| Deficiency Quantity | 2 |
| Quantity Uom | EACH |
| Potential Action | REPLACE |
| Urgency of Action | PRIORITY 3 |
| Purpose of Action | LEVEL 2 |
| Violations | No violations recorded |
| SUPPLY FAN | Does not exist |
| UNIT VENTILATOR | Does not exist |