

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M660

School: SCHL OF THE FUTURE (OLD BACON) - M, 127 EAST 22 STREET, MANHATTAN, NY, 10010

InspectionId	Inspection Type	Time In	Last Edited
1570067	ELECTRICAL	2010-12-13 12:52PM	2011-05-09 05:50AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Gymnasium Lighting Years: Under Construction Systems: General Lighting (Fluorescent Lighting) Years: 2004 Systems: Science Demo, Prep and Lab Rooms Years: 2004 Systems: Security Lighting Years: 2006 and 2007 Systems: Score Board in The Gymnasium Years: 2007 Systems: Fire Alarm System Years: 2007 Systems: Telephone System Years: 2010 Systems: Intrusion Alarm System Years: 2001 Systems: Exit Lights Battery Packs Years: 2004-2005 Type of Service Below Ground

Priority Condition

Condition Description	Component Affected	Location Description	Person(s) Notified
Water Penetration in the Switchboard Room	Switchboard	Switchboard in Electrical Room in Basement.	Fireman: ROMELL PETERS

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	2nd floor
HOUSE LIGHTING	
Instance on 2nd floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on 2nd floor	Inspected
Pendant Mounted	
Instance on 2nd floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 2nd floor	Does not exist
Surface Mounted	
Instance on 2nd floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M660

Question	Response
AUDITORIUM	
HOUSE LIGHTING	
Lighting Fixture - HID	
Instance on 2nd floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 2nd floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 2nd floor	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
PROJECTION SYSTEM	
Instance on 2nd floor	Does not exist
THEATER LIGHTING SYSTEM	
Instance on 2nd floor	Inspected
Dimming System	
Instance on 2nd floor	Does not exist
Theater Lighting	
Instance on 2nd floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	24
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA	
Instance	9th floor
LIGHTING	
Instance on 9th floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 9th floor	Inspected
Pendant Mounted	
Instance on 9th floor	Does not exist
Recessed Mounted	
Instance on 9th floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M660

Question	Response
CAFETERIA	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Instance on 9th floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 9th floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 9th floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 9th floor	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
CITY FIRE ALARM SYSTEM	
Instance on 9th floor	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Instance on 9th floor	Inspected
LIGHTING	
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Pendant Mounted	
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on 9th floor	Does not exist
Lighting Fixture - Incandescent	
Pendant Mounted	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	12

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M660

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Lighting Fixture - Incandescent	
Pendant Mounted	
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SMART BOARD	Does not exist
COMPUTER LAB	Does not exist
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
BATTERY PACK	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
BATTERY PACK	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Auditorium and 2nd floor Corridor
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
AREA SMOKE DETECTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
BELL/HORN	Inspected
Condition	1- Good

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M660

Question	Response
FIRE ALARM SYSTEM	
BELL/HORN	
Deficiency	No deficiencies recorded
DUCT SMOKE DETECTOR	Does not exist
ELEVATOR RECALL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
FAN SHUTDOWN CONTROL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
FIRE ALARM DIGITAL COMMUNICATOR	Does not exist
FUSED CUTOFF PANEL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
HEAT DETECTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
MAGNETIC DOOR HOLDER CONTACTOR	Does not exist
MAIN PANEL	Inspected
Bell At Panel	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance Lobby
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards
Model	EST-2
EquipmentId	Fire Alarm Control Panel
Capacity/Size	15 zones
Installation Year	2007
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist
MANUAL PULL STATION	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
REMOTE ANNUNCIATOR	Inspected
Display Monitor	Does not exist
Panel	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Punch Register	Does not exist
SPRINKLER FLOW/AIR PRESSURE SWITCH	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
STROBE	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
SUB-PANEL	Does not exist
TAMPER FLOW SWITCH/CHAIN	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M660

Question	Response
FIRE ALARM SYSTEM	
TAMPER FLOW SWITCH/CHAIN	
Condition	1- Good
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	
Condition	Inspected
Deficiency	3- Fair
GYMNASIUM	
Instance	Inspected
Instance	10th floor
LIGHTING	
Instance on 10th floor	Under construction
LOCAL SOUND SYSTEM	
Instance on 10th floor	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SCOREBOARD	
Instance on 10th floor	Inspected
Instance Condition	5- Poor
Deficiency	NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
THEATER LIGHTING SYSTEM	
Instance on 10th floor	Does not exist
INTERCOM SYSTEM	
Instance	Inspected
ELEVATOR	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
HOLDING AREA	
Instance	Does not exist
KITCHEN/WARMING PANTRY	
Instance	Inspected
Instance	9th floor
LIGHTING	
Instance on 9th floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 9th floor	Inspected
Pendant Mounted	
Instance on 9th floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M660

Question	Response
KITCHEN/WARMING PANTRY	
LIGHTING	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Instance on 9th floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 9th floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 9th floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 9th floor	Does not exist
LAN	Inspected
LOCAL DISTRIBUTION FRAME (I/LDF)	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
MAIN EQUIPMENT RACK (MDF)	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	Room 101
Has LAN/Modem access	Yes
LIGHTING	
Instance on Room 101	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 101	Inspected
Pendant Mounted	
Instance on Room 101	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 101	Does not exist
Surface Mounted	
Instance on Room 101	Does not exist
Lighting Fixture - HID	
Instance on Room 101	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 101	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 101	Does not exist
SMART BOARD	
Instance on Room 101	Does not exist
LIGHTING - SECURITY LIGHTS	Inspected
Condition	3- Fair
Replacement Quantity	9
Replacement Uom	EACH
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Roof and 2nd Avenue Side
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 4

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M660

Question	Response
LIGHTING - SECURITY LIGHTS	
Purpose of Action	LEVEL 3
Violations	No violations recorded
LIGHTNING PROTECTION	
	Does not exist
LOCKER ROOM	
Instance on 11th floor - Girls	Inspected
Alternative Use	No
Instance on 10th floor - Boys	Inspected
Alternative Use	No
Instance on Basement - Boys	Inspected
Alternative Use	Yes
LIGHTING	
Instance on 11th floor - Girls	Inspected
Instance on 10th floor - Boys	Inspected
Instance on Basement - Boys	Inspected
Lighting Fixture - Fluorescent	
Instance on 11th floor - Girls	Inspected
Instance on 10th floor - Boys	Inspected
Instance on Basement - Boys	Inspected
Pendant Mounted	
Instance on 11th floor - Girls	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 10th floor - Boys	Does not exist
Instance on Basement - Boys	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 11th floor - Girls	Does not exist
Instance on 10th floor - Boys	Does not exist
Instance on Basement - Boys	Does not exist
Surface Mounted	
Instance on 11th floor - Girls	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on 10th floor - Boys	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Basement - Boys	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 11th floor - Girls	Does not exist
Instance on 10th floor - Boys	Does not exist
Instance on Basement - Boys	Does not exist
Lighting Fixture - Incandescent	
Instance on 11th floor - Girls	Inspected
Instance on 10th floor - Boys	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M660

Question	Response
LOCKER ROOM	
LIGHTING	
Lighting Fixture - Incandescent	
Instance on Basement - Boys	Does not exist
Pendant Mounted	
Instance on 11th floor - Girls	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 10th floor - Boys	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 11th floor - Girls	Does not exist
Instance on 10th floor - Boys	Does not exist
Surface Mounted	
Instance on 11th floor - Girls	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 10th floor - Boys	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Boiler Room and Fan Room
Deficiency Quantity	6
Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M660

Question	Response
MOTOR STARTER/CONTACTOR	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
FUSED DISCONNECT SWITCH TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Basement
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED KNIFE SWITCH TYPE	Does not exist
FUSED TOGGLE SWITCH TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MOLDED CASE CIRCUIT BREAKER TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Corridor and Assembly Areas
Deficiency Quantity	29
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	Inspected
Instance	Room 205
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Deficiency	MASTER CLOCK BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Room 205
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Room 205
Deficiency Quantity	75,000
Quantity Uom	S.F.

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M660

Question	Response
PUBLIC ADDRESS SYSTEM	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SCIENCE DEMO ROOM	
Instance on Rooms 401 and 503	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 403	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Rooms 401 and 503	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 403	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Rooms 401 and 503	Does not exist
Instance on Room 403	Does not exist
LIGHTING	
Instance on Rooms 401 and 503	Inspected
Instance on Room 403	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms 401 and 503	Inspected
Instance on Room 403	Inspected
Pendant Mounted	
Instance on Rooms 401 and 503	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 403	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Rooms 401 and 503	Does not exist
Instance on Room 403	Does not exist
Surface Mounted	
Instance on Rooms 401 and 503	Does not exist
Instance on Room 403	Does not exist
Lighting Fixture - HID	
Instance on Rooms 401 and 503	Does not exist
Instance on Room 403	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms 401 and 503	Does not exist
Instance on Room 403	Does not exist
POWER SUPPLY	
Instance on Rooms 401 and 503	Inspected
Instance on Room 403	Inspected
Instructor Unit	
Instance on Rooms 401 and 503	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M660

Question	Response
SCIENCE DEMO ROOM	
POWER SUPPLY	
Instructor Unit	
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 403	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Rooms 401 and 503	Does not exist
Instance on Room 403	Does not exist
PROJECTION SYSTEM	
Instance on Rooms 401 and 503	Does not exist
Instance on Room 403	Does not exist
SMART BOARD	
Instance on Rooms 401 and 503	Does not exist
Instance on Room 403	Does not exist
SCIENCE LAB	
Instance on Room-702	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 701	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 803	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 302	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room-702	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 701	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 803	Does not exist
Instance on Room 302	Does not exist
EMERGENCY SHUT-OFF POWER	
Instance on Room-702	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 701	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 803	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M660

Question	Response
SCIENCE LAB	
EMERGENCY SHUT-OFF POWER	
Instance on Room 302	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Room-702	Inspected
Instance on Room 701	Inspected
Instance on Room 803	Inspected
Instance on Room 302	Inspected
Lighting Fixture - Fluorescent	
Instance on Room-702	Inspected
Instance on Room 701	Inspected
Instance on Room 803	Inspected
Instance on Room 302	Inspected
Pendant Mounted	
Instance on Room-702	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 701	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 803	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 302	Does not exist
Recessed Mounted	
Instance on Room-702	Does not exist
Instance on Room 701	Does not exist
Instance on Room 803	Does not exist
Instance on Room 302	Does not exist
Surface Mounted	
Instance on Room-702	Does not exist
Instance on Room 701	Does not exist
Instance on Room 803	Does not exist
Instance on Room 302	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room-702	Does not exist
Instance on Room 701	Does not exist
Instance on Room 803	Does not exist
Instance on Room 302	Does not exist
Lighting Fixture - Incandescent	
Instance on Room-702	Does not exist
Instance on Room 701	Does not exist
Instance on Room 803	Does not exist
Instance on Room 302	Does not exist
POWER SUPPLY	
Instance on Room-702	Inspected
Instance on Room 701	Inspected
Instance on Room 803	Inspected
Instance on Room 302	Inspected
Instructor Unit	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M660

Question	Response
SCIENCE LAB	
POWER SUPPLY	
Instructor Unit	
Instance on Room-702	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 701	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 803	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 302	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room-702	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 701	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 803	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 302	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Student Unit	
Instance on Room-702	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 701	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 803	Does not exist
Instance on Room 302	Does not exist
PROJECTION SYSTEM	
Instance on Room-702	Does not exist
Instance on Room 701	Does not exist
Instance on Room 803	Does not exist
Instance on Room 302	Does not exist
SMART BOARD	
Instance on Room-702	Does not exist
Instance on Room 701	Does not exist
Instance on Room 803	Does not exist
Instance on Room 302	Does not exist
SCIENCE PREP ROOM	
Instance on Room 700	Inspected
Has LAN/Modem access	No
Power Panel?	Yes
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 700	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M660

Question	Response
SCIENCE PREP ROOM	
EMERGENCY GAS SHUT-OFF VALVE	
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room 700	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Room 700	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 700	Inspected
Pendant Mounted	
Instance on Room 700	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 700	Does not exist
Surface Mounted	
Instance on Room 700	Does not exist
Lighting Fixture - HID	
Instance on Room 700	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 700	Does not exist
POWER SUPPLY	
Instance on Room 700	Inspected
Instructor Unit	
Instance on Room 700	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SECURITY	
INTRUSION ALARM	
Central Control Panel	
Instance	Room 356
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Ademco Vista 128B
Deficiency	No deficiencies recorded
Infrared Sensor	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Panic Switch	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Remote Annunciator	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Siren/Strobe	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	
	Does not exist
IPDVS/CCTV SYSTEM	
	Does not exist
SERVICE SWITCH	
	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M660

Question	Response
SERVICE SWITCH	
Instance	Electrical Room in vicinity of Boys Locker Room - Basment
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific
EquipmentId	Main Switch
Capacity/Size	1600 Amps
Source of Capacity/Size	Nameplate
Installation Year	1962
Source of Installation Year	Documented
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SWIMMING POOL	Does not exist
SWITCHBOARD	Inspected
Water Penetration In Electrical Room?	Yes
Number of Spares	0
AIR CIRCUIT BREAKER TYPE	Does not exist
FUSED DISCONNECT SWITCH TYPE	Inspected
Instance	Electrical Room in vicinity of Boys Locker Room - Basment
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific
EquipmentId	N/A
Capacity/Size	1600 Amps total, 3 Sections
Source of Capacity/Size	Service Switch Size
Installation Year	1962
Source of Installation Year	Documented
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED KNIFE SWITCH TYPE	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	Inspected
Instance	Electrical Room in vicinity of Boys Locker Room - Basment
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ITE ELECTRICAL PRODUCTS
EquipmentId	N/A

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

M660

Question	Response
SWITCHBOARD	
MOLDED CASE CIRCUIT BREAKER TYPE	
Capacity/Size	600 Amps total, 1 section
Source of Capacity/Size	Switchboard Mains Size
Installation Year	1985
Source of Installation Year	Documented
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
TELEPHONE	Inspected
PBX/INTERCOM	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
STANDARD	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TOILET ROOM - STUDENT	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable System Exist?	Yes
Operational?	Yes
Master Antenna System Exist?	No
MAIN EQUIPMENT RACK	Does not exist