

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

School: **J.H.S. 25 - QUEENS, 34-65 192 STREET, QUEENS, NY, 11355**

InspectionId	Inspection Type	Time In	Last Edited
2080112	ELECTRICAL	2011-02-23 08:27AM	2011-04-20 10:50AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Telephone System, Exterior Lights, Fire Alarm System Years: 2009 Systems: Intrusion Alarm System Years: 1996 Systems: Public Address System, Local Area Network, Local Sound System Years: 2001 Systems: Panel Boards, Switchboard, Service Switch, Motor Starter/Contactor Years: 1970 Systems: Elevator Intercom System Years: 2007 Systems: IPDVS/CCTV System Years: Under Construction Systems: Emergency Lights and Exit Lights (Partial) Years: 2006 Systems: Fluorescent Lights in Toilet Rooms Years: 1995 Systems: Fluorescent Recessed Mounted Lights(Partial) Years: 1995 Systems: Smart-board Years: 2008 Systems: Science Room 362, 358, 360 Years: 2007 Type of Service Below Ground

Priority Condition

Condition Description	Component Affected	Location Description	Person(s) Notified
Not Operational	Fire Alarm Manual Pull Station	By Boys Locker Room	John Klieber (Custodian)

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	2nd Floor
HOUSE LIGHTING	
Instance on 2nd Floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on 2nd Floor	Inspected
Pendant Mounted	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

Question	Response
AUDITORIUM	
HOUSE LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Deficiency Quantity	36
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	72
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 2nd Floor	Does not exist
Lighting Fixture - HID	
Instance on 2nd Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 2nd Floor	Inspected
Pendant Mounted	
Instance on 2nd Floor	Does not exist
Recessed Mounted	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	34
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	6
Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

Question	Response
AUDITORIUM	
HOUSE LIGHTING	
Lighting Fixture - Incandescent	
Recessed Mounted	
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
LOCAL SOUND SYSTEM	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
PROJECTION SYSTEM	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	No deficiencies recorded
THEATER LIGHTING SYSTEM	
Instance on 2nd Floor	Inspected
Dimming System	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	DIMMING RACK BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Theater Lighting	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	49
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

Question	Response
AUDITORIUM	
THEATER LIGHTING SYSTEM	
Theater Lighting	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA	
Instance	Inspected
Instance	Basement- Students
Instance	B35- Staff
LIGHTING	
Instance on Basement- Students	Inspected
Instance on B35- Staff	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement- Students	Inspected
Instance on B35- Staff	Inspected
Pendant Mounted	
Instance on Basement- Students	Does not exist
Instance on B35- Staff	Does not exist
Recessed Mounted	
Instance on Basement- Students	Does not exist
Instance on B35- Staff	Does not exist
Surface Mounted	
Instance on Basement- Students	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	96
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on B35- Staff	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Basement- Students	Does not exist
Instance on B35- Staff	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement- Students	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

Question	Response
CAFETERIA	
LIGHTING	
Lighting Fixture - Incandescent	
Instance on B35- Staff	Does not exist
LOCAL SOUND SYSTEM	
Instance on Basement- Students	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on B35- Staff	Does not exist
CITY FIRE ALARM SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Inspected	Inspected
LIGHTING	
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Pendant Mounted	
Inspected	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	450
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	25
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Inspected	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	110
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	21
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	579
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	13
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	55
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Inspected
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Lighting Fixture - Incandescent	
Recessed Mounted	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	21
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SMART BOARD	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
COMPUTER LAB	Inspected
Instance	Room 262
Has LAN/Modem access	Yes
Power Panel?	Yes
LIGHTING	
Instance on Room 262	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 262	Inspected
Pendant Mounted	
Instance on Room 262	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

Question	Response
COMPUTER LAB	
LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Violations	No violations recorded
Recessed Mounted	
Instance on Room 262	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on Room 262	Does not exist
Lighting Fixture - HID	
Instance on Room 262	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 262	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 262	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
BATTERY PACK	Inspected
Condition	3- Fair
Deficiency	BATTERY NOT OPERATIONAL
Deficiency Location/Instance	2nd and 3rd Floor Corridor, Auditorium, By Fan Room 136
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE BATTERY
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Non Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	2nd Floor Corridor
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
EXIT LIGHT	Inspected
BATTERY PACK	Inspected
Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

Question	Response
EXIT LIGHT	
BATTERY PACK	
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
AREA SMOKE DETECTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
BELL/HORN	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
DUCT SMOKE DETECTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
ELEVATOR RECALL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
FAN SHUTDOWN CONTROL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
FIRE ALARM DIGITAL COMMUNICATOR	Does not exist
FUSED CUTOOUT PANEL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
HEAT DETECTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
MAGNETIC DOOR HOLDER CONTACTOR	Does not exist
MAIN PANEL	Inspected
Bell At Panel	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance Vestibule
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	GE
Model	EST 2
EquipmentId	Fire Alarm Control Panel
Capacity/Size	16 Zones
Installation Year	2009
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

Question	Response
FIRE ALARM SYSTEM	
MANUAL PULL STATION	Inspected
Condition	1- Good
Deficiency	PULL STATION NOT OPERATIONAL
Deficiency Location/Instance	By Boys Locker Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
REMOTE ANNUNCIATOR	Inspected
Display Monitor	Does not exist
Panel	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Punch Register	Does not exist
SPRINKLER FLOW/AIR PRESSURE SWITCH	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
STROBE	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
SUB-PANEL	Does not exist
TAMPER FLOW SWITCH/CHAIN	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	Inspected
Instance	Basement
LIGHTING	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Does not exist
Lighting Fixture - HID	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Does not exist
Recessed Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	32
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

Question	Response
GYMNASIUM	
LIGHTING	
Lighting Fixture - HID	
Surface Mounted	
Violations	No violations recorded
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
LOCAL SOUND SYSTEM	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SCOREBOARD	
Instance on Basement	Does not exist
THEATER LIGHTING SYSTEM	
Instance on Basement	Does not exist
INTERCOM SYSTEM	Inspected
ELEVATOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
HOLDING AREA	Does not exist
KITCHEN/WARMING PANTRY	Inspected
Instance	Room B37
LIGHTING	
Instance on Room B37	Inspected
Lighting Fixture - Fluorescent	
Instance on Room B37	Inspected
Pendant Mounted	
Instance on Room B37	Does not exist
Recessed Mounted	
Instance on Room B37	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	26
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on Room B37	Does not exist
Lighting Fixture - HID	
Instance on Room B37	Does not exist
Lighting Fixture - Incandescent	
Instance on Room B37	Does not exist
LAN	Inspected
LOCAL DISTRIBUTION FRAME (I/LDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MAIN EQUIPMENT RACK (MDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	Room B8
Has LAN/Modem access	Yes

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

Question	Response
LIBRARY	
LIGHTING	
Instance on Room B8	Inspected
Lighting Fixture - Fluorescent	
Instance on Room B8	Inspected
Pendant Mounted	
Instance on Room B8	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	33
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room B8	Does not exist
Surface Mounted	
Instance on Room B8	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	44
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Room B8	Does not exist
Lighting Fixture - Incandescent	
Instance on Room B8	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room B8	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SMART BOARD	
Instance on Room B8	Does not exist
LIGHTING - SECURITY LIGHTS	
Condition	1- Good
Replacement Quantity	24
Replacement Uom	EACH
Deficiency	TIME CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Outside of Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
LIGHTNING PROTECTION	
Does not exist	
LOCKER ROOM	
Instance on Room B13	Inspected
Alternative Use	No
Instance on Room B15	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

Question	Response
LOCKER ROOM	
Alternative Use	No
LIGHTING	
Instance on Room B13	Inspected
Instance on Room B15	Inspected
Lighting Fixture - Fluorescent	
Instance on Room B13	Inspected
Instance on Room B15	Inspected
Pendant Mounted	
Instance on Room B13	Does not exist
Instance on Room B15	Does not exist
Recessed Mounted	
Instance on Room B13	Does not exist
Instance on Room B15	Does not exist
Surface Mounted	
Instance on Room B13	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	28
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room B15	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	32
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Room B13	Does not exist
Instance on Room B15	Does not exist
Lighting Fixture - Incandescent	
Instance on Room B13	Inspected
Instance on Room B15	Inspected
Pendant Mounted	
Instance on Room B13	Does not exist
Instance on Room B15	Does not exist
Recessed Mounted	
Instance on Room B13	Does not exist
Instance on Room B15	Does not exist
Surface Mounted	
Instance on Room B13	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

Question	Response
LOCKER ROOM	
LIGHTING	
Lighting Fixture - Incandescent	
Surface Mounted	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room B15	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MOTOR CONTROL CENTER	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	Motor Control Cent.1
Capacity/Size	N/A, 1 section
Installation Year	1970
Source of Installation Year	Documented
Deficiency	MCC NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	Motor Control Cent. 3
Capacity/Size	N/A, 1 section
Installation Year	1970
Source of Installation Year	Documented
Deficiency	MCC NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	N/A
Capacity/Size	N/A, 3 sections

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

Question	Response
MOTOR CONTROL CENTER	
Installation Year	1970
Source of Installation Year	Documented
Deficiency	MCC NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	MCC ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
MOTOR STARTER/CONTACTOR	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
MULTIPURPOSE ROOM	
Condition	Does not exist
PANEL BOARD	
Condition	Inspected
FUSED DISCONNECT SWITCH TYPE	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
FUSED KNIFE SWITCH TYPE	
Condition	Does not exist
FUSED TOGGLE SWITCH TYPE	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
MOLDED CASE CIRCUIT BREAKER TYPE	
Condition	Inspected
Deficiency	3- Fair
Deficiency	PANEL BOARD DOOR LOCK IS MISSING
Deficiency Location/Instance	By Room 208, 226
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	NO SPARE
Deficiency Location/Instance	By Room 208, 226
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL NEW PANEL BOARD
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	
Instance	Inspected
Instance Condition	General Office
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Rauland Telecenter 21
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Corridors
Deficiency Quantity	11

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

Question	Response
PUBLIC ADDRESS SYSTEM	
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SCIENCE DEMO ROOM	
Instance on Room 152	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 252	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 152	Does not exist
Instance on Room 252	Does not exist
EMERGENCY SHUT-OFF POWER	
Instance on Room 152	Does not exist
Instance on Room 252	Does not exist
LIGHTING	
Instance on Room 152	Inspected
Instance on Room 252	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 152	Inspected
Instance on Room 252	Inspected
Pendant Mounted	
Instance on Room 152	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 252	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room 152	Does not exist
Instance on Room 252	Does not exist
Surface Mounted	
Instance on Room 152	Does not exist
Instance on Room 252	Does not exist
Lighting Fixture - HID	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

Question	Response
SCIENCE DEMO ROOM	
LIGHTING	
Lighting Fixture - HID	
Instance on Room 152	Does not exist
Instance on Room 252	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 152	Does not exist
Instance on Room 252	Does not exist
POWER SUPPLY	
Instance on Room 152	Does not exist
Instance on Room 252	Does not exist
PROJECTION SYSTEM	
Instance on Room 152	Does not exist
Instance on Room 252	Does not exist
SMART BOARD	
Instance on Room 152	Does not exist
Instance on Room 252	Does not exist
SCIENCE LAB	
Instance on Room 156, 160, 260	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 362	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 256	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 356	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 156, 160, 260	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 362	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 256	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 356	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room 156, 160, 260	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 362	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

Question	Response
SCIENCE LAB	
EMERGENCY SHUT-OFF POWER	
Instance on Room 256	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 356	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Room 156, 160, 260	Inspected
Instance on Room 362	Inspected
Instance on Room 256	Inspected
Instance on Room 356	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 156, 160, 260	Inspected
Instance on Room 362	Inspected
Instance on Room 256	Inspected
Instance on Room 356	Inspected
Pendant Mounted	
Instance on Room 156, 160, 260	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	58
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 362	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 256	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

Question	Response
SCIENCE LAB	
LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Instance on Room 356	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 156, 160, 260	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 362	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 256	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 356	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 156, 160, 260	Does not exist
Instance on Room 362	Does not exist
Instance on Room 256	Does not exist
Instance on Room 356	Does not exist
Lighting Fixture - HID	
Instance on Room 156, 160, 260	Does not exist
Instance on Room 362	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

Question	Response
SCIENCE LAB	
LIGHTING	
Lighting Fixture - HID	
Instance on Room 256	Does not exist
Instance on Room 356	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 156, 160, 260	Does not exist
Instance on Room 362	Does not exist
Instance on Room 256	Does not exist
Instance on Room 356	Does not exist
POWER SUPPLY	
Instance on Room 156, 160, 260	Does not exist
Instance on Room 362	Inspected
Instance on Room 256	Does not exist
Instance on Room 356	Does not exist
Instructor Unit	
Instance on Room 362	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 362	Does not exist
Student Unit	
Instance on Room 362	Does not exist
PROJECTION SYSTEM	
Instance on Room 156, 160, 260	Does not exist
Instance on Room 362	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 256	Does not exist
Instance on Room 356	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
SMART BOARD	
Instance on Room 156, 160, 260	Does not exist
Instance on Room 362	Does not exist
Instance on Room 256	Does not exist
Instance on Room 356	Does not exist
SCIENCE PREP ROOM	
Instance on Room 158	Inspected
Has LAN/Modem access	No
Power Panel?	Yes
Alternative Use	No
Instance on Room 258	Inspected
Has LAN/Modem access	No
Power Panel?	Yes
Alternative Use	No
Instance on Room 360	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room B34	Inspected
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	No

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

Question	Response
SCIENCE PREP ROOM	
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 158	Does not exist
Instance on Room 258	Does not exist
Instance on Room 360	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room B34	Does not exist
EMERGENCY SHUT-OFF POWER	
Instance on Room 158	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 258	Does not exist
Instance on Room 360	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room B34	Does not exist
LIGHTING	
Instance on Room 158	Inspected
Instance on Room 258	Inspected
Instance on Room 360	Inspected
Instance on Room B34	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 158	Inspected
Instance on Room 258	Inspected
Instance on Room 360	Inspected
Instance on Room B34	Inspected
Pendant Mounted	
Instance on Room 158	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 258	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 360	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room B34	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	16

NYC Department of Education
Building Condition Assessment Survey 2010-2011

Electrical Inspection

Q025

Question	Response
SCIENCE PREP ROOM	
LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room 158	Does not exist
Instance on Room 258	Does not exist
Instance on Room 360	Does not exist
Instance on Room B34	Does not exist
Surface Mounted	
Instance on Room 158	Does not exist
Instance on Room 258	Does not exist
Instance on Room 360	Does not exist
Instance on Room B34	Does not exist
Lighting Fixture - HID	
Instance on Room 158	Does not exist
Instance on Room 258	Does not exist
Instance on Room 360	Does not exist
Instance on Room B34	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 158	Does not exist
Instance on Room 258	Does not exist
Instance on Room 360	Does not exist
Instance on Room B34	Does not exist
POWER SUPPLY	
Instance on Room 158	Does not exist
Instance on Room 258	Does not exist
Instance on Room 360	Does not exist
Instance on Room B34	Does not exist
SECURITY	Inspected
INTRUSION ALARM	Inspected
Central Control Panel	Inspected
Instance	Room C2
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Ademco-Vista 50P
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

Question	Response
SECURITY	
INTRUSION ALARM	
Siren/Strobe	
Deficiency	No deficiencies recorded
Ultrasonic Sensor	Does not exist
IPDVS/CCTV SYSTEM	Under construction
SERVICE SWITCH	Inspected
Instance	Electrical Room C4
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Standard Switchboard
EquipmentId	N/A
Capacity/Size	6000 Amps
Source of Capacity/Size	Nameplate
Installation Year	1970
Source of Installation Year	Documented
Deficiency	SWITCH ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
SWIMMING POOL	Does not exist
SWITCHBOARD	Inspected
Water Penetration In Electrical Room?	No
Number of Spares	3
AIR CIRCUIT BREAKER TYPE	Does not exist
FUSED DISCONNECT SWITCH TYPE	Inspected
Instance	Electrical Room C4
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	GE
EquipmentId	Standard Switchboard
Capacity/Size	6000 Amps total, 6 sections
Source of Capacity/Size	Service Switch Size
Installation Year	1970
Source of Installation Year	Documented
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED KNIFE SWITCH TYPE	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q025

Question	Response
TELEPHONE	Inspected
PBX/INTERCOM	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
STANDARD	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TOILET ROOM - STUDENT	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable System Exist?	Yes
Operational?	Yes
Master Antenna System Exist?	Yes

NYC Department of Education
Building Condition Assessment Survey 2010-2011

Electrical Inspection

Q025

Question	Response
TV SYSTEM	
Operational?	No
MAIN EQUIPMENT RACK	Does not exist