

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**Q025**

School: **J.H.S. 25 - QUEENS, 34-65 192 STREET, QUEENS, NY, 11355**

InspectionId	Inspection Type	Time In	Last Edited
1182054	ELECTRICAL	2009-01-26 12:14PM	2009-02-06 02:01PM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: TELEPHONE SYSTEM, PA SYSTEM, LAN, AUDITORIUM LOCAL SOUND SYSTEM Years: 2001 Systems: ELEVATOR INTERCOM Years: 2007 Systems: EMERGENCY/ EXIT LIGHTS, EMERGENCY LIGHT PANEL Years: 2000 Systems: FIRE ALARM SYSTEM AND OUTSIDE SECURITY LIGHTS Years: UNDER CONSTRUCTION

**Priority Condition**

No condition recorded

**Inspection**

Question	Response
<b>ELECTRICAL</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance	SECOND FLOOR
<b>House Lighting</b>	
Instance on SECOND FLOOR	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on SECOND FLOOR	Inspected
<b>Pendant Mounted</b>	
Instance on SECOND FLOOR	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on SECOND FLOOR	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on SECOND FLOOR	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on SECOND FLOOR	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on SECOND FLOOR	Inspected
<b>Pendant Mounted</b>	
Instance on SECOND FLOOR	Does not exist
<b>Recessed Mounted</b>	
Instance on SECOND FLOOR	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	36

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**Q025**

Question	Response
<b>AUDITORIUM</b>	
<b>House Lighting</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Recessed Mounted</b>	
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on SECOND FLOOR	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Local Sound System</b>	
Instance on SECOND FLOOR	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on SECOND FLOOR	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Theater Lighting System</b>	
Instance on SECOND FLOOR	Inspected
<b>Dimming System</b>	
Instance on SECOND FLOOR	Inspected
Instance Condition	5- Poor
Deficiency	DIMMING RACK NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Theater Lighting</b>	
Instance on SECOND FLOOR	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	24
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	
Condition	3- Fair
Replacement Quantity	173,000
Replacement Uom	S.F.
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**Q025**

<b>Question</b>	<b>Response</b>
<b>CAFETERIA</b>	Inspected
Instance	BASEMENT
<b>Lighting</b>	
Instance on BASEMENT	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on BASEMENT	Inspected
<b>Pendant Mounted</b>	
Instance on BASEMENT	Does not exist
<b>Recessed Mounted</b>	
Instance on BASEMENT	Does not exist
<b>Surface Mounted</b>	
Instance on BASEMENT	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on BASEMENT	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on BASEMENT	Does not exist
<b>Local Sound System</b>	
Instance on BASEMENT	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>CAFETERIA/MULTIPURPOSE ROOM</b>	Does not exist
<b>CITY FIRE ALARM SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**Q025**

Question	Response
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	52
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	41
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>COMPUTER LAB</b>	Inspected
Instance	ROOM 325
Has LAN/Modem access	Yes
Power Panel?	No
Instance	ROOM 262
Has LAN/Modem access	Yes
Power Panel?	Yes
<b>Lighting</b>	
Instance on ROOM 325	Inspected
Instance on ROOM 262	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on ROOM 325	Inspected
Instance on ROOM 262	Inspected
<b>Pendant Mounted</b>	
Instance on ROOM 325	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on ROOM 262	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on ROOM 325	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**Q025**

Question	Response
<b>COMPUTER LAB</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Recessed Mounted</b>	
Instance on ROOM 262	Does not exist
<b>Surface Mounted</b>	
Instance on ROOM 325	Does not exist
Instance on ROOM 262	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on ROOM 325	Does not exist
Instance on ROOM 262	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on ROOM 325	Does not exist
Instance on ROOM 262	Does not exist
<b>Raceway With Receptacles</b>	
Instance on ROOM 325	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 262	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>ELECTRIC SERVICE SWITCH</b>	Inspected
Instance	BASEMENT ELECTRICAL ROOM C4
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	STANDARD SWITCHBOARD
Model	STANDARD SWITCHBOARD
EquipmentId	N/A
Capacity/Size	6000 Amps
Installation Year	1970
Deficiency	SWITCH ID IS MISSING
Deficiency Location/Instance	BASEMENT ELECTRICAL ROOM C4
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Connected To Emergency Generator System</b>	Does not exist
<b>Connected To Emergency Light/Exit Light Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Relay Test Switch</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**Q025**

<b>Question</b>	<b>Response</b>
<b>EXIT LIGHT</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Connected To Emergency Generator System</b>	Does not exist
<b>Connected To Emergency Light/Exit Light Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>FIRE ALARM SYSTEM</b>	Under construction
<b>GROUNDING SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	Inspected
Instance	BASEMENT
<b>Lighting</b>	
Instance on BASEMENT	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on BASEMENT	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on BASEMENT	Inspected
<b>Pendant Mounted</b>	
Instance on BASEMENT	Does not exist
<b>Recessed Mounted</b>	
Instance on BASEMENT	Does not exist
<b>Surface Mounted</b>	
Instance on BASEMENT	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - Incandescent</b>	
Instance on BASEMENT	Does not exist
<b>Local Sound System</b>	
Instance on BASEMENT	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Scoreboard</b>	
Instance on BASEMENT	Does not exist
<b>Theater Lighting System</b>	
Instance on BASEMENT	Does not exist
<b>INTERCOM SYSTEM</b>	Inspected
<b>Elevator</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Holding Area</b>	Does not exist
<b>KITCHEN/WARMING PANTRY</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Inspected

NYC Department of Education  
Building Condition Assessment Survey 2008-2009

*Electrical Inspection*

**Q025**

Question	Response
<b>KITCHEN/WARMING PANTRY</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Recessed Mounted</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Does not exist
<b>LAN</b>	Inspected
<b>Local Distribution Frame (I/LDF)</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Main Equipment Rack (MDF)</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>LIBRARY</b>	Inspected
Instance	BASEMENT B8
Has LAN/Modem access	Yes
<b>Lighting</b>	
Instance on BASEMENT B8	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on BASEMENT B8	Inspected
<b>Pendant Mounted</b>	
Instance on BASEMENT B8	Does not exist
<b>Recessed Mounted</b>	
Instance on BASEMENT B8	Does not exist
<b>Surface Mounted</b>	
Instance on BASEMENT B8	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on BASEMENT B8	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on BASEMENT B8	Does not exist
<b>Raceway With Receptacles</b>	
Instance on BASEMENT B8	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>LIGHTING - EXTERIOR SECURITY</b>	Under construction
<b>LIGHTNING PROTECTION</b>	Does not exist
<b>LOCKER ROOM/SHOWER ROOM</b>	Inspected
Instance	LOCKER ROOM B38

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**Q025**

<b>Question</b>	<b>Response</b>
<b>LOCKER ROOM/SHOWER ROOM</b>	
Alternative Use	No
Instance	LOCKER ROOM B42
Alternative Use	No
<b>Lighting</b>	
Instance on LOCKER ROOM B38	Inspected
Instance on LOCKER ROOM B42	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on LOCKER ROOM B38	Inspected
Instance on LOCKER ROOM B42	Inspected
<b>Pendant Mounted</b>	
Instance on LOCKER ROOM B38	Does not exist
Instance on LOCKER ROOM B42	Does not exist
<b>Recessed Mounted</b>	
Instance on LOCKER ROOM B38	Does not exist
Instance on LOCKER ROOM B42	Does not exist
<b>Surface Mounted</b>	
Instance on LOCKER ROOM B38	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE POORLY MOUNTED
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on LOCKER ROOM B42	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
Instance on LOCKER ROOM B38	Does not exist
Instance on LOCKER ROOM B42	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on LOCKER ROOM B38	Does not exist
Instance on LOCKER ROOM B42	Inspected
<b>Pendant Mounted</b>	
Instance on LOCKER ROOM B42	Does not exist
<b>Recessed Mounted</b>	
Instance on LOCKER ROOM B42	Does not exist
<b>Surface Mounted</b>	
Instance on LOCKER ROOM B42	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**Q025**

<b>Question</b>	<b>Response</b>
<b>MOTOR CONTROL CENTER</b>	Inspected
Instance	BOILER ROOM
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	MOTOR CONTROL CENTER
Capacity/Size	225 Amps, 4 sections
Installation Year	1969
Deficiency	No deficiencies recorded
Instance	BASEMENT CHILLER ROOM
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	MOTOR CONTROL CENTER
Capacity/Size	225 Amps, 1 section
Installation Year	1969
Deficiency	MCC NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>MULTIPURPOSE ROOM</b>	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>Fused Disconnect Switch Type</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fused Knife Switch Type</b>	Does not exist
<b>Fused Toggle Switch Type</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Molded Case Circuit Breaker Type</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>PUBLIC ADDRESS SYSTEM</b>	Inspected
Replacement Quantity	173,000
Replacement Uom	S.F.
Instance	GENERAL OFFICE 108
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	RAULAND
Deficiency	No deficiencies recorded
<b>SCIENCE DEMO ROOM</b>	Inspected
Instance	ROOM 152, 252, 352
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
<b>Emergency Gas Shut-Off Valve</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**Q025**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>Emergency Gas Shut-Off Valve</b>	
Instance on ROOM 152, 252, 352	Does not exist
<b>Emergency Shut-Off Power</b>	
Instance on ROOM 152, 252, 352	Does not exist
<b>Lighting</b>	
Instance on ROOM 152, 252, 352	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on ROOM 152, 252, 352	Inspected
<b>Pendant Mounted</b>	
Instance on ROOM 152, 252, 352	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on ROOM 152, 252, 352	Does not exist
<b>Surface Mounted</b>	
Instance on ROOM 152, 252, 352	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on ROOM 152, 252, 352	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on ROOM 152, 252, 352	Does not exist
<b>Power Supply</b>	
Instance on ROOM 152, 252, 352	Does not exist
<b>SCIENCE LAB</b>	Inspected
Instance	ROOM 156
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	ROOM 160
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	ROOM 260
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	ROOM 256
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	ROOM 358
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance	ROOM 362
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
<b>Emergency Gas Shut-Off Valve</b>	
Instance on ROOM 156	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 160	Inspected
Instance Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**Q025**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>Emergency Gas Shut-Off Valve</b>	
Deficiency	No deficiencies recorded
Instance on ROOM 260	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 256	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 358	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on ROOM 362	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Emergency Shut-Off Power</b>	
Instance on ROOM 156	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 160	Does not exist
Instance on ROOM 260	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 256	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 358	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on ROOM 362	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Lighting</b>	
Instance on ROOM 156	Inspected
Instance on ROOM 160	Inspected
Instance on ROOM 260	Inspected
Instance on ROOM 256	Inspected
Instance on ROOM 358	Inspected
Instance on ROOM 362	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on ROOM 156	Inspected
Instance on ROOM 160	Inspected
Instance on ROOM 260	Inspected
Instance on ROOM 256	Inspected
Instance on ROOM 358	Inspected
Instance on ROOM 362	Inspected
<b>Pendant Mounted</b>	
Instance on ROOM 156	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 160	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 260	Inspected

NYC Department of Education  
 Building Condition Assessment Survey 2008-2009

*Electrical Inspection*

**Q025**

Question	Response
<b>SCIENCE LAB</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 256	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on ROOM 358	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on ROOM 362	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on ROOM 156	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 160	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 260	Does not exist
Instance on ROOM 256	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 358	Does not exist
Instance on ROOM 362	Does not exist
<b>Surface Mounted</b>	
Instance on ROOM 156	Does not exist
Instance on ROOM 160	Does not exist
Instance on ROOM 260	Does not exist
Instance on ROOM 256	Does not exist
Instance on ROOM 358	Does not exist
Instance on ROOM 362	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on ROOM 156	Does not exist
Instance on ROOM 160	Does not exist
Instance on ROOM 260	Does not exist
Instance on ROOM 256	Does not exist
Instance on ROOM 358	Does not exist
Instance on ROOM 362	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on ROOM 156	Does not exist
Instance on ROOM 160	Does not exist
Instance on ROOM 260	Does not exist
Instance on ROOM 256	Does not exist
Instance on ROOM 358	Does not exist
Instance on ROOM 362	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**Q025**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>Power Supply</b>	
Instance on ROOM 156	Does not exist
Instance on ROOM 160	Does not exist
Instance on ROOM 260	Does not exist
Instance on ROOM 256	Does not exist
Instance on ROOM 358	Does not exist
Instance on ROOM 362	Inspected
<b>Instructor Unit</b>	
Instance on ROOM 362	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Meter Demonstration Unit</b>	
Instance on ROOM 362	Does not exist
<b>Student Unit</b>	
Instance on ROOM 362	Does not exist
<b>SCIENCE PREP ROOM</b>	
Instance	Inspected
Instance	ROOM 360
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	ROOM 258
Has LAN/Modem access	No
Power Panel?	Yes
Alternative Use	No
Instance	ROOM 158
Has LAN/Modem access	No
Power Panel?	Yes
Alternative Use	No
Instance	ROOM B34
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	No
<b>Emergency Gas Shut-Off Valve</b>	
Instance on ROOM 360	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 258	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 158	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM B34	Does not exist
<b>Emergency Shut-Off Power</b>	
Instance on ROOM 360	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 258	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 158	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**Q025**

<b>Question</b>	<b>Response</b>
<b>SCIENCE PREP ROOM</b>	
<b>Emergency Shut-Off Power</b>	
Instance on ROOM B34	Does not exist
<b>Lighting</b>	
Instance on ROOM 360	Inspected
Instance on ROOM 258	Inspected
Instance on ROOM 158	Inspected
Instance on ROOM B34	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on ROOM 360	Inspected
Instance on ROOM 258	Inspected
Instance on ROOM 158	Inspected
Instance on ROOM B34	Inspected
<b>Pendant Mounted</b>	
Instance on ROOM 360	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 258	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 158	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM B34	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on ROOM 360	Does not exist
Instance on ROOM 258	Does not exist
Instance on ROOM 158	Does not exist
Instance on ROOM B34	Does not exist
<b>Surface Mounted</b>	
Instance on ROOM 360	Does not exist
Instance on ROOM 258	Does not exist
Instance on ROOM 158	Does not exist
Instance on ROOM B34	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on ROOM 360	Does not exist
Instance on ROOM 258	Does not exist
Instance on ROOM 158	Does not exist
Instance on ROOM B34	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on ROOM 360	Does not exist
Instance on ROOM 258	Does not exist
Instance on ROOM 158	Does not exist
Instance on ROOM B34	Does not exist
<b>Power Supply</b>	
Instance on ROOM 360	Does not exist
Instance on ROOM 258	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**Q025**

<b>Question</b>	<b>Response</b>
<b>SCIENCE PREP ROOM</b>	
<b>Power Supply</b>	
Instance on ROOM 158	Does not exist
Instance on ROOM B34	Does not exist
<b>SECURITY</b>	
Replacement Quantity	173,000
Replacement Uom	S.F.
<b>Intrusion Alarm</b>	
<b>Central Control Panel</b>	
Instance	ROOM C2
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	ADEMCO VISTA 50
Deficiency	No deficiencies recorded
<b>Infrared Sensor</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Ultrasonic Sensor</b>	
	Does not exist
<b>IPDVS/CCTV System</b>	
	Does not exist
<b>SWIMMING POOL</b>	
	Does not exist
<b>SWITCHBOARD</b>	
<b>Air Circuit Breaker Type</b>	Does not exist
<b>Fused Disconnect Switch Type</b>	Inspected
Instance	BASEMENT ELECTRICAL ROOM C4
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	N/A
Capacity/Size	6000 Amps total, 6 sections
Installation Year	1970
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

**Electrical Inspection**

**Q025**

<b>Question</b>	<b>Response</b>
<b>SWITCHBOARD</b>	
<b>Fused Knife Switch Type</b>	Does not exist
<b>Molded Case Circuit Breaker Type</b>	Does not exist
<b>TELEPHONE</b>	Inspected
<b>PBX/Intercom</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Standard</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>TOILET ROOM - STAFF</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TRANSFORMER</b>	Does not exist
<b>TV SYSTEM</b>	Inspected
<b>Cable Service</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Main Equipment Rack</b>	Does not exist
<b>Master Antenna System</b>	Inspected
Condition	5- Poor
Deficiency	ANTENNA NOT OPERATIONAL
Deficiency Location/Instance	Roof
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded