

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q036**

School: P.S. 36 - QUEENS, 187-01 FOCH BLVD, QUEENS, NY, 11412

InspectionId	Inspection Type	Time In	Last Edited
2200056	ELECTRICAL	2010-12-09 08:38AM	2010-12-17 12:15AM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: IPDVS/CCTV System Years: Under Construction Systems: Projection System in Auditorium, Telephone System, Exterior Security Lights Years: 2009 Systems: Smart Boards Years: 2008 Systems: Battery Pack Emergency and Exit Lights Years: 2004 Systems: Fire Alarm System, LAN System, Surface Fluorescent Lights, Local Sound System Years: 2000 Systems: Intrusion Alarm System Years: 1998 Systems: Public Address System Years: 1992
Type of Service	Below Ground

**Priority Condition**

No condition recorded

**Inspection**

Question	Response
<b>ELECTRICAL</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance	2nd Floor
<b>HOUSE LIGHTING</b>	
Instance on 2nd Floor	Inspected
Does a Chandelier Exist?	Yes
<b>Lighting Fixture - Fluorescent</b>	
Instance on 2nd Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 2nd Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on 2nd Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 2nd Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on 2nd Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 2nd Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 2nd Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 2nd Floor	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q036**

Question	Response
<b>AUDITORIUM</b>	
<b>LOCAL SOUND SYSTEM</b>	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>PROJECTION SYSTEM</b>	
Instance on 2nd Floor	Inspected
Instance Condition	1- Good
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	No deficiencies recorded
<b>THEATER LIGHTING SYSTEM</b>	
Instance on 2nd Floor	Inspected
<b>Dimming System</b>	
Instance on 2nd Floor	Does not exist
<b>Theater Lighting</b>	
Instance on 2nd Floor	Inspected
Instance Condition	5- Poor
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	
Instance on 2nd Floor	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>CAFETERIA</b>	
Instance on 2nd Floor	Inspected
Instance	1st Floor
<b>LIGHTING</b>	
Instance on 1st Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q036**

Question	Response
<b>CAFETERIA</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Pendant Mounted</b>	
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>CITY FIRE ALARM SYSTEM</b>	Inspected
Condition	5- Poor
Deficiency	NOT OPERATIONAL
Deficiency Location/Instance	2nd Floor By General Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	Inspected
<b>LIGHTING</b>	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	309
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q036**

Question	Response
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	13
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	28
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SMART BOARD</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>COMPUTER LAB</b>	Inspected
Instance	Room 307
Has LAN/Modem access	Yes
Power Panel?	Yes
<b>LIGHTING</b>	
Instance on Room 307	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 307	Inspected
<b>Pendant Mounted</b>	
Instance on Room 307	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q036**

Question	Response
<b>COMPUTER LAB</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 307	Does not exist
<b>Surface Mounted</b>	
Instance on Room 307	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 307	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 307	Does not exist
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room 307	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	Inspected
<b>BATTERY PACK</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	Inspected
<b>BATTERY PACK</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	1st Floor By Exit 2
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Non Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EXIT/EMERGENCY LIGHT</b>	Does not exist
<b>FIRE ALARM SYSTEM</b>	Inspected
<b>AREA SMOKE DETECTOR</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>BELL/HORN</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>DUCT SMOKE DETECTOR</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q036**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>ELEVATOR RECALL</b>	Does not exist
<b>FAN SHUTDOWN CONTROL</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>FIRE ALARM DIGITAL COMMUNICATOR</b>	Does not exist
<b>FUSED CUTOOUT PANEL</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>HEAT DETECTOR</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>MAGNETIC DOOR HOLDER CONTACTOR</b>	Does not exist
<b>MAIN PANEL</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Inspected
Instance	By Custodian Office
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards
Model	EST-2
EquipmentId	Fire Alarm Control Panel
Capacity/Size	8 zones
Installation Year	2000
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Standard)</b>	Does not exist
<b>MANUAL PULL STATION</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>REMOTE ANNUNCIATOR</b>	Inspected
<b>Display Monitor</b>	Does not exist
<b>Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Printer</b>	Does not exist
<b>Punch Register</b>	Does not exist
<b>SPRINKLER FLOW/AIR PRESSURE SWITCH</b>	Does not exist
<b>STROBE</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>SUB-PANEL</b>	Does not exist
<b>TAMPER FLOW SWITCH/CHAIN</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>GROUNDING SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	Does not exist
<b>INTERCOM SYSTEM</b>	Does not exist
<b>KITCHEN/WARMING PANTRY</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q036**

<b>Question</b>	<b>Response</b>
<b>KITCHEN/WARMING PANTRY</b>	
Instance	1st Floor
<b>LIGHTING</b>	
Instance on 1st Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not exist
<b>LAN</b>	Inspected
<b>LOCAL DISTRIBUTION FRAME (I/LDF)</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>MAIN EQUIPMENT RACK (MDF)</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>LIBRARY</b>	Inspected
Instance	Room 305
Has LAN/Modem access	Yes
<b>LIGHTING</b>	
Instance on Room 305	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 305	Inspected
<b>Pendant Mounted</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q036**

<b>Question</b>	<b>Response</b>
<b>LIBRARY</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Instance on Room 305	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	24
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 305	Does not exist
<b>Surface Mounted</b>	
Instance on Room 305	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 305	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 305	Does not exist
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room 305	Does not exist
<b>SMART BOARD</b>	
Instance on Room 305	Does not exist
<b>LIGHTING - SECURITY LIGHTS</b>	Inspected
Condition	2- Between Good and Fair
Replacement Quantity	16
Replacement Uom	EACH
Deficiency	TIME CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Penthouse
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Facing Playground
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
<b>LIGHTNING PROTECTION</b>	Does not exist
<b>LOCKER ROOM</b>	Does not exist
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Boiler Room, Mechanical Spaces
Deficiency Quantity	6
Quantity Uom	EACH

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q036**

<b>Question</b>	<b>Response</b>
<b>MOTOR STARTER/CONTACTOR</b>	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MULTIPURPOSE ROOM</b>	
Instance	Inspected
Instance	1st Floor
<b>LIGHTING</b>	
Instance on 1st Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	28
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>PROJECTION SYSTEM</b>	
Instance on 1st Floor	Does not exist
<b>THEATER LIGHTING SYSTEM</b>	
Instance on 1st Floor	Does not exist
<b>PANEL BOARD</b>	
	Inspected
<b>FUSED DISCONNECT SWITCH TYPE</b>	
Condition	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Penthouse Fan Room, Boiler Room

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q036**

Question	Response
<b>PANEL BOARD</b>	
<b>FUSED DISCONNECT SWITCH TYPE</b>	
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>FUSED KNIFE SWITCH TYPE</b>	
	Does not exist
<b>FUSED TOGGLE SWITCH TYPE</b>	
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Basement Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	
	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Corridors, Auditorium, Cafe
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>PUBLIC ADDRESS SYSTEM</b>	
	Inspected
Instance	General office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Dukane MACS
Deficiency	No deficiencies recorded
<b>SCIENCE DEMO ROOM</b>	
	Does not exist
<b>SCIENCE LAB</b>	
	Does not exist
<b>SCIENCE PREP ROOM</b>	
	Does not exist
<b>SECURITY</b>	
	Inspected
<b>INTRUSION ALARM</b>	
	Inspected
<b>Central Control Panel</b>	
Instance	Custodian Office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista-50P
Deficiency	No deficiencies recorded
<b>Infrared Sensor</b>	
	Inspected
Condition	3- Fair
Deficiency	SENSOR NOT OPERATIONAL
Deficiency Location/Instance	Room 307, 1st Floor Corridor
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q036**

<b>Question</b>	<b>Response</b>
<b>SECURITY</b>	
<b>INTRUSION ALARM</b>	
<b>Infrared Sensor</b>	
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
<b>Panic Switch</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
<b>Ultrasonic Sensor</b>	
	Does not exist
<b>IPDVS/CCTV SYSTEM</b>	
	Under construction
<b>SERVICE SWITCH</b>	
	Inspected
Instance	Basement Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard
EquipmentId	Service Switch
Capacity/Size	1200 Amps
Source of Capacity/Size	Nameplate
Installation Year	1961
Source of Installation Year	Documented
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SWIMMING POOL</b>	
	Does not exist
<b>SWITCHBOARD</b>	
	Inspected
Water Penetration In Electrical Room?	No
Number of Spares	3
<b>AIR CIRCUIT BREAKER TYPE</b>	
	Does not exist
<b>FUSED DISCONNECT SWITCH TYPE</b>	
	Inspected
Instance	Basement Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Royal Switchboard
EquipmentId	Main SWBD
Capacity/Size	1200 Amps total, 2 sections
Source of Capacity/Size	Service Switch Size
Installation Year	1961
Source of Installation Year	Documented
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q036**

<b>Question</b>	<b>Response</b>
<b>SWITCHBOARD</b>	
<b>FUSED DISCONNECT SWITCH TYPE</b>	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>FUSED KNIFE SWITCH TYPE</b>	Does not exist
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	Does not exist
<b>TELEPHONE</b>	Inspected
<b>PBX/INTERCOM</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>STANDARD</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>TOILET ROOM - STAFF</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q036**

<b>Question</b>	<b>Response</b>
<b>TOILET ROOM - STUDENT</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Pendant Mounted</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>TRANSFORMER</b>	Does not exist
<b>TV SYSTEM</b>	Inspected
Cable System Exist?	Yes
Operational?	Yes
Master Antenna System Exist?	No
<b>MAIN EQUIPMENT RACK</b>	Does not exist