

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q042

School: P.S. 42 - QUEENS, 488 BEACH 66 STREET, QUEENS, NY, 11692

InspectionId	Inspection Type	Time In	Last Edited
2080066	ELECTRICAL	2010-12-23 09:04AM	2011-01-06 10:35AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Intrusion Alarm System, IPDVS/CCTV System, Exterior Lights Years: 1997 Systems: Local Sound System, Public Address System Years: 1997 Systems: Motor Starters/Contactor, Panel Boards, Switchboard, Fire Alarm System, Grounding System Years: 2005 Systems: Emergency Lights, Exit Lights, Emergency Light/Exit Lights Panel Years: 1997/2007 Systems: Interior Fluorescent and HID Lights Years: 1997 Systems: Auditorium Local Sound System, Projection System Years: 2005 Systems: Magnetic Door Holders/Contactor Years: 2010 Systems: Library Raceway Years: 2002 Systems: Smart-boards Years: 2005/2010 Type of Service: Below Ground

Priority Condition

Condition Description	Component Affected	Location Description	Person(s) Notified
Fire Alarm System - Main Panel is Defective	Fire Alarm Control Panel	Security Office - Main Entrance Lobby	Fireman - Jose Rivera

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	2nd Floor
HOUSE LIGHTING	
Instance on 2nd Floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on 2nd Floor	Inspected
Pendant Mounted	
Instance on 2nd Floor	Does not exist
Recessed Mounted	
Instance on 2nd Floor	Does not exist
Surface Mounted	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 2nd Floor	Inspected
Pendant Mounted	
Instance on 2nd Floor	Does not exist
Recessed Mounted	
Instance on 2nd Floor	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q042

Question	Response
AUDITORIUM	
HOUSE LIGHTING	
Lighting Fixture - HID	
Surface Mounted	
Instance on 2nd Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - Incandescent	
Instance on 2nd Floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 2nd Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
PROJECTION SYSTEM	
Instance on 2nd Floor	Inspected
Instance Condition	2- Between Good and Fair
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	No deficiencies recorded
THEATER LIGHTING SYSTEM	
Instance on 2nd Floor	Inspected
Dimming System	
Instance on 2nd Floor	Does not exist
Theater Lighting	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	19
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q042

Question	Response
CAFETERIA	Inspected
Instance	1st Floor
LIGHTING	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
CITY FIRE ALARM SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
LIGHTING	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	25
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q042

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE POORLY MOUNTED
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	21
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	34
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q042

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Lighting Fixture - Incandescent	
Surface Mounted	
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SMART BOARD	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
COMPUTER LAB	Inspected
Instance	Room 407
Has LAN/Modem access	Yes
Power Panel?	Yes
LIGHTING	
Instance on Room 407	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 407	Inspected
Pendant Mounted	
Instance on Room 407	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room 407	Does not exist
Surface Mounted	
Instance on Room 407	Does not exist
Lighting Fixture - HID	
Instance on Room 407	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 407	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 407	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
BATTERY PACK	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	FIXTURE POORLY MOUNTED
Deficiency Location/Instance	Multipurpose Room
Deficiency Quantity	1
Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q042

Question	Response
EMERGENCY LIGHTING	
Non Battery Pack	
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
EXIT LIGHT	Inspected
BATTERY PACK	Inspected
Condition	2- Between Good and Fair
Deficiency	FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Main Lobby, 2nd Floor Corridor
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Non Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	FIXTURE POORLY MOUNTED
Deficiency Location/Instance	By Room 502
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	By Room 301
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
AREA SMOKE DETECTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
BELL/HORN	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
DUCT SMOKE DETECTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
ELEVATOR RECALL	Does not exist
FAN SHUTDOWN CONTROL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
FIRE ALARM DIGITAL COMMUNICATOR	Does not exist
FUSED CUTOUT PANEL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
HEAT DETECTOR	Inspected
Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q042

Question	Response
FIRE ALARM SYSTEM	
HEAT DETECTOR	
Deficiency	No deficiencies recorded
MAGNETIC DOOR HOLDER CONTACTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
MAIN PANEL	Inspected
Bell At Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Security Office - Main Entrance Lobby
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Firesens
Model	MPC 7000
EquipmentId	Fire Alarm Control Panel
Capacity/Size	8 Zones
Installation Year	2005
Source of Installation Year	Documented
Deficiency	PANEL DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Fire Alarm Control Panel (Standard)	Does not exist
MANUAL PULL STATION	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
REMOTE ANNUNCIATOR	Inspected
Display Monitor	Does not exist
Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Punch Register	Does not exist
SPRINKLER FLOW/AIR PRESSURE SWITCH	Does not exist
STROBE	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SUB-PANEL	Does not exist
TAMPER FLOW SWITCH/CHAIN	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
GYMNASIUM	Does not exist
INTERCOM SYSTEM	Does not exist
KITCHEN/WARMING PANTRY	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q042

Question	Response
KITCHEN/WARMING PANTRY	
Instance	1st Floor
LIGHTING	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
LAN	Inspected
LOCAL DISTRIBUTION FRAME (I/LDF)	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
MAIN EQUIPMENT RACK (MDF)	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	Room 129
Has LAN/Modem access	Yes
LIGHTING	
Instance on Room 129	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 129	Inspected
Pendant Mounted	
Instance on Room 129	Does not exist
Recessed Mounted	
Instance on Room 129	Does not exist
Surface Mounted	
Instance on Room 129	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q042

Question	Response
LIBRARY	
LIGHTING	
Lighting Fixture - HID	
Instance on Room 129	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 129	Inspected
Pendant Mounted	
Instance on Room 129	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	14
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room 129	Does not exist
Surface Mounted	
Instance on Room 129	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
RACEWAY WITH RECEPTACLES	
Instance on Room 129	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SMART BOARD	
Instance on Room 129	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIGHTING - SECURITY LIGHTS	Inspected
Condition	2- Between Good and Fair
Replacement Quantity	16
Replacement Uom	EACH
Deficiency	TIME CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Cafeteria Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
LIGHTNING PROTECTION	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
LOCKER ROOM	Does not exist
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MULTIPURPOSE ROOM	Inspected
Instance	1st Floor
LIGHTING	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q042

Question	Response
MULTIPURPOSE ROOM	
LIGHTING	
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 1st Floor	Does not exist
PROJECTION SYSTEM	
Instance on 1st Floor	Does not exist
THEATER LIGHTING SYSTEM	
Instance on 1st Floor	Does not exist
PANEL BOARD	Inspected
FUSED DISCONNECT SWITCH TYPE	Does not exist
FUSED KNIFE SWITCH TYPE	Does not exist
FUSED TOGGLE SWITCH TYPE	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	Inspected
Condition	2- Between Good and Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Penthouse
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	Inspected
Instance	General Office
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Telecore II
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	3rd Floor Corridor
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	Does not exist
SECURITY	Inspected
INTRUSION ALARM	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q042

Question	Response
SECURITY	
INTRUSION ALARM	
Central Control Panel	Inspected
Instance	Custodian Office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Ademco-Vista 50P
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	Inspected
Condition	3- Fair
Deficiency	SENSOR NOT IN USE
Deficiency Location/Instance	1st Floor Main Lobby, 2nd Floor Corridors, Kitchen, Multipurpose
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
IPDVS/CCTV SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
SERVICE SWITCH	Inspected
Instance	Basement Electrical Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Square D
EquipmentId	Main Service Disconnect
Capacity/Size	1600 Amps
Source of Capacity/Size	Nameplate
Installation Year	2005
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SWIMMING POOL	Does not exist
SWITCHBOARD	Inspected
Water Penetration In Electrical Room?	No
Number of Spares	0
AIR CIRCUIT BREAKER TYPE	Does not exist
FUSED DISCONNECT SWITCH TYPE	Inspected
Instance	Electrical Room in Cafeteria
Instance Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q042

Question	Response
SWITCHBOARD	
FUSED DISCONNECT SWITCH TYPE	
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Square D
EquipmentId	MDSB
Capacity/Size	1600 Amps total, 2 sections
Source of Capacity/Size	Switchboard Mains Size
Installation Year	2005
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
FUSED KNIFE SWITCH TYPE	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	Does not exist
TELEPHONE	Inspected
PBX/INTERCOM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
STANDARD	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TOILET ROOM - STUDENT	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable System Exist?	Yes
Operational?	Yes
Master Antenna System Exist?	No
MAIN EQUIPMENT RACK	Does not exist