

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q093

School: I.S. 93 - QUEENS, 66-56 FOREST AVENUE, QUEENS, NY, 11385

InspectionId	Inspection Type	Time In	Last Edited
2080041	ELECTRICAL	2010-11-22 09:01AM	2011-04-21 11:44AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Telephone System, Local Area Network, Exterior Lights Years: 2008 Systems: Intrusion Alarm System, CCTV Camera System Years: 2005 Systems: Public Address System Years: 1998 Systems: Partial/Emergency Lights (Battery Packed), Partial/Exit Lights (Battery Packed) Years: 2007 Systems: Science Rooms Electrical Components (Partial) Years: 1998/2007 Systems: Most Fluorescent Surface Mounted Lights and Fluorescent Pendant Mounted Lights Years: Under Construction Systems: Local Sound System in Cafeteria (partial) Years: 1998/2007 Systems: Local Sound System in Auditorium and Gymnasium Years: 1998 Systems: Fluorescent Recessed Mounted Lighting Years: 1998 Systems: Smart-board Years: 2009 Systems: HID Lighting Fixtures Years: 1993 Systems: Molded Case Circuit Breaker type Panels (partial) Years: 2009
Type of Service	Below Ground

Priority Condition

Condition Description	Component Affected	Location Description	Person(s) Notified
Water Penetration	Lighting Fixtures	New Wing Lobby and Staircase B of 3rd Floor	Custodian-Issac Albothor
Water Penetration	Switchboard	Basement Electrical Equipment Room (Old Wing)	Custodian-Issac Albothor

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	2nd Floor
HOUSE LIGHTING	
Instance on 2nd Floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on 2nd Floor	Inspected
Pendant Mounted	
Instance on 2nd Floor	Does not exist
Recessed Mounted	
Instance on 2nd Floor	Does not exist
Surface Mounted	
Instance on 2nd Floor	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q093

Question	Response
AUDITORIUM	
HOUSE LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on 2nd Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 2nd Floor	Inspected
Pendant Mounted	
Instance on 2nd Floor	Does not exist
Recessed Mounted	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	49
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
LOCAL SOUND SYSTEM	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
PROJECTION SYSTEM	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	No deficiencies recorded
THEATER LIGHTING SYSTEM	
Instance on 2nd Floor	Inspected
Dimming System	
Instance on 2nd Floor	Does not exist
Theater Lighting	
Instance on 2nd Floor	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q093

Question	Response
AUDITORIUM	
THEATER LIGHTING SYSTEM	
Theater Lighting	
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA	
Condition	Inspected
Instance	1st Floor - Students
Instance	1st Floor - Teachers Room 117
LIGHTING	
Instance on 1st Floor - Students	Inspected
Instance on 1st Floor - Teachers Room 117	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor - Students	Inspected
Instance on 1st Floor - Teachers Room 117	Inspected
Pendant Mounted	
Instance on 1st Floor - Students	Does not exist
Instance on 1st Floor - Teachers Room 117	Does not exist
Recessed Mounted	
Instance on 1st Floor - Students	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	94
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 1st Floor - Teachers Room 117	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	22
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q093

Question	Response
CAFETERIA	
LIGHTING	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 1st Floor - Students	Does not exist
Instance on 1st Floor - Teachers Room 117	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor - Students	Does not exist
Instance on 1st Floor - Teachers Room 117	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor - Students	Does not exist
Instance on 1st Floor - Teachers Room 117	Does not exist
LOCAL SOUND SYSTEM	
Instance on 1st Floor - Students	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor - Teachers Room 117	Does not exist
CITY FIRE ALARM SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Pendant Mounted	
Under construction	
Recessed Mounted	
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Under construction	
Lighting Fixture - HID	
Does not exist	
Lighting Fixture - Incandescent	
Pendant Mounted	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	36
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	23
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q093

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Lighting Fixture - Incandescent	
Recessed Mounted	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	156
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SMART BOARD	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
COMPUTER LAB	Does not exist
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
BATTERY PACK	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
BATTERY PACK	Inspected
Condition	3- Fair
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	4th, 5th and 6th Floor, 1st Floor Staircase Exit door
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q093

Question	Response
EXIT LIGHT	
BATTERY PACK	
Violations	No violations recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
AREA SMOKE DETECTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
BELL/HORN	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
DUCT SMOKE DETECTOR	Does not exist
ELEVATOR RECALL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
FAN SHUTDOWN CONTROL	Does not exist
FIRE ALARM DIGITAL COMMUNICATOR	Does not exist
FUSED CUTOOUT PANEL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
HEAT DETECTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MAGNETIC DOOR HOLDER CONTACTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MAIN PANEL	Inspected
Bell At Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Boiler Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Notifier
Model	N/A
EquipmentId	Interior Coded Fire Alarm
Capacity/Size	16 Zones
Installation Year	1997
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist
MANUAL PULL STATION	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
REMOTE ANNUNCIATOR	Inspected
Display Monitor	Inspected
Condition	5- Poor
Deficiency	MONITOR NOT OPERATIONAL
Deficiency Location/Instance	Custodian Office
Deficiency Quantity	1

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q093

Question	Response
FIRE ALARM SYSTEM	
REMOTE ANNUNCIATOR	
Display Monitor	
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Panel	
Condition	Inspected
Deficiency	2- Between Good and Fair
Printer	
Condition	Inspected
Deficiency	5- Poor
Deficiency	PRINTER NOT OPERATIONAL
Deficiency Location/Instance	Custodian office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Punch Register	
	Does not exist
SPRINKLER FLOW/AIR PRESSURE SWITCH	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
STROBE	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
SUB-PANEL	
Condition	Inspected
Bell At Panel	
	Does not exist
Fire Alarm Control Panel (Electronic)	
Condition	Inspected
Instance	Main Entrance Lobby
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Notifier
Model	N/A
EquipmentId	Purge Panel and Annunciator
Capacity/Size	6 Zones
Installation Year	1997
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	
	Does not exist
TAMPER FLOW SWITCH/CHAIN	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	
Instance	Inspected
Instance	2nd Floor
LIGHTING	
Instance on 2nd Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 2nd Floor	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q093

Question	Response
GYMNASIUM	
LIGHTING	
Lighting Fixture - HID	
Instance on 2nd Floor	Inspected
Pendant Mounted	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 2nd Floor	Does not exist
Surface Mounted	
Instance on 2nd Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 2nd Floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SCOREBOARD	
Instance on 2nd Floor	Does not exist
THEATER LIGHTING SYSTEM	
Instance on 2nd Floor	Does not exist
INTERCOM SYSTEM	
	Inspected
ELEVATOR	
Condition	3- Fair
Deficiency	No deficiencies recorded
HOLDING AREA	
	Does not exist
KITCHEN/WARMING PANTRY	
Instance	Inspected
Instance	1st Floor
LIGHTING	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	32
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	

NYC Department of Education
Building Condition Assessment Survey 2010-2011

Electrical Inspection

Q093

Question	Response
KITCHEN/WARMING PANTRY	
LIGHTING	
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
LAN	Inspected
LOCAL DISTRIBUTION FRAME (I/LDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
MAIN EQUIPMENT RACK (MDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	Room 405
Has LAN/Modem access	Yes
LIGHTING	
Instance on Room 405	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 405	Inspected
Pendant Mounted	
Instance on Room 405	Under construction
Recessed Mounted	
Instance on Room 405	Does not exist
Surface Mounted	
Instance on Room 405	Does not exist
Lighting Fixture - HID	
Instance on Room 405	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 405	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 405	Does not exist
SMART BOARD	
Instance on Room 405	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
LIGHTING - SECURITY LIGHTS	Inspected
Condition	1- Good
Replacement Quantity	35
Replacement Uom	EACH
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	Does not exist
LOCKER ROOM	
Instance on 2nd Floor - Boys	Inspected
Alternative Use	No
Instance on 2nd Floor - Girls	Inspected
Alternative Use	No
LIGHTING	
Instance on 2nd Floor - Boys	Inspected
Instance on 2nd Floor - Girls	Inspected
Lighting Fixture - Fluorescent	
Instance on 2nd Floor - Boys	Does not exist
Instance on 2nd Floor - Girls	Does not exist
Lighting Fixture - HID	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q093

Question	Response
LOCKER ROOM	
LIGHTING	
Lighting Fixture - HID	
Instance on 2nd Floor - Boys	Does not exist
Instance on 2nd Floor - Girls	Does not exist
Lighting Fixture - Incandescent	
Instance on 2nd Floor - Boys	Inspected
Instance on 2nd Floor - Girls	Inspected
Pendant Mounted	
Instance on 2nd Floor - Boys	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd Floor - Girls	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 2nd Floor - Boys	Does not exist
Instance on 2nd Floor - Girls	Does not exist
Surface Mounted	
Instance on 2nd Floor - Boys	Does not exist
Instance on 2nd Floor - Girls	Does not exist
MOTOR CONTROL CENTER	
	Does not exist
MOTOR STARTER/CONTACTOR	
Condition	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Mechanical Spaces
Deficiency Quantity	21
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	MOTOR STARTER PUSH BUTTON NOT OPERATIONAL
Deficiency Location/Instance	Sub-basement Fan Room by Cafeteria (Motor Starter is for Gymnasium Exhaust)

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q093

Question	Response
MOTOR STARTER/CONTACTOR	
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
FUSED DISCONNECT SWITCH TYPE	Does not exist
FUSED KNIFE SWITCH TYPE	Does not exist
FUSED TOGGLE SWITCH TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Basement, Electrical Room
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MOLDED CASE CIRCUIT BREAKER TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Corridors, Basement, Mechanical Spaces
Deficiency Quantity	27
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	Inspected
Instance	General Office - Room 209
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Telecore II
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Corridors, Offices
Deficiency Quantity	17
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SCIENCE DEMO ROOM	
Instance on Room 414, 418, 514, 518	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 150, 350 (New Wing)	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 250	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q093

Question	Response
SCIENCE DEMO ROOM	
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 414, 418, 514, 518	Does not exist
Instance on Room 150, 350 (New Wing)	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 250	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room 414, 418, 514, 518	Does not exist
Instance on Room 150, 350 (New Wing)	Does not exist
Instance on Room 250	Does not exist
LIGHTING	
Instance on Room 414, 418, 514, 518	Under construction
Instance on Room 150, 350 (New Wing)	Inspected
Instance on Room 250	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 150, 350 (New Wing)	Inspected
Instance on Room 250	Inspected
Pendant Mounted	
Instance on Room 150, 350 (New Wing)	Does not exist
Instance on Room 250	Does not exist
Recessed Mounted	
Instance on Room 150, 350 (New Wing)	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 250	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 150, 350 (New Wing)	Does not exist
Instance on Room 250	Does not exist
Lighting Fixture - HID	
Instance on Room 150, 350 (New Wing)	Does not exist
Instance on Room 250	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 150, 350 (New Wing)	Does not exist
Instance on Room 250	Does not exist
POWER SUPPLY	
Instance on Room 414, 418, 514, 518	Does not exist
Instance on Room 150, 350 (New Wing)	Inspected
Instance on Room 250	Inspected
Instructor Unit	
Instance on Room 150, 350 (New Wing)	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 250	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q093

Question	Response
SCIENCE DEMO ROOM	
POWER SUPPLY	
Meter Demonstration Unit	
Instance on Room 150, 350 (New Wing)	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 250	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
PROJECTION SYSTEM	
Instance on Room 414, 418, 514, 518	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 150, 350 (New Wing)	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 250	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
SMART BOARD	
Instance on Room 414, 418, 514, 518	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 150, 350 (New Wing)	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 250	Does not exist
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	
Instance on Room 416, 516	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 416, 516	Does not exist
EMERGENCY SHUT-OFF POWER	
Instance on Room 416, 516	Does not exist
LIGHTING	
Instance on Room 416, 516	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 416, 516	Inspected
Pendant Mounted	
Instance on Room 416, 516	Under construction
Recessed Mounted	
Instance on Room 416, 516	Does not exist
Surface Mounted	
Instance on Room 416, 516	Does not exist
Lighting Fixture - HID	
Instance on Room 416, 516	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 416, 516	Does not exist
POWER SUPPLY	
Instance on Room 416, 516	Does not exist
SECURITY	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q093

Question	Response
SECURITY	
INTRUSION ALARM	Inspected
Central Control Panel	Inspected
Instance	Custodian Office - Room 207
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Ademco-Vista 50P
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	Does not exist
IPDVS/CCTV SYSTEM	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SERVICE SWITCH	Inspected
Instance	Basement Electrical Room (Old Wing)
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific
EquipmentId	Main SER A
Capacity/Size	1200 Amps
Source of Capacity/Size	Nameplate
Installation Year	1964
Source of Installation Year	Documented
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Basement Electrical Room (Old Wing)
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pacific
EquipmentId	Main SER B
Capacity/Size	1200 Amps
Source of Capacity/Size	Nameplate
Installation Year	1964
Source of Installation Year	Documented
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q093

Question	Response
SERVICE SWITCH	
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SWIMMING POOL	Does not exist
SWITCHBOARD	Inspected
Water Penetration In Electrical Room?	Yes
Number of Spares	4
AIR CIRCUIT BREAKER TYPE	Does not exist
FUSED DISCONNECT SWITCH TYPE	Inspected
Instance	Basement Electrical Room (New Wing)
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard
EquipmentId	Distribution Panel
Capacity/Size	1000 Amps total, 2 Sections
Source of Capacity/Size	Switchboard Mains Size
Installation Year	1997
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
FUSED KNIFE SWITCH TYPE	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	Inspected
Instance	Basement Electrical Room (Old Wing)
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Standard
EquipmentId	Main Dist. Ser. A
Capacity/Size	1200 Amps total, 2 Sections
Source of Capacity/Size	Service Switch Size
Installation Year	1964
Source of Installation Year	Documented
Deficiency	SWITCHBOARD DIRECTORY MISSING OR REQUIRES UPDATING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q093

Question	Response
SWITCHBOARD	
MOLDED CASE CIRCUIT BREAKER TYPE	
Violations	No violations recorded
Instance	Basement Electrical Room (Old Wing)
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Standard
EquipmentId	Main Dist. Ser. B
Capacity/Size	1200 Amps total, 2 Sections
Source of Capacity/Size	Service Switch Size
Installation Year	1964
Source of Installation Year	Documented
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD DIRECTORY MISSING OR REQUIRES UPDATING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
TELEPHONE	Inspected
PBX/INTERCOM	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
STANDARD	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q093

Question	Response
TOILET ROOM - STAFF	
LIGHTING	
Lighting Fixture - Incandescent	
Pendant Mounted	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	13
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TOILET ROOM - STUDENT	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	30
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable System Exist?	Yes
Operational?	Yes
Master Antenna System Exist?	Yes
Operational?	No
MAIN EQUIPMENT RACK	Does not exist