

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q116

School: P.S. 116 - QUEENS, 107-25 WREN PLACE, QUEENS, NY, 11433

InspectionId	Inspection Type	Time In	Last Edited
1550114	ELECTRICAL	2011-02-23 09:15AM	2011-03-03 02:08PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Telephones / PBX/Intercom Years: Under Construction Systems: Motor Starters (Partial) Years: 2010 Systems: Science Lab, Public Address System, Local Sound System, Clocks Years: 2009 Systems: Smart Boards Years: 2008 - 2010 Systems: Fire Alarm System and Auditorium Stage Lights (Partial) Years: 2005 Systems: (Partial) Emergency Lights Years: 2005 Systems: Exterior Lights Years: 2004 Systems: Intrusion Alarm Panel Years: 2003 (Estimate) Type of Service: Below Ground

Priority Condition

Condition Description	Component Affected	Location Description	Person(s) Notified
Water Penetration in Electrical Room	Water Penetration	Electrical Room	Handyman - Jim Snyder

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	1st Floor
HOUSE LIGHTING	
Instance on 1st Floor	Inspected
Does a Chandelier Exist?	Yes
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q116

Question	Response
AUDITORIUM	
PROJECTION SYSTEM	
Instance on 1st Floor	Does not exist
THEATER LIGHTING SYSTEM	
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Does not exist
Theater Lighting	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	24
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA	
Instance	Inspected
Instance	1st Floor
LIGHTING	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	24
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 1st Floor	Inspected
Instance Condition	1- Good

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q116

Question	Response
CAFETERIA	
LOCAL SOUND SYSTEM	
Deficiency	No deficiencies recorded
CITY FIRE ALARM SYSTEM	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Condition	Inspected
LIGHTING	
Does a Chandelier Exist?	Inspected
Yes	Yes
Lighting Fixture - Fluorescent	
Pendant Mounted	
Condition	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	747
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	
Condition	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	64
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	
Condition	Inspected
Pendant Mounted	
Condition	Inspected
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q116

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Lighting Fixture - Incandescent	
Pendant Mounted	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	21
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SMART BOARD	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
COMPUTER LAB	Inspected
Instance	Room 515
Has LAN/Modem access	Yes
Power Panel?	Yes
LIGHTING	
Instance on Room 515	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 515	Inspected
Pendant Mounted	
Instance on Room 515	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Instance on Room 515	Does not exist
Surface Mounted	Does not exist
Instance on Room 515	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q116

Question	Response
COMPUTER LAB	
LIGHTING	
Lighting Fixture - HID	
Instance on Room 515	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 515	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 515	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
BATTERY PACK	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
BATTERY PACK	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Does not exist
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
AREA SMOKE DETECTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
BELL/HORN	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
DUCT SMOKE DETECTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
ELEVATOR RECALL	Does not exist
FAN SHUTDOWN CONTROL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
FIRE ALARM DIGITAL COMMUNICATOR	Does not exist
FUSED CUTOFF PANEL	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
HEAT DETECTOR	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
MAGNETIC DOOR HOLDER CONTACTOR	Does not exist
MAIN PANEL	Inspected
Bell At Panel	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q116

Question	Response
FIRE ALARM SYSTEM	
MAIN PANEL	
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Lobby
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	GE
Model	EST-2
EquipmentId	Fire Alarm Control Panel
Capacity/Size	8 Zones
Installation Year	2005
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist
MANUAL PULL STATION	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
REMOTE ANNUNCIATOR	Inspected
Display Monitor	Does not exist
Panel	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Punch Register	Does not exist
SPRINKLER FLOW/AIR PRESSURE SWITCH	Does not exist
STROBE	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
SUB-PANEL	Does not exist
TAMPER FLOW SWITCH/CHAIN	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	Inspected
Instance	3rd Floor
LIGHTING	
Instance on 3rd Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 3rd Floor	Does not exist
Lighting Fixture - HID	
Instance on 3rd Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 3rd Floor	Inspected
Pendant Mounted	
Instance on 3rd Floor	Does not exist
Recessed Mounted	
Instance on 3rd Floor	Does not exist
Surface Mounted	
Instance on 3rd Floor	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q116

Question	Response
GYMNASIUM	
LIGHTING	
Lighting Fixture - Incandescent	
Surface Mounted	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
LOCAL SOUND SYSTEM	
Instance on 3rd Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
SCOREBOARD	
Instance on 3rd Floor	Does not exist
THEATER LIGHTING SYSTEM	
Instance on 3rd Floor	Does not exist
INTERCOM SYSTEM	
	Does not exist
KITCHEN/WARMING PANTRY	
Instance	Inspected
	1st Floor
LIGHTING	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
LAN	
	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q116

Question	Response
LAN	
LOCAL DISTRIBUTION FRAME (I/LDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MAIN EQUIPMENT RACK (MDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	Room 407
Has LAN/Modem access	Yes
LIGHTING	
Instance on Room 407	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 407	Inspected
Pendant Mounted	
Instance on Room 407	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	27
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room 407	Does not exist
Surface Mounted	
Instance on Room 407	Does not exist
Lighting Fixture - HID	
Instance on Room 407	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 407	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 407	Does not exist
SMART BOARD	
Instance on Room 407	Does not exist
LIGHTING - SECURITY LIGHTS	Inspected
Condition	2- Between Good and Fair
Replacement Quantity	21
Replacement Uom	EACH
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Roof Lights
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
LIGHTNING PROTECTION	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
LOCKER ROOM	Does not exist
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q116

Question	Response
MOTOR STARTER/CONTACTOR	
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
FUSED DISCONNECT SWITCH TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Corridors (1st fl, 2nd fl, and 4th fl)
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED KNIFE SWITCH TYPE	Does not exist
FUSED TOGGLE SWITCH TYPE	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Corridors (All Floors)
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	Inspected
Instance	General Office
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Dukane
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	
Instance on Room 507	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 507	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room 507	Inspected
Instance Condition	1- Good

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q116

Question	Response
SCIENCE LAB	
EMERGENCY SHUT-OFF POWER	
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Room 507	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 507	Inspected
Pendant Mounted	
Instance on Room 507	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 507	Does not exist
Surface Mounted	
Instance on Room 507	Does not exist
Lighting Fixture - HID	
Instance on Room 507	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 507	Does not exist
POWER SUPPLY	
Instance on Room 507	Does not exist
PROJECTION SYSTEM	
Instance on Room 507	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
SMART BOARD	
Instance on Room 507	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
SCIENCE PREP ROOM	
	Does not exist
SECURITY	
	Inspected
INTRUSION ALARM	
	Inspected
Central Control Panel	
	Inspected
Instance	Custodian Office
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Deficiency	No deficiencies recorded
Infrared Sensor	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	
	Inspected
Condition	3- Fair
Deficiency	SENSOR NOT IN USE

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q116

Question	Response
SECURITY	
INTRUSION ALARM	
Ultrasonic Sensor	
Deficiency Location/Instance	@ Cafeteria Entrance
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
IPDVS/CCTV SYSTEM	Does not exist
SERVICE SWITCH	Inspected
Instance	Electrical Room (Basement)
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lexington Electric
EquipmentId	Main Service Switch (1000A Fuse)
Capacity/Size	1000 Amps
Source of Capacity/Size	Fuse Size
Installation Year	1962
Source of Installation Year	Documented
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SWIMMING POOL	Does not exist
SWITCHBOARD	Inspected
Water Penetration In Electrical Room?	Yes
Number of Spares	1
AIR CIRCUIT BREAKER TYPE	Does not exist
FUSED DISCONNECT SWITCH TYPE	Inspected
Instance	Electrical Room (Basement)
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lexington Electric
EquipmentId	Main Switchboard
Capacity/Size	1000 Amps total, 2 sections
Source of Capacity/Size	Service Switch Fuse Size
Installation Year	1962
Source of Installation Year	Estimated
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q116

Question	Response
SWITCHBOARD	
FUSED DISCONNECT SWITCH TYPE	
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED KNIFE SWITCH TYPE	
	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	
	Does not exist
TELEPHONE	
	Under construction
TOILET ROOM - STAFF	
	Inspected
LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
	Does not exist
Surface Mounted	
	Does not exist
Lighting Fixture - HID	
	Does not exist
Lighting Fixture - Incandescent	
Pendant Mounted	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
	Does not exist
Surface Mounted	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TOILET ROOM - STUDENT	
	Inspected
LIGHTING	
Lighting Fixture - Fluorescent	
	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q116

Question	Response
TOILET ROOM - STUDENT	
LIGHTING	
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	14
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable System Exist?	Yes
Operational?	Yes
Master Antenna System Exist?	No
MAIN EQUIPMENT RACK	Does not exist