

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q226

School: **I.S. 226 - QUEENS, 121-10 ROCKAWAY BLVD, QUEENS, NY, 11420**

InspectionId	Inspection Type	Time In	Last Edited
1550122	ELECTRICAL	2011-03-01 09:05AM	2011-03-21 03:22PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Theater Lights and Dimming System in Auditorium Years: 2009 Systems: Smart Boards Years: 2010 Systems: Fire Alarm (Main System) ,Telephone , Intercom Elevator), Emergency Generator (Used for Pumps Only), New Wing (Electrical Systems) Years: 2000 Systems: Fluorescent (Mainly Retro-Fit) and HID Lighting Years: 2000 Systems: Security Lights Years: 1998 (estimate) Systems: Emergency and Exit Lights (Battery Packs) Years: 1997, 2000 (Estimate) Systems: Intrusion Alarm and CCTV Systems Years: Under Construction Systems: Public Address System Years: Approximately 2000 Type of Service Below Ground

Priority Condition

No condition recorded

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	1st Floor
HOUSE LIGHTING	
Instance on 1st Floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q226

Question	Response
AUDITORIUM	
HOUSE LIGHTING	
Lighting Fixture - Incandescent	
Pendant Mounted	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 1st Floor	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
PROJECTION SYSTEM	
Instance on 1st Floor	Does not exist
THEATER LIGHTING SYSTEM	
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA	
Instance	First Floor (Teacher's)
Instance	First Floor (Student's - New Wing)
Instance	First Floor (Student's - Old Wing)
LIGHTING	
Instance on First Floor (Teacher's)	Inspected
Instance on First Floor (Student's - New Wing)	Inspected
Instance on First Floor (Student's - Old Wing)	Inspected
Lighting Fixture - Fluorescent	
Instance on First Floor (Teacher's)	Inspected
Instance on First Floor (Student's - New Wing)	Inspected
Instance on First Floor (Student's - Old Wing)	Inspected
Pendant Mounted	
Instance on First Floor (Teacher's)	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q226

Question	Response
CAFETERIA	
LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on First Floor (Student's - New Wing)	Does not exist
Instance on First Floor (Student's - Old Wing)	Does not exist
Recessed Mounted	
Instance on First Floor (Teacher's)	Does not exist
Instance on First Floor (Student's - New Wing)	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on First Floor (Student's - Old Wing)	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on First Floor (Teacher's)	Does not exist
Instance on First Floor (Student's - New Wing)	Does not exist
Instance on First Floor (Student's - Old Wing)	Does not exist
Lighting Fixture - HID	
Instance on First Floor (Teacher's)	Does not exist
Instance on First Floor (Student's - New Wing)	Does not exist
Instance on First Floor (Student's - Old Wing)	Does not exist
Lighting Fixture - Incandescent	
Instance on First Floor (Teacher's)	Does not exist
Instance on First Floor (Student's - New Wing)	Does not exist
Instance on First Floor (Student's - Old Wing)	Does not exist
LOCAL SOUND SYSTEM	
Instance on First Floor (Teacher's)	Does not exist
Instance on First Floor (Student's - New Wing)	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on First Floor (Student's - Old Wing)	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
CITY FIRE ALARM SYSTEM	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Does a Chandelier Exist?	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Pendant Mounted	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q226

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SMART BOARD	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
COMPUTER LAB	Inspected
Instance	Room 176
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room 223
Has LAN/Modem access	Yes
Power Panel?	Yes
LIGHTING	
Instance on Room 176	Inspected
Instance on Room 223	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 176	Inspected
Instance on Room 223	Inspected
Pendant Mounted	
Instance on Room 176	Does not exist
Instance on Room 223	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 176	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 223	Does not exist
Surface Mounted	
Instance on Room 176	Does not exist
Instance on Room 223	Does not exist
Lighting Fixture - HID	
Instance on Room 176	Does not exist
Instance on Room 223	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 176	Does not exist
Instance on Room 223	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q226

Question	Response
COMPUTER LAB	
RACEWAY WITH RECEPTACLES	
Instance on Room 176	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 223	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	
Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY GENERATOR SET	
AUTOMATIC TRANSFER SWITCH (ATS)	
Instance	Room C19
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Cummins/Onan
EquipmentId	Transfer Switch
Capacity/Size	125 Amps
Installation Year	2000
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
BATTERY CHARGER	
Instance	Room C19
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Cummins/Onan
EquipmentId	Battery Float Charger
Capacity/Size	10 Amps DC, 12VDC
Installation Year	2000
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
DIESEL	
Instance	Room C19
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Cummins/Onan
EquipmentId	Gen Set
Capacity/Size	25 kVA, 20 kW, 70 Amps
Installation Year	2000
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
NATURAL GAS	
Does not exist	
EMERGENCY LIGHT/EXIT LIGHT PANEL	
Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	
BATTERY PACK	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q226

Question	Response
EMERGENCY LIGHTING	
Non Battery Pack	
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
BATTERY PACK	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
AREA SMOKE DETECTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
BELL/HORN	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
DUCT SMOKE DETECTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
ELEVATOR RECALL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
FAN SHUTDOWN CONTROL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
FIRE ALARM DIGITAL COMMUNICATOR	Does not exist
FUSED CUTOFF PANEL	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
HEAT DETECTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MAGNETIC DOOR HOLDER CONTACTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MAIN PANEL	Inspected
Bell At Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards Systems Technology
Model	EST-2
EquipmentId	Fire Command Station
Capacity/Size	16 Zones
Installation Year	2000
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q226

Question	Response
FIRE ALARM SYSTEM	
MANUAL PULL STATION	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
REMOTE ANNUNCIATOR	Inspected
Display Monitor	Does not exist
Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Punch Register	Does not exist
SPRINKLER FLOW/AIR PRESSURE SWITCH	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
STROBE	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SUB-PANEL	Inspected
Bell At Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Faraday
Model	N/A
EquipmentId	Duct Detection
Capacity/Size	8 Zones
Installation Year	1990
Source of Installation Year	Estimated
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist
TAMPER FLOW SWITCH/CHAIN	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	Inspected
Instance	2nd Floor
LIGHTING	
Instance on 2nd Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 2nd Floor	Does not exist
Lighting Fixture - HID	
Instance on 2nd Floor	Inspected
Pendant Mounted	
Instance on 2nd Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	5

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q226

Question	Response
GYMNASIUM	
LIGHTING	
Lighting Fixture - HID	
Pendant Mounted	
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 2nd Floor	Does not exist
Surface Mounted	
Instance on 2nd Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 2nd Floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 2nd Floor	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SCOREBOARD	
Instance on 2nd Floor	Does not exist
THEATER LIGHTING SYSTEM	
Instance on 2nd Floor	Does not exist
INTERCOM SYSTEM	
	Inspected
ELEVATOR	
Condition	3- Fair
Deficiency	No deficiencies recorded
HOLDING AREA	
Condition	3- Fair
Deficiency	No deficiencies recorded
KITCHEN/WARMING PANTRY	
	Inspected
Instance	1st Floor (Old Wing)
Instance	1st Floor (New Wing)
LIGHTING	
Instance on 1st Floor (Old Wing)	Inspected
Instance on 1st Floor (New Wing)	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor (Old Wing)	Inspected
Instance on 1st Floor (New Wing)	Inspected
Pendant Mounted	
Instance on 1st Floor (Old Wing)	Does not exist
Instance on 1st Floor (New Wing)	Does not exist
Recessed Mounted	
Instance on 1st Floor (Old Wing)	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor (New Wing)	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q226

Question	Response
KITCHEN/WARMING PANTRY	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Instance on 1st Floor (Old Wing)	Does not exist
Instance on 1st Floor (New Wing)	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor (Old Wing)	Does not exist
Instance on 1st Floor (New Wing)	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor (Old Wing)	Does not exist
Instance on 1st Floor (New Wing)	Does not exist
LAN	Inspected
LOCAL DISTRIBUTION FRAME (I/LDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MAIN EQUIPMENT RACK (MDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	Room 329
Has LAN/Modem access	Yes
LIGHTING	
Instance on Room 329	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 329	Inspected
Pendant Mounted	
Instance on Room 329	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 329	Does not exist
Surface Mounted	
Instance on Room 329	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room 329	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 329	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 329	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SMART BOARD	
Instance on Room 329	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
LIGHTING - SECURITY LIGHTS	Inaccessible
LIGHTNING PROTECTION	Does not exist
LOCKER ROOM	
Instance on Rooms 233 (Boys), 229(Girls)	Inspected
Alternative Use	No
LIGHTING	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q226

Question	Response
LOCKER ROOM	
LIGHTING	
Instance on Rooms 233 (Boys), 229(Girls)	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms 233 (Boys), 229(Girls)	Inspected
Pendant Mounted	
Instance on Rooms 233 (Boys), 229(Girls)	Does not exist
Recessed Mounted	
Instance on Rooms 233 (Boys), 229(Girls)	Does not exist
Surface Mounted	
Instance on Rooms 233 (Boys), 229(Girls)	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Rooms 233 (Boys), 229(Girls)	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms 233 (Boys), 229(Girls)	Does not exist
MOTOR CONTROL CENTER	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	N/A
Capacity/Size	N/A, 4 sections
Installation Year	1975
Source of Installation Year	Documented
Deficiency	MCC NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	MCC ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
FUSED DISCONNECT SWITCH TYPE	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
FUSED KNIFE SWITCH TYPE	Does not exist
FUSED TOGGLE SWITCH TYPE	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
MOLDED CASE CIRCUIT BREAKER TYPE	Inspected
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q226

Question	Response
PANEL BOARD	
MOLDED CASE CIRCUIT BREAKER TYPE	
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	
Instance	Room 316
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Dukane
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	
	Does not exist
SCIENCE LAB	
Instance on Rooms 205, 207, 305, 307, 405, 407	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	Yes
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Rooms 205, 207, 305, 307, 405, 407	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
EMERGENCY SHUT-OFF POWER	
Instance on Rooms 205, 207, 305, 307, 405, 407	Does not exist
LIGHTING	
Instance on Rooms 205, 207, 305, 307, 405, 407	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms 205, 207, 305, 307, 405, 407	Inspected
Pendant Mounted	
Instance on Rooms 205, 207, 305, 307, 405, 407	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Rooms 205, 207, 305, 307, 405, 407	Does not exist
Surface Mounted	
Instance on Rooms 205, 207, 305, 307, 405, 407	Does not exist
Lighting Fixture - HID	
Instance on Rooms 205, 207, 305, 307, 405, 407	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms 205, 207, 305, 307, 405, 407	Does not exist
POWER SUPPLY	
Instance on Rooms 205, 207, 305, 307, 405, 407	Does not exist
PROJECTION SYSTEM	
Instance on Rooms 205, 207, 305, 307, 405, 407	Does not exist
SMART BOARD	
Instance on Rooms 205, 207, 305, 307, 405, 407	Does not exist
SCIENCE PREP ROOM	
Instance on Room 341	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q226

Question	Response
SCIENCE PREP ROOM	
Alternative Use	Yes
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 341	Does not exist
EMERGENCY SHUT-OFF POWER	
Instance on Room 341	Does not exist
LIGHTING	
Instance on Room 341	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 341	Inspected
Pendant Mounted	
Instance on Room 341	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 341	Does not exist
Surface Mounted	
Instance on Room 341	Does not exist
Lighting Fixture - HID	
Instance on Room 341	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 341	Does not exist
POWER SUPPLY	
Instance on Room 341	Does not exist
SECURITY	Under construction
SERVICE SWITCH	Inspected
Instance	Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Metropolitan Electric Corp.
EquipmentId	Service Disconnect SWBD #1
Capacity/Size	2500 Amps
Source of Capacity/Size	Fuse Size
Installation Year	1975
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SWIMMING POOL	Does not exist
SWITCHBOARD	Inspected
Water Penetration In Electrical Room?	No
Number of Spares	01
AIR CIRCUIT BREAKER TYPE	Does not exist
FUSED DISCONNECT SWITCH TYPE	Inspected
Instance	Electric Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Metropolitan Electric Corp.
EquipmentId	N/A
Capacity/Size	2500 Amps total, 4 sections
Source of Capacity/Size	Service Switch Fuse Size
Installation Year	1975
Source of Installation Year	Documented
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q226

Question	Response
SWITCHBOARD	
FUSED DISCONNECT SWITCH TYPE	
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electric Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Metropolitan Electric Corp.
EquipmentId	N/A
Capacity/Size	2500 Amps total, 4 sections
Source of Capacity/Size	Service Switch Fuse Size
Installation Year	1975
Source of Installation Year	Documented
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED KNIFE SWITCH TYPE	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	Does not exist
TELEPHONE	Inspected
PBX/INTERCOM	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
STANDARD	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q226

Question	Response
TOILET ROOM - STAFF	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TOILET ROOM - STUDENT	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable System Exist?	No
Master Antenna System Exist?	Yes
Operational?	No
MAIN EQUIPMENT RACK	Does not exist