

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

School: **BEACH CHANNEL HS - Q, 100-00 BEACH CHANNEL DRI, QUEENS, NY, 11694**

InspectionId	Inspection Type	Time In	Last Edited
1254036	ELECTRICAL	2009-01-13 09:24AM	2009-02-12 11:08AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: All Lighting Years: 1996 Systems: Partial Intrusion Alarm/Exit Lights Years: 2005 Systems: Exterior Lights Years: 1998 Systems: Subs Panel Fire Alarm System Years: 2007 Systems: Partial ATS Years: 1997 Systems: LAN Years: 2006 Systems: Telephone/Emergency Light Years: 1997 Systems: Auditorium Years: Under Construction Systems: Elevator/Intercom Years: Under Construction Systems: IPDVS/CCTV System Years: 2005

Priority Condition

No condition recorded

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Under construction
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Condition	3- Fair
Replacement Quantity	397,000
Replacement Uom	S.F.
Deficiency	DOOR PUSH BUTTON NOT OPERATIONAL
Deficiency Location/Instance	Main Entrance
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
CAFETERIA	Inspected
Instance	1st Floor-Students
Instance	2nd Floor - Students
Instance	2nd Floor -Teachers
Lighting	
Instance on 1st Floor-Students	Inspected
Instance on 2nd Floor - Students	Inspected
Instance on 2nd Floor -Teachers	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor-Students	Inspected
Instance on 2nd Floor - Students	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
CAFETERIA	
Lighting	
Lighting Fixture - Fluorescent	
Instance on 2nd Floor -Teachers	Inspected
Pendant Mounted	
Instance on 1st Floor-Students	Does not exist
Instance on 2nd Floor - Students	Does not exist
Instance on 2nd Floor -Teachers	Does not exist
Recessed Mounted	
Instance on 1st Floor-Students	Does not exist
Instance on 2nd Floor - Students	Does not exist
Instance on 2nd Floor -Teachers	Does not exist
Surface Mounted	
Instance on 1st Floor-Students	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on 2nd Floor - Students	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL NEW LAMP
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd Floor -Teachers	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on 1st Floor-Students	Does not exist
Instance on 2nd Floor - Students	Does not exist
Instance on 2nd Floor -Teachers	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor-Students	Inspected
Instance on 2nd Floor - Students	Inspected
Instance on 2nd Floor -Teachers	Does not exist
Pendant Mounted	
Instance on 1st Floor-Students	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd Floor - Students	Does not exist
Recessed Mounted	
Instance on 1st Floor-Students	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
CAFETERIA	
Lighting	
Lighting Fixture - Incandescent	
Recessed Mounted	
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	INSTALL NEW LAMP
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd Floor - Students	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 1st Floor-Students	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd Floor - Students	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Local Sound System	
Instance on 1st Floor-Students	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
CAFETERIA	
Local Sound System	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd Floor - Students	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd Floor -Teachers	Does not exist
CAFETERIA/MULTIPURPOSE ROOM	Does not exist
CITY FIRE ALARM SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	INSTALL NEW LAMP
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Surface Mounted	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	30

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Lighting Fixture - Incandescent	
Pendant Mounted	
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
COMPUTER LAB	Inspected
Instance	Room C399
Has LAN/Modem access	Yes
Power Panel?	No
Instance	Room C341
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room C343 and C345
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room E203
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room E297
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room E303
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room D283A
Has LAN/Modem access	Yes
Power Panel?	Yes
Lighting	
Instance on Room C399	Inspected
Instance on Room C341	Inspected
Instance on Room C343 and C345	Inspected
Instance on Room E203	Inspected
Instance on Room E297	Inspected
Instance on Room E303	Inspected
Instance on Room D283A	Inspected
Lighting Fixture - Fluorescent	
Instance on Room C399	Inspected
Instance on Room C341	Inspected
Instance on Room C343 and C345	Inspected
Instance on Room E203	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
COMPUTER LAB	
Lighting	
Lighting Fixture - Fluorescent	
Instance on Room E297	Inspected
Instance on Room E303	Inspected
Instance on Room D283A	Inspected
Pendant Mounted	
Instance on Room C399	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room C341	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room C343 and C345	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room E203	Does not exist
Instance on Room E297	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E303	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room D283A	Does not exist
Recessed Mounted	
Instance on Room C399	Does not exist
Instance on Room C341	Does not exist
Instance on Room C343 and C345	Does not exist
Instance on Room E203	Does not exist
Instance on Room E297	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
COMPUTER LAB	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Instance on Room E303	Does not exist
Instance on Room D283A	Does not exist
Surface Mounted	
Instance on Room C399	Does not exist
Instance on Room C341	Does not exist
Instance on Room C343 and C345	Does not exist
Instance on Room E203	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room E297	Does not exist
Instance on Room E303	Does not exist
Instance on Room D283A	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room C399	Does not exist
Instance on Room C341	Does not exist
Instance on Room C343 and C345	Does not exist
Instance on Room E203	Does not exist
Instance on Room E297	Does not exist
Instance on Room E303	Does not exist
Instance on Room D283A	Does not exist
Lighting Fixture - Incandescent	
Instance on Room C399	Does not exist
Instance on Room C341	Does not exist
Instance on Room C343 and C345	Does not exist
Instance on Room E203	Does not exist
Instance on Room E297	Does not exist
Instance on Room E303	Does not exist
Instance on Room D283A	Does not exist
Raceway With Receptacles	
Instance on Room C399	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room C341	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room C343 and C345	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E203	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E297	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
COMPUTER LAB	
Raceway With Receptacles	
Deficiency	No deficiencies recorded
Instance on Room E303	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D283A	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
ELECTRIC SERVICE SWITCH	
Instance	Inspected
Instance Condition	Electrical Room in Cafeteria
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lexington
Model	Lexington
EquipmentId	Main Service 1 and 2
Capacity/Size	N/A
Installation Year	1973
Deficiency	SWITCH NAME PLATE IS MISSING
Deficiency Location/Instance	Electrical Room in Cafeteria
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
EMERGENCY DC STANDBY BATTERY POWER	
	Does not exist
EMERGENCY GENERATOR SET	
Automatic Transfer Switch (ATS)	
Instance	Inspected
Instance Condition	Boiler Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ASCO
EquipmentId	ATS
Capacity/Size	100 Amps
Installation Year	1997
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ASCO
EquipmentId	ATS
Capacity/Size	260 Amps
Installation Year	1997
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ASCO
EquipmentId	ATS
Capacity/Size	400 Amps

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
EMERGENCY GENERATOR SET	
Automatic Transfer Switch (ATS)	
Installation Year	1973
Deficiency	No deficiencies recorded
Instance	Electrical Room in Cafeteria
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Onan
EquipmentId	Generator ATS
Capacity/Size	400 Amps
Installation Year	1973
Deficiency	No deficiencies recorded
Instance	Electrical Room in Cafeteria
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Onan
EquipmentId	Smoke Detector ATS
Capacity/Size	100 Amps
Installation Year	1973
Deficiency	No deficiencies recorded
Instance	Electrical Room in Cafeteria
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Onan
EquipmentId	Fire Alarm ATS
Capacity/Size	100 Amps
Installation Year	1973
Deficiency	No deficiencies recorded
Battery Charger	Inspected
Instance	Electrical Room in Cafeteria
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Onan
EquipmentId	Battery Charger
Capacity/Size	10 AmpsDC, 40 VDC
Installation Year	1973
Deficiency	No deficiencies recorded
Diesel	Does not exist
Natural Gas	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Onan
EquipmentId	Emergency Generator
Capacity/Size	170 kw, 213 kva
Installation Year	1973
Deficiency	No deficiencies recorded
EMERGENCY LIGHT/EXIT LIGHT PANEL	
Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Connected To Emergency Generator System	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Connected To Emergency Light/Exit Light Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Relay Test Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Connected To Emergency Generator System	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Connected To Emergency Light/Exit Light Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
FIRE ALARM SYSTEM	Inspected
Replacement Quantity	397,000
Replacement Uom	S.F.
Area Smoke Detector	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Bell/Horn	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Duct Smoke Detector	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Elevator Recall	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not exist
Fused Cutout Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Heat Detector	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Magnetic Door Holder Contactor	Does not exist
Main Panel	Inspected
Bell At Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Does not exist

NYC Department of Education
Building Condition Assessment Survey 2008-2009

Electrical Inspection

Q410

Question	Response
FIRE ALARM SYSTEM	
Main Panel	
Fire Alarm Control Panel (Standard)	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Standard Electric
EquipmentId	Fire Alarm Control Panel
Capacity/Size	22 circuits
Installation Year	1973
Deficiency	No deficiencies recorded
Manual Pull Station	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Display Monitor	Does not exist
Panel	Does not exist
Printer	Does not exist
Punch Register	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Sprinkler Flow/Air Pressure Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Sub-Panel	Inspected
Bell At Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Boiler Room
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Mircom
Model	FX-2000
EquipmentId	Intelligent Fire Alarm Control Panel
Capacity/Size	N/A
Installation Year	2007
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Faraday
EquipmentId	Elevator Recall Panel
Capacity/Size	12 circuits
Installation Year	1973
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
FIRE ALARM SYSTEM	
Sub-Panel	
Fire Alarm Control Panel (Standard)	
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Standard Electric
EquipmentId	Smoke Detector and Fan Shutdown Panel Control
Capacity/Size	4 circuits
Installation Year	1973
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Standard Electric
EquipmentId	Sprinkler Control Panel
Capacity/Size	8 circuits
Installation Year	1973
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Standard Electric
EquipmentId	Punch Register Panel
Capacity/Size	2 circuits
Installation Year	1973
Deficiency	No deficiencies recorded
Tamper Flow Switch/Chain	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	Inspected
Instance	1st Floor-Gym A
Instance	1st Floor-Gym B
Instance	1st Floor-Gym C
Instance	1st Floor-Gym F
Instance	1st Floor-Gym G
Instance	2nd Floor-Gym D-E
Instance	2nd Floor-Gym H
Lighting	
Instance on 1st Floor-Gym A	Inspected
Instance on 1st Floor-Gym B	Inspected
Instance on 1st Floor-Gym C	Inspected
Instance on 1st Floor-Gym F	Inspected
Instance on 1st Floor-Gym G	Inspected
Instance on 2nd Floor-Gym D-E	Inspected
Instance on 2nd Floor-Gym H	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor-Gym A	Does not exist
Instance on 1st Floor-Gym B	Does not exist
Instance on 1st Floor-Gym C	Inspected
Instance on 1st Floor-Gym F	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
GYMNASIUM	
Lighting	
Lighting Fixture - Fluorescent	
Instance on 1st Floor-Gym G	Does not exist
Instance on 2nd Floor-Gym D-E	Does not exist
Instance on 2nd Floor-Gym H	Does not exist
Pendant Mounted	
Instance on 1st Floor-Gym C	Does not exist
Recessed Mounted	
Instance on 1st Floor-Gym C	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 1st Floor-Gym C	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor-Gym A	Inspected
Instance on 1st Floor-Gym B	Inspected
Instance on 1st Floor-Gym C	Does not exist
Instance on 1st Floor-Gym F	Inspected
Instance on 1st Floor-Gym G	Inspected
Instance on 2nd Floor-Gym D-E	Inspected
Instance on 2nd Floor-Gym H	Inspected
Pendant Mounted	
Instance on 1st Floor-Gym A	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor-Gym B	Does not exist
Instance on 1st Floor-Gym F	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor-Gym G	Does not exist
Instance on 2nd Floor-Gym D-E	Does not exist
Instance on 2nd Floor-Gym H	Does not exist
Recessed Mounted	
Instance on 1st Floor-Gym A	Does not exist
Instance on 1st Floor-Gym B	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 1st Floor-Gym F	Does not exist
Instance on 1st Floor-Gym G	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1

NYC Department of Education
Building Condition Assessment Survey 2008-2009

Electrical Inspection

Q410

Question	Response
GYMNASIUM	
Lighting	
Lighting Fixture - HID	
Recessed Mounted	
Quantity Uom	EACH
Potential Action	INSTALL NEW LAMP
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd Floor-Gym D-E	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on 2nd Floor-Gym H	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st Floor-Gym A	Does not exist
Instance on 1st Floor-Gym B	Does not exist
Instance on 1st Floor-Gym F	Does not exist
Instance on 1st Floor-Gym G	Does not exist
Instance on 2nd Floor-Gym D-E	Does not exist
Instance on 2nd Floor-Gym H	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor-Gym A	Does not exist
Instance on 1st Floor-Gym B	Does not exist
Instance on 1st Floor-Gym C	Does not exist
Instance on 1st Floor-Gym F	Does not exist
Instance on 1st Floor-Gym G	Does not exist
Instance on 2nd Floor-Gym D-E	Does not exist
Instance on 2nd Floor-Gym H	Does not exist
Local Sound System	
Instance on 1st Floor-Gym A	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 1st Floor-Gym B	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 1st Floor-Gym C	Does not exist
Instance on 1st Floor-Gym F	Does not exist
Instance on 1st Floor-Gym G	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
GYMNASIUM	
Local Sound System	
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd Floor-Gym D-E	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd Floor-Gym H	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Scoreboard	
Instance on 1st Floor-Gym A	Does not exist
Instance on 1st Floor-Gym B	Does not exist
Instance on 1st Floor-Gym C	Does not exist
Instance on 1st Floor-Gym F	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor-Gym G	Does not exist
Instance on 2nd Floor-Gym D-E	Does not exist
Instance on 2nd Floor-Gym H	Does not exist
Theater Lighting System	
Instance on 1st Floor-Gym A	Does not exist
Instance on 1st Floor-Gym B	Does not exist
Instance on 1st Floor-Gym C	Does not exist
Instance on 1st Floor-Gym F	Does not exist
Instance on 1st Floor-Gym G	Does not exist
Instance on 2nd Floor-Gym D-E	Does not exist
Instance on 2nd Floor-Gym H	Does not exist
INTERCOM SYSTEM	
	Inspected
Elevator	Under construction
Holding Area	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
KITCHEN/WARMING PANTRY	
	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
KITCHEN/WARMING PANTRY	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
	Does not exist
Lighting Fixture - HID	
	Does not exist
Lighting Fixture - Incandescent	
	Inspected
Pendant Mounted	
	Does not exist
Recessed Mounted	
	Does not exist
Surface Mounted	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
LAN	Inspected
Local Distribution Frame (I/LDF)	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	Room D180
Has LAN/Modem access	Yes
Lighting	
Instance on Room D180	Inspected
Lighting Fixture - Fluorescent	
Instance on Room D180	Inspected
Pendant Mounted	
Instance on Room D180	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room D180	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on Room D180	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room D180	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
LIBRARY	
Lighting	
Lighting Fixture - Incandescent	
Instance on Room D180	Does not exist
Raceway With Receptacles	
Instance on Room D180	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
LIGHTING - EXTERIOR SECURITY	Inspected
Condition	3- Fair
Replacement Quantity	100
Replacement Uom	EACH
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Back and 2 sides of the school
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
LIGHTNING PROTECTION	Does not exist
LOCKER ROOM/SHOWER ROOM	Inspected
Instance	1st Floor - Boys
Alternative Use	No
Instance	2nd Floor - Girls
Alternative Use	No
Lighting	
Instance on 1st Floor - Boys	Inspected
Instance on 2nd Floor - Girls	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor - Boys	Inspected
Instance on 2nd Floor - Girls	Inspected
Pendant Mounted	
Instance on 1st Floor - Boys	Does not exist
Instance on 2nd Floor - Girls	Does not exist
Recessed Mounted	
Instance on 1st Floor - Boys	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on 2nd Floor - Girls	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st Floor - Boys	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd Floor - Girls	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
LOCKER ROOM/SHOWER ROOM	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	INSTALL NEW LAMP
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on 1st Floor - Boys	Does not exist
Instance on 2nd Floor - Girls	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor - Boys	Does not exist
Instance on 2nd Floor - Girls	Does not exist
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	Inspected
Replacement Quantity	397,000
Replacement Uom	S.F.
Instance	General office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Rauland SRX173
Deficiency	AMPLIFIER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	General Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	MASTER CLOCK BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	General Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
SCIENCE DEMO ROOM	Inspected
Instance	Room D325
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	Room D322
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance	Room D218, D222, D224, D228
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	Room D327, D328, D330
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	Room D324
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	Room D230
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	Room E299
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on Room D325	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D322	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D218, D222, D224, D228	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D327, D328, D330	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D324	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D230	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E299	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room D325	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
SCIENCE DEMO ROOM	
Emergency Shut-Off Power	
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D322	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D218, D222, D224, D228	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D327, D328, D330	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D324	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D230	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E299	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting	
Instance on Room D325	Inspected
Instance on Room D322	Inspected
Instance on Room D218, D222, D224, D228	Inspected
Instance on Room D327, D328, D330	Inspected
Instance on Room D324	Inspected
Instance on Room D230	Inspected
Instance on Room E299	Inspected
Lighting Fixture - Fluorescent	
Instance on Room D325	Inspected
Instance on Room D322	Inspected
Instance on Room D218, D222, D224, D228	Inspected
Instance on Room D327, D328, D330	Inspected
Instance on Room D324	Inspected
Instance on Room D230	Inspected
Instance on Room E299	Inspected
Pendant Mounted	
Instance on Room D325	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D322	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D218, D222, D224, D228	Does not exist
Instance on Room D327, D328, D330	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D324	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D230	Does not exist
Instance on Room E299	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
SCIENCE DEMO ROOM	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Instance on Room D325	Does not exist
Instance on Room D322	Does not exist
Instance on Room D218, D222, D224, D228	Does not exist
Instance on Room D327, D328, D330	Does not exist
Instance on Room D324	Does not exist
Instance on Room D230	Does not exist
Instance on Room E299	Does not exist
Surface Mounted	
Instance on Room D325	Does not exist
Instance on Room D322	Does not exist
Instance on Room D218, D222, D224, D228	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D327, D328, D330	Does not exist
Instance on Room D324	Does not exist
Instance on Room D230	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E299	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room D325	Does not exist
Instance on Room D322	Does not exist
Instance on Room D218, D222, D224, D228	Does not exist
Instance on Room D327, D328, D330	Does not exist
Instance on Room D324	Does not exist
Instance on Room D230	Does not exist
Instance on Room E299	Does not exist
Lighting Fixture - Incandescent	
Instance on Room D325	Does not exist
Instance on Room D322	Does not exist
Instance on Room D218, D222, D224, D228	Does not exist
Instance on Room D327, D328, D330	Does not exist
Instance on Room D324	Does not exist
Instance on Room D230	Does not exist
Instance on Room E299	Does not exist
Power Supply	
Instance on Room D325	Inspected
Instance on Room D322	Inspected
Instance on Room D218, D222, D224, D228	Inspected
Instance on Room D327, D328, D330	Inspected
Instance on Room D324	Inspected
Instance on Room D230	Inspected
Instance on Room E299	Inspected
Instructor Unit	
Instance on Room D325	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D322	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
SCIENCE DEMO ROOM	
Power Supply	
Instructor Unit	
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D218, D222, D224, D228	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D327, D328, D330	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D324	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D230	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E299	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room D325	Does not exist
Instance on Room D322	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D218, D222, D224, D228	Does not exist
Instance on Room D327, D328, D330	Does not exist
Instance on Room D324	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D230	Does not exist
Instance on Room E299	Does not exist
SCIENCE LAB	Inspected
Instance	Room E106
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	Room E204
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance	Room E316
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance	Room E304
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance	Room E112
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	Room D318

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
SCIENCE LAB	
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance	Room E212
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on Room E106	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E204	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E316	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E304	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E112	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D318	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E212	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room E106	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E204	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E316	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E304	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E112	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D318	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E212	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting	
Instance on Room E106	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
SCIENCE LAB	
Lighting	
Instance on Room E204	Inspected
Instance on Room E316	Inspected
Instance on Room E304	Inspected
Instance on Room E112	Inspected
Instance on Room D318	Inspected
Instance on Room E212	Inspected
Lighting Fixture - Fluorescent	
Instance on Room E106	Inspected
Instance on Room E204	Inspected
Instance on Room E316	Inspected
Instance on Room E304	Inspected
Instance on Room E112	Inspected
Instance on Room D318	Inspected
Instance on Room E212	Inspected
Pendant Mounted	
Instance on Room E106	Does not exist
Instance on Room E204	Does not exist
Instance on Room E316	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E304	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E112	Does not exist
Instance on Room D318	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E212	Does not exist
Recessed Mounted	
Instance on Room E106	Does not exist
Instance on Room E204	Does not exist
Instance on Room E316	Does not exist
Instance on Room E304	Does not exist
Instance on Room E112	Does not exist
Instance on Room D318	Does not exist
Instance on Room E212	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	INSTALL NEW LAMP
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on Room E106	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E204	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E316	Does not exist
Instance on Room E304	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
SCIENCE LAB	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Instance on Room E112	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D318	Does not exist
Instance on Room E212	Does not exist
Lighting Fixture - HID	
Instance on Room E106	Does not exist
Instance on Room E204	Does not exist
Instance on Room E316	Does not exist
Instance on Room E304	Does not exist
Instance on Room E112	Does not exist
Instance on Room D318	Does not exist
Instance on Room E212	Does not exist
Lighting Fixture - Incandescent	
Instance on Room E106	Does not exist
Instance on Room E204	Does not exist
Instance on Room E316	Does not exist
Instance on Room E304	Does not exist
Instance on Room E112	Does not exist
Instance on Room D318	Does not exist
Instance on Room E212	Does not exist
Power Supply	
Instance on Room E106	Inspected
Instance on Room E204	Inspected
Instance on Room E316	Inspected
Instance on Room E304	Inspected
Instance on Room E112	Inspected
Instance on Room D318	Inspected
Instance on Room E212	Inspected
Instructor Unit	
Instance on Room E106	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E204	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E316	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E304	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E112	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D318	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E212	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
SCIENCE LAB	
Power Supply	
Instructor Unit	
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room E106	Does not exist
Instance on Room E204	Does not exist
Instance on Room E316	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E304	Does not exist
Instance on Room E112	Does not exist
Instance on Room D318	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E212	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Student Unit	
Instance on Room E106	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E204	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E316	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E304	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E112	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D318	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E212	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SCIENCE PREP ROOM	
Instance	Room E208
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance	Room E310
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	Room E306
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance	Room E108

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
SCIENCE PREP ROOM	
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on Room E208	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E310	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E306	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E108	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room E208	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E310	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E306	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E108	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting	
Instance on Room E208	Inspected
Instance on Room E310	Inspected
Instance on Room E306	Inspected
Instance on Room E108	Inspected
Lighting Fixture - Fluorescent	
Instance on Room E208	Inspected
Instance on Room E310	Inspected
Instance on Room E306	Inspected
Instance on Room E108	Inspected
Pendant Mounted	
Instance on Room E208	Does not exist
Instance on Room E310	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E306	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E108	Does not exist
Recessed Mounted	
Instance on Room E208	Does not exist
Instance on Room E310	Does not exist
Instance on Room E306	Does not exist
Instance on Room E108	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
SCIENCE PREP ROOM	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Instance on Room E208	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E310	Does not exist
Instance on Room E306	Does not exist
Instance on Room E108	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room E208	Does not exist
Instance on Room E310	Does not exist
Instance on Room E306	Does not exist
Instance on Room E108	Does not exist
Lighting Fixture - Incandescent	
Instance on Room E208	Does not exist
Instance on Room E310	Does not exist
Instance on Room E306	Does not exist
Instance on Room E108	Does not exist
Power Supply	
Instance on Room E208	Inspected
Instance on Room E310	Inspected
Instance on Room E306	Inspected
Instance on Room E108	Inspected
Instructor Unit	
Instance on Room E208	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E310	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E306	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E108	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SECURITY	Inspected
Replacement Quantity	397,000
Replacement Uom	S.F.
Intrusion Alarm	
Central Control Panel	
Instance	Custodian Office
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Ademco Vista-50P
Deficiency	No deficiencies recorded
Infrared Sensor	
Condition	2- Between Good and Fair
Deficiency	SENSOR NOT OPERATIONAL

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
SECURITY	
Intrusion Alarm	
Infrared Sensor	
Deficiency Location/Instance	F100 lobby and cafeteria
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
Panic Switch	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Remote Annunciator	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Siren/Strobe	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	
	Does not exist
IPDVS/CCTV System	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SWIMMING POOL	
	Inspected
Instance	1st Floor
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Local Sound System	
Instance on 1st Floor	Does not exist
SWITCHBOARD	
	Inspected
Air Circuit Breaker Type	
	Does not exist
Fused Disconnect Switch Type	
	Inspected
Instance	Electrical Room in Cafeteria
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lexington
EquipmentId	N/A
Capacity/Size	1600 Amps total, 3 sections
Installation Year	1973
Deficiency	SWITCHBOARD ID IS MISSING

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room in Cafeteria
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lexington
EquipmentId	N/A
Capacity/Size	500 Amps total, 1 section
Installation Year	1973
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room in Cafeteria
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lexington
EquipmentId	N/A
Capacity/Size	1600 Amps total, 2 sections
Installation Year	1973
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Does not exist
TELEPHONE	Inspected
PBX/Intercom	Inspected
Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q410

Question	Response
TELEPHONE	
PBX/Intercom	
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable Service	Does not exist
Main Equipment Rack	Does not exist
Master Antenna System	Inspected
Condition	5- Poor
Deficiency	ANTENNA NOT OPERATIONAL
Deficiency Location/Instance	Roof
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded