

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

School: **BEACH CHANNEL HS - Q, 100-00 BEACH CHANNEL DRIVE, QUEENS, NY, 11694**

InspectionId	Inspection Type	Time In	Last Edited
1550077	ELECTRICAL	2011-01-04 09:21AM	2011-05-09 05:50AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Elevator in D-Wing Years: 2010 Systems: Auditorium (All Elec. Components), Elevator in B-Wing, Panel Boards (Molded-Partial Years: 2009 Systems: Telephone Systems and Smart Boards Years: 2008 Systems: Fire Alarm Sub-Panel & Strobes Years: 2007 Systems: IPDVS/CCTV System, Battery Pack Exit Lights, and LAN Systems Years: 2005 - 2006 Systems: Partial ATS, Fluorescent Lighting throughout building (except partial in cafeteria and kitchen), HID Lights in CCA Space & Gymnasiums (partial) Years: 1997 Systems: Intrusion Alarm System, PA System (tuner and amplifier) Years: 1997 Systems: All other electrical equipments Years: 1973 Type of Service Below Ground

Priority Condition

Condition Description	Component Affected	Location Description	Person(s) Notified
Fire Alarm Strobes and Elevator Recall system are not operational	Fire Alarm System	Corridors, Elevators and Assembly Areas	Fireman - Joe Garguilo

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	1st Floor
HOUSE LIGHTING	
Instance on 1st Floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Lighting Fixture - Incandescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
AUDITORIUM	
HOUSE LIGHTING	
Lighting Fixture - Incandescent	
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st Floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
PROJECTION SYSTEM	
Instance on 1st Floor	Does not exist
THEATER LIGHTING SYSTEM	
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA	
Instance	Inspected
Instance	1st Floor- Student
Instance	2nd Floor- Student
Instance	2nd Floor- Staff
LIGHTING	
Instance on 1st Floor- Student	Inspected
Instance on 2nd Floor- Student	Inspected
Instance on 2nd Floor- Staff	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor- Student	Inspected
Instance on 2nd Floor- Student	Inspected
Instance on 2nd Floor- Staff	Inspected
Pendant Mounted	
Instance on 1st Floor- Student	Does not exist
Instance on 2nd Floor- Student	Does not exist
Instance on 2nd Floor- Staff	Does not exist
Recessed Mounted	
Instance on 1st Floor- Student	Does not exist
Instance on 2nd Floor- Student	Does not exist
Instance on 2nd Floor- Staff	Does not exist
Surface Mounted	
Instance on 1st Floor- Student	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on 2nd Floor- Student	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
CAFETERIA	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Deficiency	No deficiencies recorded
Instance on 2nd Floor- Staff	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor- Student	Does not exist
Instance on 2nd Floor- Student	Does not exist
Instance on 2nd Floor- Staff	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor- Student	Inspected
Instance on 2nd Floor- Student	Inspected
Instance on 2nd Floor- Staff	Does not exist
Pendant Mounted	
Instance on 1st Floor- Student	Does not exist
Instance on 2nd Floor- Student	Does not exist
Recessed Mounted	
Instance on 1st Floor- Student	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd Floor- Student	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 1st Floor- Student	Does not exist
Instance on 2nd Floor- Student	Does not exist
LOCAL SOUND SYSTEM	
Instance on 1st Floor- Student	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
CAFETERIA	
LOCAL SOUND SYSTEM	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd Floor- Student	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd Floor- Staff	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
CITY FIRE ALARM SYSTEM	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Does a Chandelier Exist?	Inspected
Lighting Fixture - Fluorescent	No
Pendant Mounted	Inspected
Condition	Inspected
Deficiency	3- Fair
Deficiency Quantity	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Quantity Uom	2
Potential Action	EACH
Urgency of Action	MAINTENANCE
Purpose of Action	PRIORITY 3
Violations	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Condition	Inspected
Deficiency	3- Fair
Deficiency Quantity	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Quantity Uom	3
Potential Action	EACH
Urgency of Action	MAINTENANCE
Purpose of Action	PRIORITY 3
Violations	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Condition	Inspected
Deficiency	3- Fair
Deficiency Quantity	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Quantity Uom	1
Potential Action	EACH
Urgency of Action	MAINTENANCE
Urgency of Action	PRIORITY 3

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
	Inspected
Pendant Mounted	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
	Does not exist
Surface Mounted	
	Does not exist
Lighting Fixture - Incandescent	
	Inspected
Pendant Mounted	
	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SMART BOARD	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
COMPUTER LAB	
	Inspected
Instance	Room C339
Has LAN/Modem access	Yes

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
COMPUTER LAB	
Power Panel?	No
Instance	Room C341
Has LAN/Modem access	Yes
Power Panel?	No
Instance	Room D283
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room E297
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room E303
Has LAN/Modem access	Yes
Power Panel?	No
LIGHTING	
Instance on Room C339	Inspected
Instance on Room C341	Inspected
Instance on Room D283	Inspected
Instance on Room E297	Inspected
Instance on Room E303	Inspected
Lighting Fixture - Fluorescent	
Instance on Room C339	Inspected
Instance on Room C341	Inspected
Instance on Room D283	Inspected
Instance on Room E297	Inspected
Instance on Room E303	Inspected
Pendant Mounted	
Instance on Room C339	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room C341	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D283	Does not exist
Instance on Room E297	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E303	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room C339	Does not exist
Instance on Room C341	Does not exist
Instance on Room D283	Does not exist
Instance on Room E297	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E303	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
COMPUTER LAB	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Instance on Room C339	Does not exist
Instance on Room C341	Does not exist
Instance on Room D283	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E297	Does not exist
Instance on Room E303	Does not exist
Lighting Fixture - HID	
Instance on Room C339	Does not exist
Instance on Room C341	Does not exist
Instance on Room D283	Does not exist
Instance on Room E297	Does not exist
Instance on Room E303	Does not exist
Lighting Fixture - Incandescent	
Instance on Room C339	Does not exist
Instance on Room C341	Does not exist
Instance on Room D283	Does not exist
Instance on Room E297	Inspected
Instance on Room E303	Does not exist
Pendant Mounted	
Instance on Room E297	Does not exist
Recessed Mounted	
Instance on Room E297	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on Room E297	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room C339	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room C341	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D283	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
COMPUTER LAB	
RACEWAY WITH RECEPTACLES	
Instance on Room E297	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E303	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	
EMERGENCY GENERATOR SET	
AUTOMATIC TRANSFER SWITCH (ATS)	
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ASCO
EquipmentId	N/A
Capacity/Size	260 Amps
Installation Year	1997
Source of Installation Year	Documented
Deficiency	ATS ID MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	ATS NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ASCO
EquipmentId	N/A
Capacity/Size	100 Amps
Installation Year	1997
Source of Installation Year	Documented
Deficiency	ATS ID MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	ATS NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
EMERGENCY GENERATOR SET	
AUTOMATIC TRANSFER SWITCH (ATS)	
Violations	No violations recorded
Instance	Electrical Room in Cafeteria
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Onan
EquipmentId	N/A
Capacity/Size	400 Amps
Installation Year	1973
Source of Installation Year	Documented
Deficiency	ATS ID MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room in Cafeteria
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Onan
EquipmentId	N/A
Capacity/Size	100 Amps
Installation Year	1973
Source of Installation Year	Documented
Deficiency	ATS ID MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room in Cafeteria
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Onan
EquipmentId	N/A
Capacity/Size	100 Amps
Installation Year	1973
Source of Installation Year	Documented
Deficiency	ATS ID MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
BATTERY CHARGER	
Instance	Inspected
Instance	Electrical Room in Cafeteria
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
EMERGENCY GENERATOR SET	
BATTERY CHARGER	
Manufacturer	Onan
EquipmentId	Battery Charger
Capacity/Size	10 AmpsDC, 24 VDC
Installation Year	1973
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
DIESEL	Does not exist
NATURAL GAS	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ONAN
EquipmentId	N/A
Capacity/Size	213 kVA, 70 kW, 591 Amps
Installation Year	1973
Source of Installation Year	Documented
Deficiency	DEFECTIVE ENGINE COOLING SYSTEM
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	GENERATOR BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
BATTERY PACK	Inspected
Condition	4- Between Fair and Poor
Deficiency	FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Corridors and Public Spaces
Deficiency Quantity	27
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
BATTERY PACK	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
EXIT LIGHT	
Non Battery Pack	
Deficiency	No deficiencies recorded
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
AREA SMOKE DETECTOR	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
BELL/HORN	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
DUCT SMOKE DETECTOR	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
ELEVATOR RECALL	Inspected
Condition	5- Poor
Deficiency	SYSTEM NOT OPERATIONAL
Deficiency Location/Instance	@ Elevators
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
FAN SHUTDOWN CONTROL	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
FIRE ALARM DIGITAL COMMUNICATOR	Does not exist
FUSED CUTOOUT PANEL	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
HEAT DETECTOR	Does not exist
MAGNETIC DOOR HOLDER CONTACTOR	Does not exist
MAIN PANEL	Inspected
Bell At Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Does not exist
Fire Alarm Control Panel (Standard)	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Standard Electric
EquipmentId	I.F.A. Control Panel
Capacity/Size	38 Circuits, 3 Sections
Installation Year	1973
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	410,000
Quantity Uom	S.F.
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
FIRE ALARM SYSTEM	
MANUAL PULL STATION	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
REMOTE ANNUNCIATOR	Inspected
Display Monitor	Does not exist
Panel	Does not exist
Printer	Does not exist
Punch Register	Inspected
Condition	5- Poor
Deficiency	REGISTER NOT OPERATIONAL
Deficiency Location/Instance	Custodian Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
SPRINKLER FLOW/AIR PRESSURE SWITCH	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
STROBE	Inspected
Condition	5- Poor
Deficiency	STROBE NOT OPERATIONAL
Deficiency Location/Instance	Corridors & Public Spaces
Deficiency Quantity	50
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
SUB-PANEL	Inspected
Bell At Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Boiler Room
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Microm
Model	FX-2000
EquipmentId	N/A
Capacity/Size	16 zones
Installation Year	2007
Source of Installation Year	Documented
Deficiency	PANEL ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PANEL DIRECTION/DIAGRAM IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
FIRE ALARM SYSTEM	
SUB-PANEL	
Fire Alarm Control Panel (Electronic)	
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Boiler Room
Instance Condition	5- Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Faraday
Model	N/A
EquipmentId	Elevator Recall Control Panel
Capacity/Size	4 zones
Installation Year	1973
Source of Installation Year	Documented
Deficiency	PANEL NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Fire Alarm Control Panel (Standard)	
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Standard Electric
EquipmentId	Smoke Detection System - Fan Shutdown Control
Capacity/Size	28 Circuits
Installation Year	1973
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Standard Electric
EquipmentId	Punch Register
Capacity/Size	3 Circuits
Installation Year	1973
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
FIRE ALARM SYSTEM	
SUB-PANEL	
Fire Alarm Control Panel (Standard)	
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Standard Electric
EquipmentId	Sprinkler Alarm and Supervisory Control
Capacity/Size	8 Circuits
Installation Year	1973
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TAMPER FLOW SWITCH/CHAIN	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	
Instance	Inspected
Instance	Gym B,D,E,C,G,H,I
Instance	Gym A,F
LIGHTING	
Instance on Gym B,D,E,C,G,H,I	Inspected
Instance on Gym A,F	Inspected
Lighting Fixture - Fluorescent	
Instance on Gym B,D,E,C,G,H,I	Does not exist
Instance on Gym A,F	Does not exist
Lighting Fixture - HID	
Instance on Gym B,D,E,C,G,H,I	Inspected
Instance on Gym A,F	Inspected
Pendant Mounted	
Instance on Gym B,D,E,C,G,H,I	Does not exist
Instance on Gym A,F	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Gym B,D,E,C,G,H,I	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	72
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Gym A,F	Does not exist
Surface Mounted	
Instance on Gym B,D,E,C,G,H,I	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
GYMNASIUM	
LIGHTING	
Lighting Fixture - HID	
Surface Mounted	
Instance on Gym A,F	Does not exist
Lighting Fixture - Incandescent	
Instance on Gym B,D,E,C,G,H,I	Does not exist
Instance on Gym A,F	Does not exist
LOCAL SOUND SYSTEM	
Instance on Gym B,D,E,C,G,H,I	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Gym A,F	Inspected
Instance Condition	3- Fair
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SCOREBOARD	
Instance on Gym B,D,E,C,G,H,I	Does not exist
Instance on Gym A,F	Does not exist
THEATER LIGHTING SYSTEM	
Instance on Gym B,D,E,C,G,H,I	Does not exist
Instance on Gym A,F	Does not exist
INTERCOM SYSTEM	
	Inspected
ELEVATOR	
Condition	1- Good
Deficiency	No deficiencies recorded
HOLDING AREA	
Condition	3- Fair
Deficiency	No deficiencies recorded
KITCHEN/WARMING PANTRY	
	Inspected
Instance	1st Floor
Instance	2nd Floor
LIGHTING	
Instance on 1st Floor	Inspected
Instance on 2nd Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Instance on 2nd Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Instance on 2nd Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
KITCHEN/WARMING PANTRY	
LIGHTING	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	30
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	26
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 1st Floor	Does not exist
Instance on 2nd Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Instance on 2nd Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Instance on 2nd Floor	Does not exist
LAN	Inspected
LOCAL DISTRIBUTION FRAME (I/LDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MAIN EQUIPMENT RACK (MDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	1st Floor
Has LAN/Modem access	Yes
LIGHTING	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
LIBRARY	
LIGHTING	
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SMART BOARD	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
LIGHTING - SECURITY LIGHTS	Inaccessible
LIGHTNING PROTECTION	Does not exist
LOCKER ROOM	
Instance on 1st Floor - Boys	Inspected
Alternative Use	No
Instance on 2nd Floor - Girls	Inspected
Alternative Use	No
Instance on 1st Floor - Pool	Inspected
Alternative Use	No
LIGHTING	
Instance on 1st Floor - Boys	Inspected
Instance on 2nd Floor - Girls	Inspected
Instance on 1st Floor - Pool	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor - Boys	Inspected
Instance on 2nd Floor - Girls	Inspected
Instance on 1st Floor - Pool	Inspected
Pendant Mounted	
Instance on 1st Floor - Boys	Does not exist
Instance on 2nd Floor - Girls	Does not exist
Instance on 1st Floor - Pool	Does not exist
Recessed Mounted	
Instance on 1st Floor - Boys	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd Floor - Girls	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
LOCKER ROOM	
LIGHTING	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 1st Floor - Pool	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st Floor - Boys	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd Floor - Girls	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 1st Floor - Pool	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor - Boys	Does not exist
Instance on 2nd Floor - Girls	Does not exist
Instance on 1st Floor - Pool	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor - Boys	Does not exist
Instance on 2nd Floor - Girls	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
LOCKER ROOM	
LIGHTING	
Lighting Fixture - Incandescent	
Instance on 1st Floor - Pool	Does not exist
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER NOT OPERATIONAL
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
FUSED DISCONNECT SWITCH TYPE	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
FUSED KNIFE SWITCH TYPE	Does not exist
FUSED TOGGLE SWITCH TYPE	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	Inspected
Instance	General Office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Dukane
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	1st, 2nd, & 3rd Floor Corridor
Deficiency Quantity	17
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	CLOCK POORLY MOUNTED
Deficiency Location/Instance	@ Gym C
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SCIENCE DEMO ROOM	
Instance on Room D218	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room D222	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE DEMO ROOM	
Alternative Use	No
Instance on Room D224	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room D228	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room D230	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room D322	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	Yes
Instance on Room D324	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room D325	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room D327	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room D328	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room D330	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room E297	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	Yes
Instance on Room E299	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room D218	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D222	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE DEMO ROOM	
EMERGENCY GAS SHUT-OFF VALVE	
Deficiency	No deficiencies recorded
Instance on Room D224	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room D228	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D230	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D322	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room D324	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D325	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D327	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room D328	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room D330	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E297	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE DEMO ROOM	
EMERGENCY GAS SHUT-OFF VALVE	
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room E299	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room D218	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D222	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D224	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room D228	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D230	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D322	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room D324	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D325	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D327	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE DEMO ROOM	
EMERGENCY SHUT-OFF POWER	
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room D328	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room D330	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E297	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room E299	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
LIGHTING	
Instance on Room D218	Inspected
Instance on Room D222	Inspected
Instance on Room D224	Inspected
Instance on Room D228	Inspected
Instance on Room D230	Inspected
Instance on Room D322	Inspected
Instance on Room D324	Inspected
Instance on Room D325	Inspected
Instance on Room D327	Inspected
Instance on Room D328	Inspected
Instance on Room D330	Inspected
Instance on Room E297	Inspected
Instance on Room E299	Inspected
Lighting Fixture - Fluorescent	
Instance on Room D218	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE DEMO ROOM	
LIGHTING	
Lighting Fixture - Fluorescent	
Instance on Room D222	Inspected
Instance on Room D224	Inspected
Instance on Room D228	Inspected
Instance on Room D230	Inspected
Instance on Room D322	Inspected
Instance on Room D324	Inspected
Instance on Room D325	Inspected
Instance on Room D327	Inspected
Instance on Room D328	Inspected
Instance on Room D330	Inspected
Instance on Room E297	Inspected
Instance on Room E299	Inspected
Pendant Mounted	
Instance on Room D218	Does not exist
Instance on Room D222	Does not exist
Instance on Room D224	Does not exist
Instance on Room D228	Does not exist
Instance on Room D230	Does not exist
Instance on Room D322	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D324	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D325	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D327	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D328	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D330	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E297	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E299	Does not exist
Recessed Mounted	
Instance on Room D218	Does not exist
Instance on Room D222	Does not exist
Instance on Room D224	Does not exist
Instance on Room D228	Does not exist
Instance on Room D230	Does not exist
Instance on Room D322	Does not exist
Instance on Room D324	Does not exist
Instance on Room D325	Does not exist
Instance on Room D327	Does not exist
Instance on Room D328	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE DEMO ROOM	
LIGHTING	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Instance on Room D330	Does not exist
Instance on Room E297	Does not exist
Instance on Room E299	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room D218	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D222	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D224	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D228	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D230	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D322	Does not exist
Instance on Room D324	Does not exist
Instance on Room D325	Does not exist
Instance on Room D327	Does not exist
Instance on Room D328	Does not exist
Instance on Room D330	Does not exist
Instance on Room E297	Does not exist
Instance on Room E299	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room D218	Does not exist
Instance on Room D222	Does not exist
Instance on Room D224	Does not exist
Instance on Room D228	Does not exist
Instance on Room D230	Does not exist
Instance on Room D322	Does not exist
Instance on Room D324	Does not exist
Instance on Room D325	Does not exist
Instance on Room D327	Does not exist
Instance on Room D328	Does not exist
Instance on Room D330	Does not exist
Instance on Room E297	Does not exist
Instance on Room E299	Does not exist
Lighting Fixture - Incandescent	
Instance on Room D218	Inspected
Instance on Room D222	Inspected
Instance on Room D224	Inspected
Instance on Room D228	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE DEMO ROOM	
LIGHTING	
Lighting Fixture - Incandescent	
Instance on Room D230	Inspected
Instance on Room D322	Inspected
Instance on Room D324	Inspected
Instance on Room D325	Inspected
Instance on Room D327	Inspected
Instance on Room D328	Inspected
Instance on Room D330	Inspected
Instance on Room E297	Does not exist
Instance on Room E299	Inspected
Pendant Mounted	
Instance on Room D218	Does not exist
Instance on Room D222	Does not exist
Instance on Room D224	Does not exist
Instance on Room D228	Does not exist
Instance on Room D230	Does not exist
Instance on Room D322	Does not exist
Instance on Room D324	Does not exist
Instance on Room D325	Does not exist
Instance on Room D327	Does not exist
Instance on Room D328	Does not exist
Instance on Room D330	Does not exist
Instance on Room E299	Does not exist
Recessed Mounted	
Instance on Room D218	Does not exist
Instance on Room D222	Does not exist
Instance on Room D224	Does not exist
Instance on Room D228	Does not exist
Instance on Room D230	Does not exist
Instance on Room D322	Does not exist
Instance on Room D324	Does not exist
Instance on Room D325	Does not exist
Instance on Room D327	Does not exist
Instance on Room D328	Does not exist
Instance on Room D330	Does not exist
Instance on Room E299	Does not exist
Surface Mounted	
Instance on Room D218	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE DEMO ROOM	
LIGHTING	
Lighting Fixture - Incandescent	
Surface Mounted	
Violations	No violations recorded
Instance on Room D222	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room D224	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room D228	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room D230	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE DEMO ROOM	
LIGHTING	
Lighting Fixture - Incandescent	
Surface Mounted	
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room D322	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room D324	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room D325	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE DEMO ROOM	
LIGHTING	
Lighting Fixture - Incandescent	
Surface Mounted	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room D327	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room D328	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room D330	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE DEMO ROOM	
LIGHTING	
Lighting Fixture - Incandescent	
Surface Mounted	
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room E299	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
POWER SUPPLY	
Instance on Room D218	Inspected
Instance on Room D222	Inspected
Instance on Room D224	Inspected
Instance on Room D228	Inspected
Instance on Room D230	Inspected
Instance on Room D322	Inspected
Instance on Room D324	Inspected
Instance on Room D325	Inspected
Instance on Room D327	Inspected
Instance on Room D328	Inspected
Instance on Room D330	Inspected
Instance on Room E297	Inspected
Instance on Room E299	Inspected
Instructor Unit	
Instance on Room D218	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D222	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D224	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE DEMO ROOM	
POWER SUPPLY	
Instructor Unit	
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room D228	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D230	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D322	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room D324	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D325	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D327	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room D328	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room D330	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E297	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE DEMO ROOM	
POWER SUPPLY	
Instructor Unit	
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room E299	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Meter Demonstration Unit	
Instance on Room D218	Does not exist
Instance on Room D222	Does not exist
Instance on Room D224	Does not exist
Instance on Room D228	Does not exist
Instance on Room D230	Does not exist
Instance on Room D322	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D324	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room D325	Does not exist
Instance on Room D327	Does not exist
Instance on Room D328	Does not exist
Instance on Room D330	Does not exist
Instance on Room E297	Does not exist
Instance on Room E299	Does not exist
PROJECTION SYSTEM	
Instance on Room D218	Does not exist
Instance on Room D222	Does not exist
Instance on Room D224	Does not exist
Instance on Room D228	Does not exist
Instance on Room D230	Does not exist
Instance on Room D322	Does not exist
Instance on Room D324	Does not exist
Instance on Room D325	Does not exist
Instance on Room D327	Does not exist
Instance on Room D328	Does not exist
Instance on Room D330	Does not exist
Instance on Room E297	Does not exist
Instance on Room E299	Does not exist
SMART BOARD	
Instance on Room D218	Does not exist
Instance on Room D222	Does not exist
Instance on Room D224	Does not exist
Instance on Room D228	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE DEMO ROOM	
SMART BOARD	
Instance on Room D230	Does not exist
Instance on Room D322	Does not exist
Instance on Room D324	Does not exist
Instance on Room D325	Does not exist
Instance on Room D327	Does not exist
Instance on Room D328	Does not exist
Instance on Room D330	Does not exist
Instance on Room E297	Does not exist
Instance on Room E299	Does not exist
SCIENCE LAB	
Instance on Room D318	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room E106	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room E112	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room E204	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room E212	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	Yes
Instance on Room E304	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room E316	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room D318	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E106	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE LAB	
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room E112	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E204	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E212	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room E304	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E316	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room D318	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E106	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room E112	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E204	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E212	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room E304	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E316	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE LAB	
EMERGENCY SHUT-OFF POWER	
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Room D318	Inspected
Instance on Room E106	Inspected
Instance on Room E112	Inspected
Instance on Room E204	Inspected
Instance on Room E212	Inspected
Instance on Room E304	Inspected
Instance on Room E316	Inspected
Lighting Fixture - Fluorescent	
Instance on Room D318	Inspected
Instance on Room E106	Inspected
Instance on Room E112	Inspected
Instance on Room E204	Inspected
Instance on Room E212	Inspected
Instance on Room E304	Inspected
Instance on Room E316	Inspected
Pendant Mounted	
Instance on Room D318	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E106	Does not exist
Instance on Room E112	Does not exist
Instance on Room E204	Does not exist
Instance on Room E212	Does not exist
Instance on Room E304	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E316	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room D318	Does not exist
Instance on Room E106	Does not exist
Instance on Room E112	Does not exist
Instance on Room E204	Does not exist
Instance on Room E212	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E304	Does not exist
Instance on Room E316	Does not exist
Surface Mounted	
Instance on Room D318	Does not exist
Instance on Room E106	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E112	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E204	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE LAB	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Deficiency	No deficiencies recorded
Instance on Room E212	Does not exist
Instance on Room E304	Does not exist
Instance on Room E316	Does not exist
Lighting Fixture - HID	
Instance on Room D318	Does not exist
Instance on Room E106	Does not exist
Instance on Room E112	Does not exist
Instance on Room E204	Does not exist
Instance on Room E212	Does not exist
Instance on Room E304	Does not exist
Instance on Room E316	Does not exist
Lighting Fixture - Incandescent	
Instance on Room D318	Inspected
Instance on Room E106	Does not exist
Instance on Room E112	Inspected
Instance on Room E204	Does not exist
Instance on Room E212	Inspected
Instance on Room E304	Does not exist
Instance on Room E316	Inspected
Pendant Mounted	
Instance on Room D318	Does not exist
Instance on Room E112	Does not exist
Instance on Room E212	Does not exist
Instance on Room E316	Does not exist
Recessed Mounted	
Instance on Room D318	Does not exist
Instance on Room E112	Does not exist
Instance on Room E212	Does not exist
Instance on Room E316	Does not exist
Surface Mounted	
Instance on Room D318	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room E112	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE LAB	
LIGHTING	
Lighting Fixture - Incandescent	
Surface Mounted	
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room E212	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room E316	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
POWER SUPPLY	
Instance on Room D318	Inspected
Instance on Room E106	Inspected
Instance on Room E112	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE LAB	
POWER SUPPLY	
Instance on Room E204	Inspected
Instance on Room E212	Inspected
Instance on Room E304	Inspected
Instance on Room E316	Inspected
Instructor Unit	
Instance on Room D318	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E106	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room E112	Does not exist
Instance on Room E204	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E212	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room E304	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E316	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room D318	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E106	Does not exist
Instance on Room E112	Does not exist
Instance on Room E204	Does not exist
Instance on Room E212	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room E304	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE LAB	
POWER SUPPLY	
Meter Demonstration Unit	
Instance on Room E316	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Student Unit	
Instance on Room D318	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E106	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room E112	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E204	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E212	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	13
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room E304	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E316	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
PROJECTION SYSTEM	
Instance on Room D318	Does not exist
Instance on Room E106	Does not exist
Instance on Room E112	Does not exist
Instance on Room E204	Does not exist
Instance on Room E212	Does not exist
Instance on Room E304	Does not exist
Instance on Room E316	Does not exist
SMART BOARD	
Instance on Room D318	Does not exist
Instance on Room E106	Does not exist
Instance on Room E112	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room E204	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE LAB	
SMART BOARD	
Instance on Room E212	Does not exist
Instance on Room E304	Does not exist
Instance on Room E316	Does not exist
SCIENCE PREP ROOM	
Instance on Room E108	Inspected
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	Yes
Instance on Room E208	Inspected
Has LAN/Modem access	No
Power Panel?	Yes
Alternative Use	No
Instance on Room E306	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room E310	Inspected
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room E108	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room E208	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E306	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E310	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room E108	Does not exist
Instance on Room E208	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E306	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E310	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Room E108	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE PREP ROOM	
LIGHTING	
Instance on Room E208	Inspected
Instance on Room E306	Inspected
Instance on Room E310	Inspected
Lighting Fixture - Fluorescent	
Instance on Room E108	Inspected
Instance on Room E208	Inspected
Instance on Room E306	Inspected
Instance on Room E310	Inspected
Pendant Mounted	
Instance on Room E108	Does not exist
Instance on Room E208	Does not exist
Instance on Room E306	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E310	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room E108	Does not exist
Instance on Room E208	Does not exist
Instance on Room E306	Does not exist
Instance on Room E310	Does not exist
Surface Mounted	
Instance on Room E108	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E208	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E306	Does not exist
Instance on Room E310	Does not exist
Lighting Fixture - HID	
Instance on Room E108	Does not exist
Instance on Room E208	Does not exist
Instance on Room E306	Does not exist
Instance on Room E310	Does not exist
Lighting Fixture - Incandescent	
Instance on Room E108	Does not exist
Instance on Room E208	Does not exist
Instance on Room E306	Does not exist
Instance on Room E310	Does not exist
POWER SUPPLY	
Instance on Room E108	Inspected
Instance on Room E208	Inspected
Instance on Room E306	Inspected
Instance on Room E310	Inspected
Instructor Unit	
Instance on Room E108	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SCIENCE PREP ROOM	
POWER SUPPLY	
Instructor Unit	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room E208	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E306	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room E310	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SECURITY	
	Inspected
INTRUSION ALARM	
	Inspected
Central Control Panel	
Instance	Custodians Office
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista 128B
Deficiency	No deficiencies recorded
Infrared Sensor	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	
	Does not exist
IPDVS/CCTV SYSTEM	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SERVICE SWITCH	
	Inspected
Instance	Electrical Room @ 1st Floor Cafeteria
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lexington Standard Co.
EquipmentId	Main Service (no. 1)
Capacity/Size	4000 Amps
Source of Capacity/Size	Custodian
Installation Year	1973
Source of Installation Year	Documented
Deficiency	SWITCH NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SERVICE SWITCH	
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room @ 1st Floor Cafeteria
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lexington Standard Co.
EquipmentId	N/A (no. 2)
Capacity/Size	4000 Amps
Source of Capacity/Size	Custodian
Installation Year	1973
Source of Installation Year	Documented
Deficiency	SWITCH NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCH ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
SWIMMING POOL	
Instance	Inspected
Instance	1st Floor
LIGHTING	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 1st Floor	Does not exist
SCOREBOARD	
Instance on 1st Floor	Does not exist
SWITCHBOARD	
Water Penetration In Electrical Room?	Inspected
Number of Spares	No
Number of Spares	2
AIR CIRCUIT BREAKER TYPE	
	Does not exist
FUSED DISCONNECT SWITCH TYPE	
Instance	Inspected
Instance	Electrical Room @ 1st Floor Cafeteria

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q410

Question	Response
SWITCHBOARD	
FUSED DISCONNECT SWITCH TYPE	
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lexington Standard Co.
EquipmentId	N/A
Capacity/Size	4000 Amps Total, 4 Sections
Source of Capacity/Size	Service Switch Size
Installation Year	1973
Source of Installation Year	Documented
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room @ 1st Floor Cafeteria
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lexington Standard Co.
EquipmentId	N/A
Capacity/Size	4000 Amps total, 3 sections
Source of Capacity/Size	Service Switch Size
Installation Year	1973
Source of Installation Year	Documented
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED KNIFE SWITCH TYPE	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	Does not exist
TELEPHONE	Inspected
PBX/INTERCOM	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
STANDARD	Inspected
Condition	1- Good

NYC Department of Education
Building Condition Assessment Survey 2010-2011

Electrical Inspection

Q410

Question	Response
TELEPHONE	
STANDARD	
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TOILET ROOM - STUDENT	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable System Exist?	Yes
Operational?	Yes
Master Antenna System Exist?	Yes
Operational?	No
MAIN EQUIPMENT RACK	Does not exist