

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

School: **NEWCOMERS HIGH SCHOOL (OLD LIC)-Q, 28-01 41ST AVENUE, QUEENS, NY, 11101**

InspectionId	Inspection Type	Time In	Last Edited
1610029	ELECTRICAL	2010-11-02 08:13AM	2011-05-09 05:50AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Smart boards Years: 2009 Systems: Pendant Fluorescent Lighting in Cafeteria(East) Years: 2007 Systems: LAN -Main and Local Distribution Frames Years: 2006-2007 Systems: Telephone System Years: 2006-2007 Systems: Auditorium -Local Sound System, Theater Lighting, Dimming System, Projection System Years: 2005 Systems: Emergency and Exit Lighting System (Partial) Years: 2001-2002 Systems: Security Lighting Years: 2000-2001 Systems: Panel Board - Fused Disconnect Switch Type Years: 2002 Systems: Panel board- Molded Case Circuit Breaker Type (partial) Years: 1992, 2003 Systems: Science Rooms Years: 1998-1999 Systems: Intrusion Alarm Years: 1995-1996 Systems: Recessed Fluorescent Years: 1996, 1998 Systems: Switchboard-Fused Disconnect Switch Type Years: 2002 Systems: Electric Service Switch (Partial) Years: 2002
Type of Service	Below Ground

Priority Condition

Condition Description	Component Affected	Location Description	Person(s) Notified
Local Sound System not Connected to PA System	Public Address System	Auditorium	Joseph Nevis (Custodian), Roland Rompey (Handyman), Horace John (Firemen)

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	1st Floor
HOUSE LIGHTING	
Instance on 1st Floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
AUDITORIUM	
HOUSE LIGHTING	
Lighting Fixture - Incandescent	
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	59
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
LOCAL SOUND SYSTEM	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	NOT CONNECTED TO PA SYSTEM
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL CONNECTION
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
PROJECTION SYSTEM	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	No deficiencies recorded
THEATER LIGHTING SYSTEM	
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA	
Instance	Inspected
Instance	Basement- East Cafeteria
Instance	Basement- West Cafeteria

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
CAFETERIA	
LIGHTING	
Instance on Basement- East Cafeteria	Inspected
Instance on Basement- West Cafeteria	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement- East Cafeteria	Inspected
Instance on Basement- West Cafeteria	Inspected
Pendant Mounted	
Instance on Basement- East Cafeteria	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Basement- West Cafeteria	Does not exist
Recessed Mounted	
Instance on Basement- East Cafeteria	Does not exist
Instance on Basement- West Cafeteria	Does not exist
Surface Mounted	
Instance on Basement- East Cafeteria	Does not exist
Instance on Basement- West Cafeteria	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Basement- East Cafeteria	Does not exist
Instance on Basement- West Cafeteria	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement- East Cafeteria	Does not exist
Instance on Basement- West Cafeteria	Does not exist
LOCAL SOUND SYSTEM	
Instance on Basement- East Cafeteria	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Basement- West Cafeteria	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
CITY FIRE ALARM SYSTEM	
Condition	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
LIGHTING	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	850
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	140
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Lighting Fixture - Incandescent	
Surface Mounted	
Deficiency Quantity	25
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SMART BOARD	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
COMPUTER LAB	Inspected
Instance	Room 410
Has LAN/Modem access	Yes
Power Panel?	No
Instance	Room 318B
Has LAN/Modem access	Yes
Power Panel?	No
Instance	Room 210
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room 206
Has LAN/Modem access	Yes
Power Panel?	Yes
LIGHTING	
Instance on Room 410	Inspected
Instance on Room 318B	Inspected
Instance on Room 210	Inspected
Instance on Room 206	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 410	Inspected
Instance on Room 318B	Inspected
Instance on Room 210	Inspected
Instance on Room 206	Inspected
Pendant Mounted	
Instance on Room 410	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 318B	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	21
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
COMPUTER LAB	
LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 210	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 206	Does not exist
Recessed Mounted	
Instance on Room 410	Does not exist
Instance on Room 318B	Does not exist
Instance on Room 210	Does not exist
Instance on Room 206	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 410	Does not exist
Instance on Room 318B	Does not exist
Instance on Room 210	Does not exist
Instance on Room 206	Does not exist
Lighting Fixture - HID	
Instance on Room 410	Does not exist
Instance on Room 318B	Does not exist
Instance on Room 210	Does not exist
Instance on Room 206	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 410	Does not exist
Instance on Room 318B	Does not exist
Instance on Room 210	Does not exist
Instance on Room 206	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 410	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 318B	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 210	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
COMPUTER LAB	
RACEWAY WITH RECEPTACLES	
Deficiency	No deficiencies recorded
Instance on Room 206	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
BATTERY PACK	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
BATTERY PACK	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
AREA SMOKE DETECTOR	Does not exist
BELL/HORN	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
DUCT SMOKE DETECTOR	Does not exist
ELEVATOR RECALL	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
FAN SHUTDOWN CONTROL	Does not exist
FIRE ALARM DIGITAL COMMUNICATOR	Does not exist
FUSED CUTOFF PANEL	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
HEAT DETECTOR	Does not exist
MAGNETIC DOOR HOLDER CONTACTOR	Does not exist
MAIN PANEL	Inspected
Bell At Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Does not exist
Fire Alarm Control Panel (Standard)	Inspected
Instance	Sub-Basement
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
EquipmentId	Fire Alarm Control Panel

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
FIRE ALARM SYSTEM	
MAIN PANEL	
Fire Alarm Control Panel (Standard)	
Capacity/Size	10 circuits
Installation Year	1954
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	136,000
Quantity Uom	S.F.
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MANUAL PULL STATION	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
REMOTE ANNUNCIATOR	Inspected
Display Monitor	Does not exist
Panel	Does not exist
Printer	Does not exist
Punch Register	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
SPRINKLER FLOW/AIR PRESSURE SWITCH	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
STROBE	Does not exist
SUB-PANEL	Inspected
Bell At Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Sub- Basement
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Fire Control Instruments
Model	7200
EquipmentId	Elevator Smoke Detection Control Panel
Capacity/Size	12 zones
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Inspected
Instance	Sub-basement
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Sprinkler Alarm
Capacity/Size	2 Circuits
Installation Year	1954
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
FIRE ALARM SYSTEM	
SUB-PANEL	
Fire Alarm Control Panel (Standard)	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Sub- Basement
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards Systems Technology
EquipmentId	N/A
Capacity/Size	3 circuits
Installation Year	1954
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PANEL ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
TAMPER FLOW SWITCH/CHAIN	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	
Instance	Inspected
Instance	4th Floor- (Girls)
Instance	2nd Floor -Boys
LIGHTING	
Instance on 4th Floor- (Girls)	Inspected
Instance on 2nd Floor -Boys	Inspected
Lighting Fixture - Fluorescent	
Instance on 4th Floor- (Girls)	Does not exist
Instance on 2nd Floor -Boys	Inspected
Pendant Mounted	
Instance on 2nd Floor -Boys	Does not exist
Recessed Mounted	
Instance on 2nd Floor -Boys	Does not exist
Surface Mounted	
Instance on 2nd Floor -Boys	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	16
Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
GYMNASIUM	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on 4th Floor- (Girls)	Inspected
Instance on 2nd Floor -Boys	Inspected
Pendant Mounted	
Instance on 4th Floor- (Girls)	Does not exist
Instance on 2nd Floor -Boys	Does not exist
Recessed Mounted	
Instance on 4th Floor- (Girls)	Does not exist
Instance on 2nd Floor -Boys	Does not exist
Surface Mounted	
Instance on 4th Floor- (Girls)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	28
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd Floor -Boys	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	35
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - Incandescent	
Instance on 4th Floor- (Girls)	Does not exist
Instance on 2nd Floor -Boys	Inspected
Pendant Mounted	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
GYMNASIUM	
LIGHTING	
Lighting Fixture - Incandescent	
Pendant Mounted	
Instance on 2nd Floor -Boys	Does not exist
Recessed Mounted	
Instance on 2nd Floor -Boys	Does not exist
Surface Mounted	
Instance on 2nd Floor -Boys	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
LOCAL SOUND SYSTEM	
Instance on 4th Floor- (Girls)	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd Floor -Boys	Inspected
Instance Condition	5- Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SCOREBOARD	
Instance on 4th Floor- (Girls)	Does not exist
Instance on 2nd Floor -Boys	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
THEATER LIGHTING SYSTEM	
Instance on 4th Floor- (Girls)	Does not exist
Instance on 2nd Floor -Boys	Does not exist
INTERCOM SYSTEM	
	Inspected
ELEVATOR	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
HOLDING AREA	
	Does not exist
KITCHEN/WARMING PANTRY	
Instance	Inspected
	Basement
LIGHTING	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
KITCHEN/WARMING PANTRY	
LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	25
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
LAN	Inspected
LOCAL DISTRIBUTION FRAME (I/LDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MAIN EQUIPMENT RACK (MDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	Room 213
Has LAN/Modem access	Yes
LIGHTING	
Instance on Room 213	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 213	Inspected
Pendant Mounted	
Instance on Room 213	Does not exist
Recessed Mounted	
Instance on Room 213	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	70
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
LIBRARY	
LIGHTING	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on Room 213	Does not exist
Lighting Fixture - HID	
Instance on Room 213	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 213	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 213	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SMART BOARD	
Instance on Room 213	Does not exist
LIGHTING - SECURITY LIGHTS	
Condition	Inspected
Replacement Quantity	3- Fair
Replacement Uom	27
Replacement Uom	EACH
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Roof and Wall
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
LIGHTNING PROTECTION	
Does not exist	
LOCKER ROOM	
Instance on 4th Floor -Room 416 (Boys)	Inspected
Alternative Use	No
Instance on 2nd Floor- Boys	Inspected
Alternative Use	No
Instance on 5th Floor - Room 502 (Girls)	Inspected
Alternative Use	No
LIGHTING	
Instance on 4th Floor -Room 416 (Boys)	Inspected
Instance on 2nd Floor- Boys	Inspected
Instance on 5th Floor - Room 502 (Girls)	Inspected
Lighting Fixture - Fluorescent	
Instance on 4th Floor -Room 416 (Boys)	Inspected
Instance on 2nd Floor- Boys	Inspected
Instance on 5th Floor - Room 502 (Girls)	Does not exist
Pendant Mounted	
Instance on 4th Floor -Room 416 (Boys)	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
LOCKER ROOM	
LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Instance on 2nd Floor- Boys	Does not exist
Recessed Mounted	
Instance on 4th Floor -Room 416 (Boys)	Does not exist
Instance on 2nd Floor- Boys	Does not exist
Surface Mounted	
Instance on 4th Floor -Room 416 (Boys)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 2nd Floor- Boys	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on 4th Floor -Room 416 (Boys)	Does not exist
Instance on 2nd Floor- Boys	Does not exist
Instance on 5th Floor - Room 502 (Girls)	Does not exist
Lighting Fixture - Incandescent	
Instance on 4th Floor -Room 416 (Boys)	Inspected
Instance on 2nd Floor- Boys	Does not exist
Instance on 5th Floor - Room 502 (Girls)	Inspected
Pendant Mounted	
Instance on 4th Floor -Room 416 (Boys)	Does not exist
Instance on 5th Floor - Room 502 (Girls)	Does not exist
Recessed Mounted	
Instance on 4th Floor -Room 416 (Boys)	Does not exist
Instance on 5th Floor - Room 502 (Girls)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	19
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
LOCKER ROOM	
LIGHTING	
Lighting Fixture - Incandescent	
Recessed Mounted	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 4th Floor -Room 416 (Boys)	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 5th Floor - Room 502 (Girls)	Does not exist
MOTOR CONTROL CENTER	
Instance	Inspected
Instance	Room 013
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Westinghouse
EquipmentId	Control Center
Capacity/Size	N/A, 2 Sections
Installation Year	1956
Source of Installation Year	Documented
Deficiency	MCC BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	MCC ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	MCC NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Boiler Room, Basement Fan Room, Mechanical Spaces
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
FUSED DISCONNECT SWITCH TYPE	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
FUSED KNIFE SWITCH TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Basement - Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED TOGGLE SWITCH TYPE	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Corridors of 1st Floor, 2nd Floor, 3rd floor, 4th Floor, Kitchen and Cafeteria
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	Inspected
Instance	Room113A
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Dukane
Deficiency	SYSTEM BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Room 113A
Deficiency Quantity	136,000
Quantity Uom	S.F.
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
SCIENCE DEMO ROOM	
Instance on Room 314	Inspected
Has LAN/Modem access	Yes
Power Panel?	No

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
SCIENCE DEMO ROOM	
Alternative Use	No
Instance on Room 313	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 312	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 309	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 307	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 301	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 314	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 313	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 312	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 309	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 307	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 301	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room 314	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 313	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 312	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 309	Inspected
Instance Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
SCIENCE DEMO ROOM	
EMERGENCY SHUT-OFF POWER	
Deficiency	No deficiencies recorded
Instance on Room 307	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 301	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Room 314	Inspected
Instance on Room 313	Inspected
Instance on Room 312	Inspected
Instance on Room 309	Inspected
Instance on Room 307	Inspected
Instance on Room 301	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 314	Inspected
Instance on Room 313	Inspected
Instance on Room 312	Inspected
Instance on Room 309	Inspected
Instance on Room 307	Inspected
Instance on Room 301	Inspected
Pendant Mounted	
Instance on Room 314	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 313	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 312	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 309	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 307	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 301	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 314	Does not exist
Instance on Room 313	Does not exist
Instance on Room 312	Does not exist
Instance on Room 309	Does not exist
Instance on Room 307	Does not exist
Instance on Room 301	Does not exist
Surface Mounted	
Instance on Room 314	Does not exist
Instance on Room 313	Does not exist
Instance on Room 312	Does not exist
Instance on Room 309	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
SCIENCE DEMO ROOM	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Instance on Room 307	Does not exist
Instance on Room 301	Does not exist
Lighting Fixture - HID	
Instance on Room 314	Does not exist
Instance on Room 313	Does not exist
Instance on Room 312	Does not exist
Instance on Room 309	Does not exist
Instance on Room 307	Does not exist
Instance on Room 301	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 314	Does not exist
Instance on Room 313	Does not exist
Instance on Room 312	Does not exist
Instance on Room 309	Does not exist
Instance on Room 307	Does not exist
Instance on Room 301	Does not exist
POWER SUPPLY	
Instance on Room 314	Inspected
Instance on Room 313	Inspected
Instance on Room 312	Inspected
Instance on Room 309	Inspected
Instance on Room 307	Inspected
Instance on Room 301	Inspected
Instructor Unit	
Instance on Room 314	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 313	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 312	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 309	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 307	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 301	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 314	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 313	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 312	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
SCIENCE DEMO ROOM	
POWER SUPPLY	
Meter Demonstration Unit	
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 309	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 307	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 301	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
PROJECTION SYSTEM	
Instance on Room 314	Does not exist
Instance on Room 313	Does not exist
Instance on Room 312	Does not exist
Instance on Room 309	Does not exist
Instance on Room 307	Does not exist
Instance on Room 301	Does not exist
SMART BOARD	
Instance on Room 314	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 313	Does not exist
Instance on Room 312	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 309	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 307	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 301	Does not exist
SCIENCE LAB	
Instance on Room 308	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 302	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 308	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 302	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room 308	Inspected

NYC Department of Education
 Building Condition Assessment Survey 2010-2011

Electrical Inspection

Q450

Question	Response
SCIENCE LAB	
EMERGENCY SHUT-OFF POWER	
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 302	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Room 308	Inspected
Instance on Room 302	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 308	Inspected
Instance on Room 302	Inspected
Pendant Mounted	
Instance on Room 308	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 302	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 308	Does not exist
Instance on Room 302	Does not exist
Surface Mounted	
Instance on Room 308	Does not exist
Instance on Room 302	Does not exist
Lighting Fixture - HID	
Instance on Room 308	Does not exist
Instance on Room 302	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 308	Does not exist
Instance on Room 302	Does not exist
POWER SUPPLY	
Instance on Room 308	Inspected
Instance on Room 302	Inspected
Instructor Unit	
Instance on Room 308	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 302	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 308	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 302	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Student Unit	
Instance on Room 308	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 302	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
SCIENCE LAB	
POWER SUPPLY	
Student Unit	
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
PROJECTION SYSTEM	
Instance on Room 308	Does not exist
Instance on Room 302	Does not exist
SMART BOARD	
Instance on Room 308	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 302	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
SCIENCE PREP ROOM	
Instance on Room 310	Inspected
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	Yes
Instance on Room 304	Inspected
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 310	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 304	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room 310	Does not exist
Instance on Room 304	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Room 310	Inspected
Instance on Room 304	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 310	Inspected
Instance on Room 304	Inspected
Pendant Mounted	
Instance on Room 310	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 304	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 310	Does not exist
Instance on Room 304	Does not exist
Surface Mounted	
Instance on Room 310	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
SCIENCE PREP ROOM	
LIGHTING	
Lighting Fixture - Fluorescent	
Surface Mounted	
Instance on Room 304	Does not exist
Lighting Fixture - HID	
Instance on Room 310	Does not exist
Instance on Room 304	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 310	Does not exist
Instance on Room 304	Does not exist
POWER SUPPLY	
Instance on Room 310	Inspected
Instance on Room 304	Inspected
Instructor Unit	
Instance on Room 310	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 304	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SECURITY	Inspected
INTRUSION ALARM	Inspected
Central Control Panel	Inspected
Instance	Room 113A
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Ademco- Vista 128B
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	Does not exist
IPDVS/CCTV SYSTEM	Does not exist
SERVICE SWITCH	Inspected
Instance	Power Light Riser Room/Sub-basement
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Siemens
EquipmentId	Switchboard MDP- Service Disconnect
Capacity/Size	1600 Amps
Source of Capacity/Size	Nameplate
Installation Year	2002

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
SERVICE SWITCH	
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Equipment Room- Sub Basement
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Westinghouse
EquipmentId	N/A
Capacity/Size	N/A
Source of Capacity/Size	None
Installation Year	1954
Source of Installation Year	Documented
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCH ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCH NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Equipment Room -Sub Basement
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Westinghouse
EquipmentId	N/A
Capacity/Size	N/A
Source of Capacity/Size	None
Installation Year	1954
Source of Installation Year	Documented
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCH ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
SERVICE SWITCH	
Violations	No violations recorded
Deficiency	SWITCH NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
SWIMMING POOL	
	Does not exist
SWITCHBOARD	
	Inspected
Water Penetration In Electrical Room?	No
Number of Spares	0
AIR CIRCUIT BREAKER TYPE	
	Does not exist
FUSED DISCONNECT SWITCH TYPE	
	Inspected
Instance	Power Light Riser Room. Sub Basement
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Siemens
EquipmentId	Section A and Section B
Capacity/Size	1600 Amps total, 2 Sections
Source of Capacity/Size	Switchboard Mains Size
Installation Year	2002
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
FUSED KNIFE SWITCH TYPE	
	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	
	Inspected
Instance	Power Light Riser Room- Sub Basement
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Westinghouse
EquipmentId	Service A
Capacity/Size	1600 Amps total, 1 section
Source of Capacity/Size	Switchboard Mains Size
Installation Year	1954
Source of Installation Year	Documented
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Power Light Riser Room-Sub Basement
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Westinghouse
EquipmentId	Service B
Capacity/Size	1600 Amps total, 1 section
Source of Capacity/Size	Switchboard Mains Size
Installation Year	1954
Source of Installation Year	Documented

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
SWITCHBOARD	
MOLDED CASE CIRCUIT BREAKER TYPE	
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TELEPHONE	
	Inspected
PBX/INTERCOM	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
STANDARD	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	
	Inspected
LIGHTING	
	Inspected
Lighting Fixture - Fluorescent	
	Inspected
Pendant Mounted	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
	Does not exist
Surface Mounted	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
	Does not exist
Lighting Fixture - Incandescent	
	Inspected
Pendant Mounted	
	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
	Does not exist
Surface Mounted	
	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TOILET ROOM - STUDENT	
	Inspected
LIGHTING	
	Inspected
Lighting Fixture - Fluorescent	
	Inspected
Pendant Mounted	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q450

Question	Response
TOILET ROOM - STUDENT	
LIGHTING	
Lighting Fixture - Fluorescent	
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable System Exist?	Yes
Operational?	No
Master Antenna System Exist?	No
MAIN EQUIPMENT RACK	Does not exist