

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q465

School: **FAR ROCKAWAY HS - Q, 8-21 BEACH 25 STREET, QUEENS, NY, 11691**

InspectionId	Inspection Type	Time In	Last Edited
1254065	ELECTRICAL	2009-02-18 09:08AM	2009-07-13 03:10PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: PA System and Local Sound System Years: Under Construction Systems: Partial Panel Boards, LAN/Phone, Camera Years: 2001 Systems: Emergency/Exit Lights Years: 1990 and 2000 Systems: Fluorescent Lighting Years: 1997 Systems: Partial lighting in library, computer rooms, science rooms Years: 2008 Systems: Fire Alarm System, Emergency Gas and Power Shutoff Years: 2000 Systems: Emergency/Exit Lights Battery Pack Years: 2007 Systems: Intrusion Alarm Years: 2003

Priority Condition

Condition Description	Component Affected	Location Description	Person(s) Notified
Elevator intercom does not exist	Elevator intercom	Elevator Cab	Fireman: Nando Holiprasad

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	1st Floor
House Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	14
Quantity Uom	EACH
Potential Action	INSTALL NEW LAMP
Urgency of Action	PRIORITY 3

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q465

Question	Response
AUDITORIUM	
House Lighting	
Lighting Fixture - HID	
Recessed Mounted	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Local Sound System	
Instance on 1st Floor	Under construction
Projection System	
Instance on 1st Floor	Does not exist
Theater Lighting System	
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	DIMMING RACK BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Theater Lighting	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	Inspected
Replacement Quantity	3- Fair
Replacement Uom	227,000
Deficiency	S.F.
Deficiency	No deficiencies recorded
CAFETERIA	
Instance	Inspected
Instance	Basement
Lighting	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Does not exist
Recessed Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
Local Sound System	

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q465

Question	Response
CAFETERIA	
Local Sound System	
Instance on Basement	Under construction
CAFETERIA/MULTIPURPOSE ROOM	Does not exist
CITY FIRE ALARM SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	30
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
COMPUTER LAB	Inspected
Instance	Room 230,247,249
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room 342
Has LAN/Modem access	Yes
Power Panel?	Yes
Lighting	
Instance on Room 230,247,249	Inspected
Instance on Room 342	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 230,247,249	Inspected
Instance on Room 342	Inspected
Pendant Mounted	
Instance on Room 230,247,249	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 342	Does not exist
Recessed Mounted	
Instance on Room 230,247,249	Does not exist
Instance on Room 342	Does not exist
Surface Mounted	
Instance on Room 230,247,249	Does not exist
Instance on Room 342	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Lighting Fixture - HID	

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q465

Question	Response
COMPUTER LAB	
Lighting	
Lighting Fixture - HID	
Instance on Room 230,247,249	Does not exist
Instance on Room 342	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 230,247,249	Does not exist
Instance on Room 342	Does not exist
Raceway With Receptacles	
Instance on Room 230,247,249	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 342	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
ELECTRIC SERVICE SWITCH	
Instance	Basement -Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Gallagher Switchboard
Model	Gallagher Switchboard
EquipmentId	N/A
Capacity/Size	N/A
Installation Year	1959
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Basement -Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCH ID IS MISSING
Deficiency Location/Instance	Basement -Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCH NAME PLATE IS MISSING
Deficiency Location/Instance	Basement -Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Boiler room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Gallagher Switchboard
Model	Gallagher Switchboard
EquipmentId	N/A

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q465

Question	Response
ELECTRIC SERVICE SWITCH	
Capacity/Size	N/A
Installation Year	1959
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Basement -Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCH ID IS MISSING
Deficiency Location/Instance	Basement -Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCH NAME PLATE IS MISSING
Deficiency Location/Instance	Basement -Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Connected To Emergency Generator System	Does not exist
Connected To Emergency Light/Exit Light Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Relay Test Switch	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Connected To Emergency Generator System	Does not exist
Connected To Emergency Light/Exit Light Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
FIRE ALARM SYSTEM	Inspected
Replacement Quantity	227,000
Replacement Uom	S.F.
Area Smoke Detector	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q465

Question	Response
FIRE ALARM SYSTEM	
Area Smoke Detector	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Bell/Horn	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Duct Smoke Detector	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Elevator Recall	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	
Instance	Basement-Electrical room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Radionics Inc.
EquipmentId	Fire Alarm Communicator
Capacity/Size	5 zones
Installation Year	2000
Deficiency	No deficiencies recorded
Fused Cutout Panel	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Heat Detector	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Magnetic Door Holder Contactor	
	Does not exist
Main Panel	
	Inspected
Bell At Panel	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	
Instance	Main Entrance
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	EST
Model	EST CM2
EquipmentId	Fire Alarm Control Panel
Capacity/Size	16 zones
Installation Year	2000
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	
	Does not exist
Manual Pull Station	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Remote Annunciator	
	Inspected
Display Monitor	
	Does not exist
Panel	
	Inspected

NYC Department of Education
Building Condition Assessment Survey 2008-2009

Electrical Inspection

Q465

Question	Response
FIRE ALARM SYSTEM	
Remote Annunciator	
Panel	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Printer	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Punch Register	
	Does not exist
Sprinkler Flow/Air Pressure Switch	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Strobe	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Sub-Panel	
	Inspected
Bell At Panel	
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	
	Inspected
Instance	Boiler room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Gamewell
Model	Gamewell
EquipmentId	N/A
Capacity/Size	5 zones
Installation Year	1990
Deficiency	PANEL ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fire Alarm Control Panel (Standard)	
	Inspected
Instance	Boiler room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	Sprinkler Alarm
Capacity/Size	2 circuits
Installation Year	1959
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Tamper Flow Switch/Chain	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q465

Question	Response
GROUNDING SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	Inspected
Instance	First Floor - Gym A
Instance	First Floor - Gym B
Lighting	
Instance on First Floor - Gym A	Inspected
Instance on First Floor - Gym B	Inspected
Lighting Fixture - Fluorescent	
Instance on First Floor - Gym A	Does not exist
Instance on First Floor - Gym B	Does not exist
Lighting Fixture - HID	
Instance on First Floor - Gym A	Inspected
Instance on First Floor - Gym B	Inspected
Pendant Mounted	
Instance on First Floor - Gym B	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on First Floor - Gym A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on First Floor - Gym B	Does not exist
Instance on First Floor - Gym A	Does not exist
Surface Mounted	
Instance on First Floor - Gym B	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on First Floor - Gym A	Does not exist
Lighting Fixture - Incandescent	
Instance on First Floor - Gym A	Does not exist
Instance on First Floor - Gym B	Does not exist
Local Sound System	
Instance on First Floor - Gym A	Under construction
Instance on First Floor - Gym B	Under construction
Scoreboard	

NYC Department of Education
Building Condition Assessment Survey 2008-2009

Electrical Inspection

Q465

Question	Response
GYMNASIUM	
Scoreboard	
Instance on First Floor - Gym A	Does not exist
Instance on First Floor - Gym B	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Theater Lighting System	
Instance on First Floor - Gym A	Does not exist
Instance on First Floor - Gym B	Does not exist
INTERCOM SYSTEM	
KITCHEN/WARMING PANTRY	
Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Surface Mounted	
Lighting Fixture - HID	
Lighting Fixture - Incandescent	
LAN	
Local Distribution Frame (I/LDF)	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIBRARY	
Instance	Room 312
Has LAN/Modem access	Yes
Lighting	
Instance on Room 312	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 312	Inspected
Pendant Mounted	
Instance on Room 312	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 312	Does not exist
Surface Mounted	
Instance on Room 312	Does not exist
Lighting Fixture - HID	
Instance on Room 312	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 312	Does not exist
Raceway With Receptacles	
Instance on Room 312	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIGHTING - EXTERIOR SECURITY	
Condition	3- Fair
Replacement Quantity	36
Replacement Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q465

Question	Response
LIGHTING - EXTERIOR SECURITY	
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	Does not exist
LOCKER ROOM/SHOWER ROOM	Inspected
Instance	Basement-Boys
Alternative Use	No
Instance	2nd Floor-Girl Lockers
Alternative Use	No
Instance	Basement-Girl Showers
Alternative Use	No
Lighting	
Instance on Basement-Boys	Inspected
Instance on 2nd Floor-Girl Lockers	Inspected
Instance on Basement-Girl Showers	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement-Boys	Inspected
Instance on 2nd Floor-Girl Lockers	Inspected
Instance on Basement-Girl Showers	Inspected
Pendant Mounted	
Instance on Basement-Boys	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on 2nd Floor-Girl Lockers	Does not exist
Instance on Basement-Girl Showers	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Basement-Boys	Does not exist
Instance on 2nd Floor-Girl Lockers	Does not exist
Instance on Basement-Girl Showers	Does not exist
Surface Mounted	
Instance on Basement-Boys	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on 2nd Floor-Girl Lockers	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL NEW LAMP
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Basement-Girl Showers	Does not exist
Lighting Fixture - HID	
Instance on Basement-Boys	Does not exist
Instance on 2nd Floor-Girl Lockers	Does not exist
Instance on Basement-Girl Showers	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q465

Question	Response
LOCKER ROOM/SHOWER ROOM	
Lighting	
Lighting Fixture - Incandescent	
Instance on Basement-Boys	Does not exist
Instance on 2nd Floor-Girl Lockers	Does not exist
Instance on Basement-Girl Showers	Does not exist
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Fan's room, Elevator room, Basement, Boiler room
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Fan's room, Corridors
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fused Toggle Switch Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Electrical room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Molded Case Circuit Breaker Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Corridors, Public areas, Basement
Deficiency Quantity	14
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	Under construction
SCIENCE DEMO ROOM	Inspected
Instance	Room 236,239,240,242

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q465

Question	Response
SCIENCE DEMO ROOM	
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	Room 243
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	Room 248,252,254
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	Room 373
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on Room 236,239,240,242	Does not exist
Instance on Room 243	Does not exist
Instance on Room 248,252,254	Does not exist
Instance on Room 373	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 236,239,240,242	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 243	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 248,252,254	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 373	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting	
Instance on Room 236,239,240,242	Inspected
Instance on Room 243	Inspected
Instance on Room 248,252,254	Inspected
Instance on Room 373	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 236,239,240,242	Inspected
Instance on Room 243	Inspected
Instance on Room 248,252,254	Inspected
Instance on Room 373	Inspected
Pendant Mounted	
Instance on Room 236,239,240,242	Does not exist
Instance on Room 243	Does not exist
Instance on Room 248,252,254	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 373	Inspected
Instance Condition	1- Good

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q465

Question	Response
SCIENCE DEMO ROOM	
Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 236,239,240,242	Does not exist
Instance on Room 243	Does not exist
Instance on Room 248,252,254	Does not exist
Instance on Room 373	Does not exist
Surface Mounted	
Instance on Room 236,239,240,242	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 243	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 248,252,254	Does not exist
Instance on Room 373	Does not exist
Lighting Fixture - HID	
Instance on Room 236,239,240,242	Does not exist
Instance on Room 243	Does not exist
Instance on Room 248,252,254	Does not exist
Instance on Room 373	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 236,239,240,242	Does not exist
Instance on Room 243	Does not exist
Instance on Room 248,252,254	Does not exist
Instance on Room 373	Does not exist
Power Supply	
Instance on Room 236,239,240,242	Inspected
Instance on Room 243	Inspected
Instance on Room 248,252,254	Inspected
Instance on Room 373	Inspected
Instructor Unit	
Instance on Room 236,239,240,242	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 243	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 248,252,254	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 373	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 236,239,240,242	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q465

Question	Response
SCIENCE DEMO ROOM	
Power Supply	
Meter Demonstration Unit	
Instance on Room 243	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 248,252,254	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 373	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE LAB	Inspected
Instance	Room 244
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance	Room 245
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	Room 339
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on Room 244	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 245	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 339	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 244	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 245	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 339	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting	
Instance on Room 244	Inspected
Instance on Room 245	Inspected
Instance on Room 339	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 244	Inspected
Instance on Room 245	Inspected
Instance on Room 339	Inspected
Pendant Mounted	

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q465

Question	Response
SCIENCE LAB	
Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Instance on Room 244	Does not exist
Instance on Room 245	Does not exist
Instance on Room 339	Does not exist
Recessed Mounted	
Instance on Room 244	Does not exist
Instance on Room 245	Does not exist
Instance on Room 339	Does not exist
Surface Mounted	
Instance on Room 244	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 245	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 339	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room 244	Does not exist
Instance on Room 245	Does not exist
Instance on Room 339	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 244	Does not exist
Instance on Room 245	Does not exist
Instance on Room 339	Does not exist
Power Supply	
Instance on Room 244	Inspected
Instance on Room 245	Inspected
Instance on Room 339	Inspected
Instructor Unit	
Instance on Room 244	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 245	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 339	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 244	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 245	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 339	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Student Unit	

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q465

Question	Response
SCIENCE LAB	
Power Supply	
Student Unit	
Instance on Room 244	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 245	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 339	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE PREP ROOM	
Instance	Inspected
Has LAN/Modem access	Room 241
Power Panel?	No
Alternative Use	Yes
Instance	No
Has LAN/Modem access	Room 244A
Power Panel?	No
Alternative Use	No
Instance	No
Has LAN/Modem access	Room 245A
Power Panel?	No
Alternative Use	Yes
Instance	No
Has LAN/Modem access	Room 339A
Power Panel?	No
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on Room 241	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 244A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 245A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 339A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 241	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 244A	Does not exist
Instance on Room 245A	Does not exist
Instance on Room 339A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting	
Instance on Room 241	Inspected
Instance on Room 244A	Inspected

NYC Department of Education
Building Condition Assessment Survey 2008-2009

Electrical Inspection

Q465

Question	Response
SCIENCE PREP ROOM	
Lighting	
Instance on Room 245A	Inspected
Instance on Room 339A	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 241	Inspected
Instance on Room 244A	Inspected
Instance on Room 245A	Inspected
Instance on Room 339A	Inspected
Pendant Mounted	
Instance on Room 241	Does not exist
Instance on Room 244A	Does not exist
Instance on Room 245A	Does not exist
Instance on Room 339A	Does not exist
Recessed Mounted	
Instance on Room 241	Does not exist
Instance on Room 244A	Does not exist
Instance on Room 245A	Does not exist
Instance on Room 339A	Does not exist
Surface Mounted	
Instance on Room 241	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 244A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 245A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 339A	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room 241	Does not exist
Instance on Room 244A	Does not exist
Instance on Room 245A	Does not exist
Instance on Room 339A	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 241	Does not exist
Instance on Room 244A	Does not exist
Instance on Room 245A	Does not exist
Instance on Room 339A	Does not exist
Power Supply	
Instance on Room 241	Inspected
Instance on Room 244A	Inspected
Instance on Room 245A	Does not exist
Instance on Room 339A	Does not exist
Instructor Unit	
Instance on Room 241	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 244A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q465

Question	Response
SECURITY	Inspected
Replacement Quantity	227,000
Replacement Uom	S.F.
Intrusion Alarm	Inspected
Central Control Panel	Inspected
Instance	Room 158
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	VISTA 128B
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	Inspected
Condition	3- Fair
Deficiency	SENSOR NOT IN USE
Deficiency Location/Instance	Corridors
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
IPDVS/CCTV System	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SWIMMING POOL	Inspected
Instance	Basement
Lighting	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Does not exist
Recessed Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q465

Question	Response
SWIMMING POOL	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
Local Sound System	
Instance on Basement	Under construction
SWITCHBOARD	Inspected
Air Circuit Breaker Type	Does not exist
Fused Disconnect Switch Type	Does not exist
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Instance	Basement -Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	N/A
Capacity/Size	N/A, 7 sections
Installation Year	1959
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
TELEPHONE	Inspected
PBX/Intercom	Inspected

NYC Department of Education
Building Condition Assessment Survey 2008-2009

Electrical Inspection

Q465

Question	Response
TELEPHONE	
PBX/Intercom	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable Service	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Main Equipment Rack	Does not exist
Master Antenna System	Does not exist