

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

School: FAR ROCKAWAY HS - Q, 8-21 BAY 25 STREET, QUEENS, NY, 11691

InspectionId	Inspection Type	Time In	Last Edited
1550109	ELECTRICAL	2011-02-15 08:52AM	2011-04-29 02:03PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	<p>Systems: Public Address System and Local Sound Systems (Auditorium, Cafeteria, Gymnasiums, Swimming Pool)</p> <p>Years: Under Construction</p> <p>Systems: Telephone Systems and Security Lighting (Retro-Fit)</p> <p>Years: 2010</p> <p>Systems: Projection System (Room 373), Smart Boards, Intercom (Elevator)</p> <p>Years: 2009</p> <p>Systems: Fluorescent Lighting (Recessed), Partial Motor Starters</p> <p>Years: 2008</p> <p>Systems: Emergency lights & Exit Lights (Battery Packs) (Partial), Partial Panel Boards, Fluorescent Lighting (Room 342, 339A, 373)</p> <p>Years: 2007</p> <p>Systems: CCTV System</p> <p>Years: 2005</p> <p>Systems: Intrusion Alarm</p> <p>Years: 2003</p> <p>Systems: HID Lighting (Gym & Auditorium), Fluorescent Lighting, Fused Disconnect Switch Type (Panel Boards)</p> <p>Years: 2001</p> <p>Systems: LAN Systems, Fire Alarm System (Partial)</p> <p>Years: 2000</p> <p>Systems: Emergency Light / Exit Light Panel</p> <p>Years: 1989</p> <p>Type of Service Below Ground</p>

Priority Condition

Condition Description	Component Affected	Location Description	Person(s) Notified
Bell /Horn not operational, Manual Pull Station not operational, Elevator Recall is not operational.	Fire Alarm System	Corridors (Basement to 3rd fl)	Fireman - Nando

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	1st Floor
HOUSE LIGHTING	
Instance on 1st Floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
AUDITORIUM	
HOUSE LIGHTING	
Lighting Fixture - HID	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	19
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
LOCAL SOUND SYSTEM	
Instance on 1st Floor	Under construction
PROJECTION SYSTEM	
Instance on 1st Floor	Does not exist
THEATER LIGHTING SYSTEM	
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	DIMMING RACK BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Theater Lighting	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	146
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
CAFETERIA	
Instance	Basement - Students
Instance	Basement - Staff
LIGHTING	
Instance on Basement - Students	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
CAFETERIA	
LIGHTING	
Instance on Basement - Staff	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement - Students	Inspected
Instance on Basement - Staff	Inspected
Pendant Mounted	
Instance on Basement - Students	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Basement - Staff	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Basement - Students	Does not exist
Instance on Basement - Staff	Does not exist
Surface Mounted	
Instance on Basement - Students	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Basement - Staff	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Basement - Students	Does not exist
Instance on Basement - Staff	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement - Students	Does not exist
Instance on Basement - Staff	Does not exist
LOCAL SOUND SYSTEM	
Instance on Basement - Students	Under construction
Instance on Basement - Staff	Does not exist
CITY FIRE ALARM SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Pendant Mounted	
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Condition	1- Good
Deficiency	No deficiencies recorded
Surface Mounted	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
LIGHTING	
Lighting Fixture - Incandescent	Does not exist
SMART BOARD	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
COMPUTER LAB	Inspected
Instance	Room 247
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room 342
Has LAN/Modem access	Yes
Power Panel?	Yes
LIGHTING	
Instance on Room 247	Inspected
Instance on Room 342	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 247	Inspected
Instance on Room 342	Inspected
Pendant Mounted	
Instance on Room 247	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 342	Does not exist
Recessed Mounted	
Instance on Room 247	Does not exist
Instance on Room 342	Does not exist
Surface Mounted	
Instance on Room 247	Does not exist
Instance on Room 342	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room 247	Does not exist
Instance on Room 342	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 247	Does not exist
Instance on Room 342	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 247	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 342	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
BATTERY PACK	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
EMERGENCY LIGHTING	
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
BATTERY PACK	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
AREA SMOKE DETECTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
BELL/HORN	Inspected
Condition	5- Poor
Deficiency	BELL/HORN NOT OPERATIONAL
Deficiency Location/Instance	Corridors (1st fl - 3rd fl)
Deficiency Quantity	19
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
DUCT SMOKE DETECTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
ELEVATOR RECALL	Inspected
Condition	5- Poor
Deficiency	SYSTEM NOT OPERATIONAL
Deficiency Location/Instance	Elevator
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
FAN SHUTDOWN CONTROL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
FIRE ALARM DIGITAL COMMUNICATOR	Inspected
Instance	Basement - Electrical Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Radionics
EquipmentId	Fire Alarm Communicator
Capacity/Size	5 Zones
Installation Year	2000
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
FUSED CUTOFF PANEL	Inspected
Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
FIRE ALARM SYSTEM	
FUSED CUTOUT PANEL	
Deficiency	No deficiencies recorded
HEAT DETECTOR	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MAGNETIC DOOR HOLDER CONTACTOR	Does not exist
MAIN PANEL	Inspected
Bell At Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Unisys Electric Inc.
Model	FAST systems
EquipmentId	Fire Alarm Control Panel
Capacity/Size	16 Zones
Installation Year	2000
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist
MANUAL PULL STATION	Inspected
Condition	3- Fair
Deficiency	PULL STATION NOT OPERATIONAL
Deficiency Location/Instance	Corridors (1st fl - 3rd fl)
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
REMOTE ANNUNCIATOR	Inspected
Display Monitor	Does not exist
Panel	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	5- Poor
Deficiency	PRINTER NOT OPERATIONAL
Deficiency Location/Instance	Custodian's Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Punch Register	Does not exist
SPRINKLER FLOW/AIR PRESSURE SWITCH	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
STROBE	Inspected
Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
FIRE ALARM SYSTEM	
STROBE	
Deficiency	No deficiencies recorded
SUB-PANEL	
	Inspected
Bell At Panel	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	
	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Gamewell
Model	N/A
EquipmentId	N/A
Capacity/Size	5 Zones
Installation Year	1990
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	
	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ACME
EquipmentId	N/A
Capacity/Size	2 circuits
Installation Year	1959
Source of Installation Year	Documented
Deficiency	PANEL BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PANEL ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
TAMPER FLOW SWITCH/CHAIN	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	
	Inspected
Instance	1st Floor - Gym A
Instance	1st Floor - Gym B
LIGHTING	
Instance on 1st Floor - Gym A	Inspected
Instance on 1st Floor - Gym B	Inspected
Lighting Fixture - Fluorescent	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
GYMNASIUM	
LIGHTING	
Lighting Fixture - Fluorescent	
Instance on 1st Floor - Gym A	Does not exist
Instance on 1st Floor - Gym B	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor - Gym A	Inspected
Instance on 1st Floor - Gym B	Inspected
Pendant Mounted	
Instance on 1st Floor - Gym A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor - Gym B	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 1st Floor - Gym A	Does not exist
Instance on 1st Floor - Gym B	Does not exist
Surface Mounted	
Instance on 1st Floor - Gym A	Does not exist
Instance on 1st Floor - Gym B	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - Incandescent	
Instance on 1st Floor - Gym A	Does not exist
Instance on 1st Floor - Gym B	Does not exist
LOCAL SOUND SYSTEM	
Instance on 1st Floor - Gym A	Under construction
Instance on 1st Floor - Gym B	Under construction
SCOREBOARD	
Instance on 1st Floor - Gym A	Does not exist
Instance on 1st Floor - Gym B	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
THEATER LIGHTING SYSTEM	
Instance on 1st Floor - Gym A	Does not exist
Instance on 1st Floor - Gym B	Does not exist
INTERCOM SYSTEM	
	Inspected
ELEVATOR	
Condition	1- Good
Deficiency	No deficiencies recorded
HOLDING AREA	
	Does not exist
KITCHEN/WARMING PANTRY	
	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
KITCHEN/WARMING PANTRY	
Instance	Basement
LIGHTING	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Does not exist
Lighting Fixture - HID	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
LAN	Inspected
LOCAL DISTRIBUTION FRAME (I/LDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MAIN EQUIPMENT RACK (MDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	Room 312
Has LAN/Modem access	Yes
LIGHTING	
Instance on Room 312	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 312	Inspected
Pendant Mounted	
Instance on Room 312	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 312	Does not exist
Surface Mounted	
Instance on Room 312	Does not exist
Lighting Fixture - HID	
Instance on Room 312	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 312	Does not exist
RACEWAY WITH RECEPTACLES	
Instance on Room 312	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SMART BOARD	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
LIBRARY	
SMART BOARD	
Instance on Room 312	Does not exist
LIGHTING - SECURITY LIGHTS	
Condition	Inspected
Replacement Quantity	2- Between Good and Fair
Replacement Uom	68
Deficiency	EACH
	No deficiencies recorded
LIGHTNING PROTECTION	
	Does not exist
LOCKER ROOM	
Instance on Basement - Boy's	Inspected
Alternative Use	No
Instance on 2nd Floor - Girl's	Inspected
Alternative Use	No
LIGHTING	
Instance on Basement - Boy's	Inspected
Instance on 2nd Floor - Girl's	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement - Boy's	Inspected
Instance on 2nd Floor - Girl's	Inspected
Pendant Mounted	
Instance on Basement - Boy's	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on 2nd Floor - Girl's	Does not exist
Recessed Mounted	
Instance on Basement - Boy's	Does not exist
Instance on 2nd Floor - Girl's	Does not exist
Surface Mounted	
Instance on Basement - Boy's	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on 2nd Floor - Girl's	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Basement - Boy's	Does not exist
Instance on 2nd Floor - Girl's	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement - Boy's	Does not exist
Instance on 2nd Floor - Girl's	Does not exist
MOTOR CONTROL CENTER	
	Does not exist
MOTOR STARTER/CONTACTOR	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency Location/Instance	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	Bulkhead 14, Kitchen, Teacher's Cafeteria, and Pool Machine Room
Quantity Uom	7
Potential Action	EACH
Urgency of Action	REPLACE-UPGRADE
Purpose of Action	PRIORITY 1
Violations	LEVEL 2
	No violations recorded
MULTIPURPOSE ROOM	
	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
PANEL BOARD	Inspected
FUSED DISCONNECT SWITCH TYPE	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
FUSED KNIFE SWITCH TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	3rd Floor Corridor, Penthouse above the Library, and 2nd Floor Corridor.
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
FUSED TOGGLE SWITCH TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MOLDED CASE CIRCUIT BREAKER TYPE	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Basement to 3rd Floor Corridors, Kitchen, and Cafeteria.
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	Under construction
SCIENCE DEMO ROOM	
Instance on Room 236	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 239	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 240	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 242	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 243	Inspected
Has LAN/Modem access	Yes

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
SCIENCE DEMO ROOM	
Power Panel?	No
Alternative Use	Yes
Instance on Room 248	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 252	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 254	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 336	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance on Room 373	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	Yes
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 236	Does not exist
Instance on Room 239	Does not exist
Instance on Room 240	Does not exist
Instance on Room 242	Does not exist
Instance on Room 243	Does not exist
Instance on Room 248	Does not exist
Instance on Room 252	Does not exist
Instance on Room 254	Does not exist
Instance on Room 336	Does not exist
Instance on Room 373	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room 236	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 239	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
SCIENCE DEMO ROOM	
EMERGENCY SHUT-OFF POWER	
Violations	No violations recorded
Instance on Room 240	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 242	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 243	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 248	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 252	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 254	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 336	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 373	Inspected
Instance Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
SCIENCE DEMO ROOM	
EMERGENCY SHUT-OFF POWER	
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
LIGHTING	
Instance on Room 236	Inspected
Instance on Room 239	Inspected
Instance on Room 240	Inspected
Instance on Room 242	Inspected
Instance on Room 243	Inspected
Instance on Room 248	Inspected
Instance on Room 252	Inspected
Instance on Room 254	Inspected
Instance on Room 336	Inspected
Instance on Room 373	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 236	Inspected
Instance on Room 239	Inspected
Instance on Room 240	Inspected
Instance on Room 242	Inspected
Instance on Room 243	Inspected
Instance on Room 248	Inspected
Instance on Room 252	Inspected
Instance on Room 254	Inspected
Instance on Room 336	Inspected
Instance on Room 373	Inspected
Pendant Mounted	
Instance on Room 236	Does not exist
Instance on Room 239	Does not exist
Instance on Room 240	Does not exist
Instance on Room 242	Does not exist
Instance on Room 243	Does not exist
Instance on Room 248	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 252	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 254	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 336	Does not exist
Instance on Room 373	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 236	Does not exist
Instance on Room 239	Does not exist
Instance on Room 240	Does not exist
Instance on Room 242	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
SCIENCE DEMO ROOM	
LIGHTING	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Instance on Room 243	Does not exist
Instance on Room 248	Does not exist
Instance on Room 252	Does not exist
Instance on Room 254	Does not exist
Instance on Room 336	Does not exist
Instance on Room 373	Does not exist
Surface Mounted	
Instance on Room 236	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 239	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 240	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 242	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 243	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 248	Does not exist
Instance on Room 252	Does not exist
Instance on Room 254	Does not exist
Instance on Room 336	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 373	Does not exist
Lighting Fixture - HID	
Instance on Room 236	Does not exist
Instance on Room 239	Does not exist
Instance on Room 240	Does not exist
Instance on Room 242	Does not exist
Instance on Room 243	Does not exist
Instance on Room 248	Does not exist
Instance on Room 252	Does not exist
Instance on Room 254	Does not exist
Instance on Room 336	Does not exist
Instance on Room 373	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 236	Inspected
Instance on Room 239	Does not exist
Instance on Room 240	Inspected
Instance on Room 242	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
SCIENCE DEMO ROOM	
LIGHTING	
Lighting Fixture - Incandescent	
Instance on Room 243	Does not exist
Instance on Room 248	Does not exist
Instance on Room 252	Does not exist
Instance on Room 254	Does not exist
Instance on Room 336	Inspected
Instance on Room 373	Does not exist
Pendant Mounted	
Instance on Room 236	Does not exist
Instance on Room 240	Does not exist
Instance on Room 242	Does not exist
Instance on Room 336	Does not exist
Recessed Mounted	
Instance on Room 236	Does not exist
Instance on Room 240	Does not exist
Instance on Room 242	Does not exist
Instance on Room 336	Does not exist
Surface Mounted	
Instance on Room 236	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 240	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 242	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 336	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
POWER SUPPLY	
Instance on Room 236	Inspected
Instance on Room 239	Inspected
Instance on Room 240	Inspected
Instance on Room 242	Inspected
Instance on Room 243	Inspected
Instance on Room 248	Inspected
Instance on Room 252	Inspected
Instance on Room 254	Inspected
Instance on Room 336	Inspected
Instance on Room 373	Inspected
Instructor Unit	
Instance on Room 236	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 239	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
SCIENCE DEMO ROOM	
POWER SUPPLY	
Instructor Unit	
Violations	No violations recorded
Instance on Room 240	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 242	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 243	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 248	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 252	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 254	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 336	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 373	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
SCIENCE DEMO ROOM	
POWER SUPPLY	
Instructor Unit	
Instance Condition	2- Between Good and Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Meter Demonstration Unit	
Instance on Room 236	Does not exist
Instance on Room 239	Does not exist
Instance on Room 240	Does not exist
Instance on Room 242	Does not exist
Instance on Room 243	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 248	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 252	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on Room 254	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 336	Does not exist
Instance on Room 373	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
SCIENCE DEMO ROOM	
PROJECTION SYSTEM	
Instance on Room 236	Does not exist
Instance on Room 239	Does not exist
Instance on Room 240	Does not exist
Instance on Room 242	Does not exist
Instance on Room 243	Does not exist
Instance on Room 248	Does not exist
Instance on Room 252	Does not exist
Instance on Room 254	Does not exist
Instance on Room 336	Does not exist
Instance on Room 373	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
SMART BOARD	
Instance on Room 236	Does not exist
Instance on Room 239	Does not exist
Instance on Room 240	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 242	Does not exist
Instance on Room 243	Does not exist
Instance on Room 248	Does not exist
Instance on Room 252	Does not exist
Instance on Room 254	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room 336	Does not exist
Instance on Room 373	Does not exist
SCIENCE LAB	
Instance on Room 244	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance on Room 245	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance on Room 339	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 244	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 245	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 339	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room 244	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
SCIENCE LAB	
EMERGENCY SHUT-OFF POWER	
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 245	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 339	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Room 244	Inspected
Instance on Room 245	Inspected
Instance on Room 339	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 244	Inspected
Instance on Room 245	Inspected
Instance on Room 339	Inspected
Pendant Mounted	
Instance on Room 244	Does not exist
Instance on Room 245	Does not exist
Instance on Room 339	Does not exist
Recessed Mounted	
Instance on Room 244	Does not exist
Instance on Room 245	Does not exist
Instance on Room 339	Does not exist
Surface Mounted	
Instance on Room 244	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 245	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE LAMP NOT OPERATIONAL/MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 339	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room 244	Does not exist
Instance on Room 245	Does not exist
Instance on Room 339	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 244	Inspected
Instance on Room 245	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
SCIENCE LAB	
LIGHTING	
Lighting Fixture - Incandescent	
Instance on Room 339	Does not exist
Pendant Mounted	
Instance on Room 244	Does not exist
Instance on Room 245	Does not exist
Recessed Mounted	
Instance on Room 244	Does not exist
Instance on Room 245	Does not exist
Surface Mounted	
Instance on Room 244	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 245	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
POWER SUPPLY	
Instance on Room 244	Inspected
Instance on Room 245	Inspected
Instance on Room 339	Inspected
Instructor Unit	
Instance on Room 244	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 245	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 339	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 244	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 245	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 339	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Student Unit	
Instance on Room 244	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 245	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 339	Does not exist
PROJECTION SYSTEM	
Instance on Room 244	Does not exist
Instance on Room 245	Does not exist
Instance on Room 339	Inspected
Instance Condition	1- Good

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
SCIENCE LAB	
PROJECTION SYSTEM	
Deficiency	No deficiencies recorded
SMART BOARD	
Instance on Room 244	Does not exist
Instance on Room 245	Does not exist
Instance on Room 339	Does not exist
SCIENCE PREP ROOM	
Instance on Room 241	Inspected
Has LAN/Modem access	No
Power Panel?	Yes
Alternative Use	No
Instance on Room 244A	Inspected
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	No
Instance on Room 245A	Inspected
Has LAN/Modem access	No
Power Panel?	Yes
Alternative Use	No
Instance on Room 339A	Inspected
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	No
EMERGENCY GAS SHUT-OFF VALVE	
Instance on Room 241	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 244A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 245A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 339A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY SHUT-OFF POWER	
Instance on Room 241	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 244A	Does not exist
Instance on Room 245A	Does not exist
Instance on Room 339A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIGHTING	
Instance on Room 241	Inspected
Instance on Room 244A	Inspected
Instance on Room 245A	Inspected
Instance on Room 339A	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 241	Inspected

NYC Department of Education
Building Condition Assessment Survey 2010-2011

Electrical Inspection

Q465

Question	Response
SCIENCE PREP ROOM	
LIGHTING	
Lighting Fixture - Fluorescent	
Instance on Room 244A	Inspected
Instance on Room 245A	Inspected
Instance on Room 339A	Inspected
Pendant Mounted	
Instance on Room 241	Does not exist
Instance on Room 244A	Does not exist
Instance on Room 245A	Does not exist
Instance on Room 339A	Does not exist
Recessed Mounted	
Instance on Room 241	Does not exist
Instance on Room 244A	Does not exist
Instance on Room 245A	Does not exist
Instance on Room 339A	Does not exist
Surface Mounted	
Instance on Room 241	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 244A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 245A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 339A	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room 241	Does not exist
Instance on Room 244A	Does not exist
Instance on Room 245A	Does not exist
Instance on Room 339A	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 241	Does not exist
Instance on Room 244A	Does not exist
Instance on Room 245A	Does not exist
Instance on Room 339A	Does not exist
POWER SUPPLY	
Instance on Room 241	Inspected
Instance on Room 244A	Inspected
Instance on Room 245A	Inspected
Instance on Room 339A	Does not exist
Instructor Unit	
Instance on Room 241	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 244A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 245A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
SECURITY	Inspected
INTRUSION ALARM	Inspected
Central Control Panel	Inspected
Instance	Room 158
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista 128B
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	Inspected
Condition	3- Fair
Deficiency	SENSOR NOT IN USE
Deficiency Location/Instance	1st Floor - Custodian's Office, Stair A-1, B, D1, E-I, @ Elevator, and Room 137. Basement - Student's & Teacher's Cafeteria.
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
IPDVS/CCTV SYSTEM	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SERVICE SWITCH	Inspected
Instance	Basement - Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Gallagher Switchboard
EquipmentId	N/A
Capacity/Size	2000 Amps
Source of Capacity/Size	Custodian
Installation Year	1959
Source of Installation Year	Documented
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCH ID IS MISSING
Deficiency Quantity	1

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
SERVICE SWITCH	
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCH NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Basement - Electrical Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Gallagher Switchboard
EquipmentId	Service B
Capacity/Size	2000 Amps
Source of Capacity/Size	Custodian
Installation Year	1959
Source of Installation Year	Documented
Deficiency	SWITCH BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCH NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
SWIMMING POOL	Inspected
Instance	Basement
LIGHTING	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Does not exist
Lighting Fixture - HID	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
LOCAL SOUND SYSTEM	

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
SWIMMING POOL	
LOCAL SOUND SYSTEM	
Instance on Basement	Under construction
SCOREBOARD	
Instance on Basement	Does not exist
SWITCHBOARD	
Water Penetration In Electrical Room?	Inspected
Number of Spares	No
	0
AIR CIRCUIT BREAKER TYPE	
	Does not exist
FUSED DISCONNECT SWITCH TYPE	
	Does not exist
FUSED KNIFE SWITCH TYPE	
	Does not exist
MOLDED CASE CIRCUIT BREAKER TYPE	
	Inspected
Instance	Basement - Electrical
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Gallagher Switchboard
EquipmentId	N/A
Capacity/Size	4000 Amps, 7 sections
Source of Capacity/Size	Service Switch Size
Installation Year	1959
Source of Installation Year	Documented
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
TELEPHONE	
	Inspected
PBX/INTERCOM	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
STANDARD	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	
	Inspected
LIGHTING	
	Inspected
Lighting Fixture - Fluorescent	
	Inspected
Pendant Mounted	
	Inspected
Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2010-2011**

Electrical Inspection

Q465

Question	Response
TOILET ROOM - STAFF	
LIGHTING	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TOILET ROOM - STUDENT	Inspected
LIGHTING	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Does not exist