

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q485

School: GROVER CLEVELAND HS - Q, 21-27 HIMROD STREET, QUEENS, NY, 11385

InspectionId	Inspection Type	Time In	Last Edited
1178106	ELECTRICAL	2009-06-15 11:40AM	2009-07-02 08:53AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	<p>Systems: PARTIAL MOLDED CASE CB PANEL, PARTIAL FLUORESCENT LIGHTS, LAN</p> <p>Years: 2002</p> <p>Systems: CCTV SYSTEM, AUXILIARY SIGNAL/BELLSYSTEM</p> <p>Years: 2009</p> <p>Systems: SWITCHBOARD</p> <p>Years: 1997</p> <p>Systems: INTRUSION ALARM</p> <p>Years: 1998</p> <p>Systems: ELECTRIC SERVICE AND PANEL BOARDS</p> <p>Years: APPROX. 1970</p> <p>Systems: OUTSIDE SECURITY LIGHTS</p> <p>Years: 1992</p> <p>Systems: THEATER LIGHTING SYSTEM</p> <p>Years: 1984</p> <p>Systems: FIRE ALARM, PA, LOCAL SOUND SYSTEMS AND MOTOR STARTERS</p> <p>Years: UNDER CONSTRUCTION</p>

Priority Condition

Condition Description	Component Affected	Location Description	Person(s) Notified
NOT OPERATIONAL	ELEVATOR INTERCOM	ELEVATOR CAB	ROBERT WAGNER

Inspection

Question	Response
ELECTRICAL	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance	FIRST FLOOR
House Lighting	
Instance on FIRST FLOOR	Inspected
Lighting Fixture - Fluorescent	
Instance on FIRST FLOOR	Inspected
Pendant Mounted	
Instance on FIRST FLOOR	Does not exist
Recessed Mounted	
Instance on FIRST FLOOR	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on FIRST FLOOR	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on FIRST FLOOR	Inspected
Pendant Mounted	

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q485

Question	Response
AUDITORIUM	
House Lighting	
Lighting Fixture - HID	
Pendant Mounted	
Instance on FIRST FLOOR	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on FIRST FLOOR	Does not exist
Surface Mounted	
Instance on FIRST FLOOR	Does not exist
Lighting Fixture - Incandescent	
Instance on FIRST FLOOR	Inspected
Pendant Mounted	
Instance on FIRST FLOOR	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on FIRST FLOOR	Does not exist
Surface Mounted	
Instance on FIRST FLOOR	Does not exist
Local Sound System	
Instance on FIRST FLOOR	Under construction
Projection System	
Instance on FIRST FLOOR	Does not exist
Theater Lighting System	
Instance on FIRST FLOOR	Inspected
Dimming System	
Instance on FIRST FLOOR	Inspected
Instance Condition	5- Poor
Deficiency	DIMMING RACK NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Theater Lighting	
Instance on FIRST FLOOR	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	1- Good
Replacement Quantity	263,000
Replacement Uom	S.F.
Deficiency	No deficiencies recorded
CAFETERIA	
Instance	Inspected
Instance	BASEMENT STUDENTS CAFETERIA
Instance	BASEMENT TEACHERS CAFETERIA

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q485

Question	Response
CAFETERIA	
Lighting	
Instance on BASEMENT STUDENTS CAFETERIA	Inspected
Instance on BASEMENT TEACHERS CAFETERIA	Inspected
Lighting Fixture - Fluorescent	
Instance on BASEMENT STUDENTS CAFETERIA	Inspected
Instance on BASEMENT TEACHERS CAFETERIA	Inspected
Pendant Mounted	
Instance on BASEMENT STUDENTS CAFETERIA	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on BASEMENT TEACHERS CAFETERIA	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on BASEMENT STUDENTS CAFETERIA	Does not exist
Instance on BASEMENT TEACHERS CAFETERIA	Does not exist
Surface Mounted	
Instance on BASEMENT STUDENTS CAFETERIA	Does not exist
Instance on BASEMENT TEACHERS CAFETERIA	Does not exist
Lighting Fixture - HID	
Instance on BASEMENT STUDENTS CAFETERIA	Does not exist
Instance on BASEMENT TEACHERS CAFETERIA	Does not exist
Lighting Fixture - Incandescent	
Instance on BASEMENT STUDENTS CAFETERIA	Does not exist
Instance on BASEMENT TEACHERS CAFETERIA	Does not exist
Local Sound System	
Instance on BASEMENT STUDENTS CAFETERIA	Under construction
Instance on BASEMENT TEACHERS CAFETERIA	Does not exist
CAFETERIA/MULTIPURPOSE ROOM	Does not exist
CITY FIRE ALARM SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q485

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Lighting Fixture - Incandescent	
Surface Mounted	
Purpose of Action	LEVEL 2
Violations	No violations recorded
COMPUTER LAB	
Instance	Inspected
Instance	ROOM 104
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	ROOM 105/107
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	ROOM 219
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	ROOM 203
Has LAN/Modem access	Yes
Power Panel?	Yes
Lighting	
Instance on ROOM 104	Inspected
Instance on ROOM 105/107	Inspected
Instance on ROOM 219	Inspected
Instance on ROOM 203	Inspected
Lighting Fixture - Fluorescent	
Instance on ROOM 104	Inspected
Instance on ROOM 105/107	Inspected
Instance on ROOM 219	Inspected
Instance on ROOM 203	Inspected
Pendant Mounted	
Instance on ROOM 104	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 105/107	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 219	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on ROOM 203	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on ROOM 104	Does not exist
Instance on ROOM 105/107	Does not exist
Instance on ROOM 219	Does not exist
Instance on ROOM 203	Does not exist
Surface Mounted	

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q485

Question	Response
COMPUTER LAB	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Instance on ROOM 104	Does not exist
Instance on ROOM 105/107	Does not exist
Instance on ROOM 219	Does not exist
Instance on ROOM 203	Does not exist
Lighting Fixture - HID	
Instance on ROOM 104	Does not exist
Instance on ROOM 105/107	Does not exist
Instance on ROOM 219	Does not exist
Instance on ROOM 203	Does not exist
Lighting Fixture - Incandescent	
Instance on ROOM 104	Does not exist
Instance on ROOM 105/107	Does not exist
Instance on ROOM 219	Does not exist
Instance on ROOM 203	Does not exist
Raceway With Receptacles	
Instance on ROOM 104	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 105/107	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 219	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 203	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
ELECTRIC SERVICE SWITCH	Inspected
Instance	BASEMENT ELECTRICAL ROOM
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ROYAL SWITCHBOARD COMPANY
Model	ROYAL
EquipmentId	SERVICE SWITCH #1
Capacity/Size	1600 Amps
Installation Year	1970
Deficiency	No deficiencies recorded
Instance	BASEMENT ELECTRICAL ROOM
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ROYAL SWITCHBOARD COMPANY
Model	ROYAL
EquipmentId	SERVICE SWITCH #2
Capacity/Size	1600 Amps
Installation Year	1970
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q485

Question	Response
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Connected To Emergency Generator System	Does not exist
Connected To Emergency Light/Exit Light Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Relay Test Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Connected To Emergency Generator System	Does not exist
Connected To Emergency Light/Exit Light Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
FIRE ALARM SYSTEM	Under construction
GROUNDING SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	Inspected
Instance	FIRST FLOOR GYM#1
Instance	FIRST FLOOR GYM#2
Instance	FIRST FLOOR GYM#3
Lighting	
Instance on FIRST FLOOR GYM#1	Inspected
Instance on FIRST FLOOR GYM#2	Inspected
Instance on FIRST FLOOR GYM#3	Inspected
Lighting Fixture - Fluorescent	
Instance on FIRST FLOOR GYM#1	Does not exist
Instance on FIRST FLOOR GYM#2	Does not exist
Instance on FIRST FLOOR GYM#3	Does not exist
Lighting Fixture - HID	
Instance on FIRST FLOOR GYM#1	Inspected
Instance on FIRST FLOOR GYM#2	Inspected
Instance on FIRST FLOOR GYM#3	Inspected
Pendant Mounted	
Instance on FIRST FLOOR GYM#1	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on FIRST FLOOR GYM#2	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q485

Question	Response
GYMNASIUM	
Lighting	
Lighting Fixture - HID	
Pendant Mounted	
Violations	No violations recorded
Instance on FIRST FLOOR GYM#3	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on FIRST FLOOR GYM#1	Does not exist
Instance on FIRST FLOOR GYM#2	Does not exist
Instance on FIRST FLOOR GYM#3	Does not exist
Surface Mounted	
Instance on FIRST FLOOR GYM#1	Does not exist
Instance on FIRST FLOOR GYM#2	Does not exist
Instance on FIRST FLOOR GYM#3	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - Incandescent	
Instance on FIRST FLOOR GYM#1	Does not exist
Instance on FIRST FLOOR GYM#2	Does not exist
Instance on FIRST FLOOR GYM#3	Does not exist
Local Sound System	
Instance on FIRST FLOOR GYM#1	Under construction
Instance on FIRST FLOOR GYM#2	Under construction
Instance on FIRST FLOOR GYM#3	Under construction
Scoreboard	
Instance on FIRST FLOOR GYM#1	Does not exist
Instance on FIRST FLOOR GYM#2	Does not exist
Instance on FIRST FLOOR GYM#3	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Theater Lighting System	
Instance on FIRST FLOOR GYM#1	Does not exist
Instance on FIRST FLOOR GYM#2	Does not exist
Instance on FIRST FLOOR GYM#3	Does not exist
INTERCOM SYSTEM	
	Inspected
Elevator	
	Inspected
Condition	5- Poor
Deficiency	INTERCOM CABINET NOT OPERATIONAL
Deficiency Location/Instance	ELEVATOR CAB
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Holding Area	
	Does not exist
KITCHEN/WARMING PANTRY	
	Inspected

NYC Department of Education
Building Condition Assessment Survey 2008-2009

Electrical Inspection

Q485

Question	Response
KITCHEN/WARMING PANTRY	
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
LAN	Inspected
Local Distribution Frame (I/LDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance	ROOM 300
Has LAN/Modem access	Yes
Lighting	
Instance on ROOM 300	Inspected
Lighting Fixture - Fluorescent	
Instance on ROOM 300	Inspected
Pendant Mounted	
Instance on ROOM 300	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on ROOM 300	Does not exist
Surface Mounted	
Instance on ROOM 300	Does not exist
Lighting Fixture - HID	
Instance on ROOM 300	Does not exist
Lighting Fixture - Incandescent	
Instance on ROOM 300	Does not exist
Raceway With Receptacles	
Instance on ROOM 300	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
LIGHTING - EXTERIOR SECURITY	Inaccessible
LIGHTNING PROTECTION	Does not exist
LOCKER ROOM/SHOWER ROOM	Inspected
Instance	BASEMENT BOYS' LOCKER ROOM B2
Alternative Use	No
Instance	BASEMENT GIRLS' LOCKER ROOM B54
Alternative Use	No
Instance	FIRST FLOOR SWIMMING POOL
Alternative Use	No
Lighting	
Instance on BASEMENT BOYS' LOCKER ROOM B2	Inspected
Instance on BASEMENT GIRLS' LOCKER ROOM B54	Inspected
Instance on FIRST FLOOR SWIMMING POOL	Inspected
Lighting Fixture - Fluorescent	

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q485

Question	Response
LOCKER ROOM/SHOWER ROOM	
Lighting	
Lighting Fixture - Fluorescent	
Instance on BASEMENT BOYS' LOCKER ROOM B2	Inspected
Instance on BASEMENT GIRLS' LOCKER ROOM B54	Inspected
Instance on FIRST FLOOR SWIMMING POOL	Inspected
Pendant Mounted	
Instance on BASEMENT BOYS' LOCKER ROOM B2	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on BASEMENT GIRLS' LOCKER ROOM B54	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on FIRST FLOOR SWIMMING POOL	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on BASEMENT BOYS' LOCKER ROOM B2	Does not exist
Instance on BASEMENT GIRLS' LOCKER ROOM B54	Does not exist
Instance on FIRST FLOOR SWIMMING POOL	Does not exist
Surface Mounted	
Instance on BASEMENT BOYS' LOCKER ROOM B2	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on BASEMENT GIRLS' LOCKER ROOM B54	Does not exist
Instance on FIRST FLOOR SWIMMING POOL	Does not exist
Lighting Fixture - HID	
Instance on BASEMENT BOYS' LOCKER ROOM B2	Does not exist
Instance on BASEMENT GIRLS' LOCKER ROOM B54	Does not exist
Instance on FIRST FLOOR SWIMMING POOL	Does not exist
Lighting Fixture - Incandescent	
Instance on BASEMENT BOYS' LOCKER ROOM B2	Inspected
Instance on BASEMENT GIRLS' LOCKER ROOM B54	Does not exist
Instance on FIRST FLOOR SWIMMING POOL	Does not exist
Pendant Mounted	
Instance on BASEMENT BOYS' LOCKER ROOM B2	Does not exist
Recessed Mounted	
Instance on BASEMENT BOYS' LOCKER ROOM B2	Does not exist
Surface Mounted	
Instance on BASEMENT BOYS' LOCKER ROOM B2	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Under construction
MULTIPURPOSE ROOM	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q485

Question	Response
PANEL BOARD	
Fused Disconnect Switch Type	
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Molded Case Circuit Breaker Type	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	Under construction
SCIENCE DEMO ROOM	Inspected
Instance	ROOMS 338, 340, 341, 343
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	ROOM 229
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance	ROOM 238
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	ROOM 231
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	ROOM 141
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	ROOM 139
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	ROOM 138
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Instance	ROOM 240
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	Yes
Emergency Gas Shut-Off Valve	
Instance on ROOMS 338, 340, 341, 343	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 229	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q485

Question	Response
SCIENCE DEMO ROOM	
Emergency Gas Shut-Off Valve	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on ROOM 238	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 231	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 141	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 139	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 138	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on ROOM 240	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Emergency Shut-Off Power	
Instance on ROOMS 338, 340, 341, 343	Does not exist
Instance on ROOM 229	Does not exist
Instance on ROOM 238	Does not exist
Instance on ROOM 231	Does not exist
Instance on ROOM 141	Does not exist
Instance on ROOM 139	Does not exist
Instance on ROOM 138	Does not exist
Instance on ROOM 240	Inspected
Instance Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Lighting	
Instance on ROOMS 338, 340, 341, 343	Inspected
Instance on ROOM 229	Not required

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q485

Question	Response
SCIENCE DEMO ROOM	
Lighting	
Instance on ROOM 238	Inspected
Instance on ROOM 231	Inspected
Instance on ROOM 141	Inspected
Instance on ROOM 139	Inspected
Instance on ROOM 138	Not required
Instance on ROOM 240	Not required
Lighting Fixture - Fluorescent	
Instance on ROOMS 338, 340, 341, 343	Inspected
Instance on ROOM 238	Inspected
Instance on ROOM 231	Inspected
Instance on ROOM 141	Inspected
Instance on ROOM 139	Inspected
Pendant Mounted	
Instance on ROOMS 338, 340, 341, 343	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 238	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 231	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 141	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 139	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on ROOMS 338, 340, 341, 343	Does not exist
Instance on ROOM 238	Does not exist
Instance on ROOM 231	Does not exist
Instance on ROOM 141	Does not exist
Instance on ROOM 139	Does not exist
Surface Mounted	
Instance on ROOMS 338, 340, 341, 343	Does not exist
Instance on ROOM 238	Does not exist
Instance on ROOM 231	Does not exist
Instance on ROOM 141	Does not exist
Instance on ROOM 139	Does not exist
Lighting Fixture - HID	
Instance on ROOMS 338, 340, 341, 343	Does not exist
Instance on ROOM 238	Does not exist
Instance on ROOM 231	Does not exist
Instance on ROOM 141	Does not exist
Instance on ROOM 139	Does not exist
Lighting Fixture - Incandescent	
Instance on ROOMS 338, 340, 341, 343	Does not exist
Instance on ROOM 238	Does not exist
Instance on ROOM 231	Does not exist
Instance on ROOM 141	Does not exist
Instance on ROOM 139	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q485

Question	Response
SCIENCE DEMO ROOM	
Power Supply	
Instance on ROOMS 338, 340, 341, 343	Inspected
Instance on ROOM 229	Inspected
Instance on ROOM 238	Inspected
Instance on ROOM 231	Inspected
Instance on ROOM 141	Inspected
Instance on ROOM 139	Inspected
Instance on ROOM 138	Inspected
Instance on ROOM 240	Inspected
Instructor Unit	
Instance on ROOMS 338, 340, 341, 343	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 229	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on ROOM 238	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 231	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 141	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 139	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on ROOM 138	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance on ROOM 240	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Meter Demonstration Unit	
Instance on ROOMS 338, 340, 341, 343	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q485

Question	Response
SCIENCE DEMO ROOM	
Power Supply	
Meter Demonstration Unit	
Instance on ROOM 229	Does not exist
Instance on ROOM 238	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 231	Does not exist
Instance on ROOM 141	Does not exist
Instance on ROOM 139	Does not exist
Instance on ROOM 138	Does not exist
Instance on ROOM 240	Inspected
Instance Condition	3- Fair
Deficiency	UNIT NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
SCIENCE LAB	Inspected
Instance	ROOM 235
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Instance	ROOM 241
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on ROOM 235	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 241	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on ROOM 235	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 241	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting	
Instance on ROOM 235	Inspected
Instance on ROOM 241	Inspected
Lighting Fixture - Fluorescent	
Instance on ROOM 235	Inspected
Instance on ROOM 241	Inspected
Pendant Mounted	
Instance on ROOM 235	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 241	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q485

Question	Response
SCIENCE LAB	
Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on ROOM 235	Does not exist
Instance on ROOM 241	Does not exist
Surface Mounted	
Instance on ROOM 235	Does not exist
Instance on ROOM 241	Does not exist
Lighting Fixture - HID	
Instance on ROOM 235	Does not exist
Instance on ROOM 241	Does not exist
Lighting Fixture - Incandescent	
Instance on ROOM 235	Does not exist
Instance on ROOM 241	Does not exist
Power Supply	
Instance on ROOM 235	Inspected
Instance on ROOM 241	Inspected
Instructor Unit	
Instance on ROOM 235	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 241	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on ROOM 235	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 241	Does not exist
Student Unit	
Instance on ROOM 235	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 241	Does not exist
SCIENCE PREP ROOM	
Instance	ROOM 239
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
Instance	ROOM 238A
Has LAN/Modem access	No
Power Panel?	No
Alternative Use	No
Instance	ROOM 339
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	Yes
Instance	ROOM 140A
Has LAN/Modem access	No
Power Panel?	No

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q485

Question	Response
SCIENCE PREP ROOM	
Alternative Use	No
Emergency Gas Shut-Off Valve	
Instance on ROOM 239	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 339	Does not exist
Instance on ROOM 140A	Does not exist
Instance on ROOM 238A	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on ROOM 239	Does not exist
Instance on ROOM 339	Does not exist
Instance on ROOM 140A	Does not exist
Instance on ROOM 238A	Does not exist
Lighting	
Instance on ROOM 239	Inspected
Instance on ROOM 238A	Inspected
Instance on ROOM 339	Not required
Instance on ROOM 140A	Inspected
Lighting Fixture - Fluorescent	
Instance on ROOM 239	Inspected
Instance on ROOM 238A	Inspected
Instance on ROOM 140A	Inspected
Pendant Mounted	
Instance on ROOM 239	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 238A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 140A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on ROOM 239	Does not exist
Instance on ROOM 238A	Does not exist
Instance on ROOM 140A	Does not exist
Surface Mounted	
Instance on ROOM 239	Does not exist
Instance on ROOM 238A	Does not exist
Instance on ROOM 140A	Does not exist
Lighting Fixture - HID	
Instance on ROOM 239	Does not exist
Instance on ROOM 238A	Does not exist
Instance on ROOM 140A	Does not exist
Lighting Fixture - Incandescent	
Instance on ROOM 239	Does not exist
Instance on ROOM 238A	Does not exist
Instance on ROOM 140A	Does not exist
Power Supply	
Instance on ROOM 239	Inspected
Instance on ROOM 238A	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q485

Question	Response
SCIENCE PREP ROOM	
Power Supply	
Instance on ROOM 339	Does not exist
Instance on ROOM 140A	Inspected
Instructor Unit	
Instance on ROOM 239	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 238A	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on ROOM 140A	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SECURITY	Inspected
Replacement Quantity	263,000
Replacement Uom	S.F.
Intrusion Alarm	Inspected
Central Control Panel	Inspected
Instance	CUSTODIAN OFFICE 125
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	ADEMCO VISTA 128B
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Ultrasonic Sensor	Does not exist
IPDVS/CCTV System	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
SWIMMING POOL	Inspected
Instance	FIRST FLOOR
Lighting	
Instance on FIRST FLOOR	Inspected
Lighting Fixture - Fluorescent	
Instance on FIRST FLOOR	Inspected
Pendant Mounted	
Instance on FIRST FLOOR	Does not exist
Recessed Mounted	
Instance on FIRST FLOOR	Does not exist
Surface Mounted	
Instance on FIRST FLOOR	Inspected
Instance Condition	2- Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q485

Question	Response
SWIMMING POOL	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on FIRST FLOOR	Inspected
Pendant Mounted	
Instance on FIRST FLOOR	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on FIRST FLOOR	Does not exist
Surface Mounted	
Instance on FIRST FLOOR	Does not exist
Lighting Fixture - Incandescent	
Instance on FIRST FLOOR	Does not exist
Local Sound System	
Instance on FIRST FLOOR	Under construction
SWITCHBOARD	Inspected
Air Circuit Breaker Type	Does not exist
Fused Disconnect Switch Type	Inspected
Instance	BASEMENT ELECTRICAL ROOM
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ROYAL SWITCHBOARD COMPANY
EquipmentId	DISTRIBUTION #1
Capacity/Size	1000 Amps total, 3 sections
Installation Year	1970
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	BASEMENT ELECTRICAL ROOM
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ROYAL SWITCHBOARD COMPANY
EquipmentId	DISTRIBUTION#2
Capacity/Size	1000 Amps total,3 sections
Installation Year	1970
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2

**NYC Department of Education
Building Condition Assessment Survey 2008-2009**

Electrical Inspection

Q485

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	ABOVE THE AUDITORIUM
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	N/A
EquipmentId	N/A
Capacity/Size	600 Amps total, 1 section
Installation Year	1997
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	BOILER ROOM
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	SQUARE D COMPANY
EquipmentId	N/A
Capacity/Size	400 Amps total, 1 section
Installation Year	1997
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Does not exist
TELEPHONE	Inspected
PBX/Intercom	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded

NYC Department of Education
 Building Condition Assessment Survey 2008-2009

Electrical Inspection

Q485

Question	Response
TOILET ROOM - STAFF	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
TRANSFORMER	Does not exist
TV SYSTEM	Inspected
Cable Service	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Main Equipment Rack	Does not exist
Master Antenna System	Does not exist