

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q595**

School: **AUX. SERV. - JAMAICA LEARN CT - Q, 162-02 HILLSIDE AVENUE, QUEENS, NY, 11434**

InspectionId	Inspection Type	Time In	Last Edited
2200025	ELECTRICAL	2010-11-01 01:01PM	2011-04-21 01:12PM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Auxiliary Bell System, Public Address System, Local Sound System, Auditorium, Raceway in Room 302 Years: 2010 Systems: Remote Annunciator for Intrusion Alarm System Years: 2009 Systems: Fire Alarm System Years: 2006 Systems: Lighting in 4th Floor, Boiler Room, Electrical Room Years: 2001 Systems: Lighting in 3rd Floor Years: 2006 Systems: Electric Service Switch, Switchboards, Motor Starters, Partial Panel Boards Years: 2001 Systems: Science Rooms - Emergency Gas Shut off Valve, Emergency Power Shut off Valve, and Power Supply Years: 2001 Systems: Emergency and Exit Lights and Panel Years: 2001 Systems: Intrusion Alarm System Years: 1990s Systems: Smartboards Years: 2007 Systems: LAN system Years: 2000
Type of Service	Below Ground

**Priority Condition**

No condition recorded

**Inspection**

Question	Response
<b>ELECTRICAL</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance	3rd Floor
<b>HOUSE LIGHTING</b>	
Instance on 3rd Floor	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
Instance on 3rd Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 3rd Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 3rd Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 3rd Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 3rd Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q595**

<b>Question</b>	<b>Response</b>
<b>AUDITORIUM</b>	
<b>HOUSE LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
Instance on 3rd Floor	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on 3rd Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>PROJECTION SYSTEM</b>	
Instance on 3rd Floor	Inspected
Instance Condition	1- Good
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	No deficiencies recorded
<b>THEATER LIGHTING SYSTEM</b>	
Instance on 3rd Floor	Inspected
<b>Dimming System</b>	
Instance on 3rd Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Theater Lighting</b>	
Instance on 3rd Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>CAFETERIA</b>	
Instance	3rd Floor
<b>LIGHTING</b>	
Instance on 3rd Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 3rd Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 3rd Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 3rd Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 3rd Floor	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on 3rd Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 3rd Floor	Does not exist
<b>LOCAL SOUND SYSTEM</b>	
Instance on 3rd Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>CITY FIRE ALARM SYSTEM</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	
Does a Chandelier Exist?	No

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q595**

<b>Question</b>	<b>Response</b>
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	211
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	23
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	43
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q595**

Question	Response
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Incandescent</b>	
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	21
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SMART BOARD</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>COMPUTER LAB</b>	Inspected
Instance	Room B5
Has LAN/Modem access	Yes
Power Panel?	Yes
Instance	Room 302
Has LAN/Modem access	Yes
Power Panel?	Yes
<b>LIGHTING</b>	
Instance on Room B5	Inspected
Instance on Room 302	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room B5	Inspected
Instance on Room 302	Inspected
<b>Pendant Mounted</b>	
Instance on Room B5	Does not exist
Instance on Room 302	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room B5	Does not exist
Instance on Room 302	Does not exist
<b>Surface Mounted</b>	
Instance on Room B5	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE LENS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q595**

<b>Question</b>	<b>Response</b>
<b>COMPUTER LAB</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Instance on Room 302	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room B5	Does not exist
Instance on Room 302	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room B5	Does not exist
Instance on Room 302	Does not exist
<b>RACEWAY WITH RECEPTACLES</b>	
Instance on Room B5	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 302	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	Inspected
<b>BATTERY PACK</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	Inspected
<b>BATTERY PACK</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EXIT/EMERGENCY LIGHT</b>	Does not exist
<b>FIRE ALARM SYSTEM</b>	Inspected
<b>AREA SMOKE DETECTOR</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>BELL/HORN</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>DUCT SMOKE DETECTOR</b>	Does not exist
<b>ELEVATOR RECALL</b>	Does not exist
<b>FAN SHUTDOWN CONTROL</b>	Does not exist
<b>FIRE ALARM DIGITAL COMMUNICATOR</b>	Does not exist
<b>FUSED CUTOFF PANEL</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>HEAT DETECTOR</b>	Inspected
Condition	1- Good

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q595**

<b>Question</b>	<b>Response</b>
<b>FIRE ALARM SYSTEM</b>	
<b>HEAT DETECTOR</b>	
Deficiency	No deficiencies recorded
<b>MAGNETIC DOOR HOLDER CONTACTOR</b>	Does not exist
<b>MAIN PANEL</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Inspected
Instance	Main Entrance
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Honeywell
Model	E3 Series
EquipmentId	E3 Fire Alarm Control Panel
Capacity/Size	12 zones
Installation Year	2006
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Standard)</b>	Does not exist
<b>MANUAL PULL STATION</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>REMOTE ANNUNCIATOR</b>	Inspected
<b>Display Monitor</b>	Does not exist
<b>Panel</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Printer</b>	Inspected
Condition	5- Poor
Deficiency	PRINTER NOT OPERATIONAL
Deficiency Location/Instance	Custodians Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Punch Register</b>	Does not exist
<b>SPRINKLER FLOW/AIR PRESSURE SWITCH</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>STROBE</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>SUB-PANEL</b>	Does not exist
<b>TAMPER FLOW SWITCH/CHAIN</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>GROUNDING SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GYMNASIUM</b>	Does not exist
<b>INTERCOM SYSTEM</b>	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q595**

<b>Question</b>	<b>Response</b>
<b>KITCHEN/WARMING PANTRY</b>	Does not exist
<b>LAN</b>	Inspected
<b>LOCAL DISTRIBUTION FRAME (I/LDF)</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>MAIN EQUIPMENT RACK (MDF)</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>LIBRARY</b>	Does not exist
<b>LIGHTING - SECURITY LIGHTS</b>	Inspected
Condition	3- Fair
Replacement Quantity	6
Replacement Uom	EACH
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Building Perimeter
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 3
Violations	No violations recorded
<b>LIGHTNING PROTECTION</b>	Does not exist
<b>LOCKER ROOM</b>	Does not exist
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	MOTOR STARTER BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Custodial Shop
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MULTIPURPOSE ROOM</b>	Does not exist
<b>PANEL BOARD</b>	Inspected
<b>FUSED DISCONNECT SWITCH TYPE</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>FUSED KNIFE SWITCH TYPE</b>	Does not exist
<b>FUSED TOGGLE SWITCH TYPE</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	3rd Floor Corridor
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Location/Instance	Corridors, Basement

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q595**

<b>Question</b>	<b>Response</b>
<b>PANEL BOARD</b>	
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>PUBLIC ADDRESS SYSTEM</b>	
	Inspected
Instance	Room 108
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Dukane 250
Deficiency	No deficiencies recorded
<b>SCIENCE DEMO ROOM</b>	
Instance on Room 202	Inspected
Has LAN/Modem access	Yes
Power Panel?	No
Alternative Use	No
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Room 202	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY SHUT-OFF POWER</b>	
Instance on Room 202	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>LIGHTING</b>	
Instance on Room 202	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 202	Inspected
<b>Pendant Mounted</b>	
Instance on Room 202	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 202	Does not exist
<b>Surface Mounted</b>	
Instance on Room 202	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 202	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 202	Does not exist
<b>POWER SUPPLY</b>	
Instance on Room 202	Inspected
<b>Instructor Unit</b>	
Instance on Room 202	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q595**

Question	Response
<b>SCIENCE DEMO ROOM</b>	
<b>POWER SUPPLY</b>	
<b>Instructor Unit</b>	
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Meter Demonstration Unit</b>	
Instance on Room 202	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>PROJECTION SYSTEM</b>	
Instance on Room 202	Does not exist
<b>SMART BOARD</b>	
Instance on Room 202	Does not exist
<b>SCIENCE LAB</b>	
Instance on Room 204	Inspected
Has LAN/Modem access	Yes
Power Panel?	Yes
Alternative Use	No
<b>EMERGENCY GAS SHUT-OFF VALVE</b>	
Instance on Room 204	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY SHUT-OFF POWER</b>	
Instance on Room 204	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>LIGHTING</b>	
Instance on Room 204	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 204	Inspected
<b>Pendant Mounted</b>	
Instance on Room 204	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	
Instance on Room 204	Does not exist
<b>Surface Mounted</b>	
Instance on Room 204	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 204	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 204	Does not exist
<b>POWER SUPPLY</b>	
Instance on Room 204	Inspected
<b>Instructor Unit</b>	
Instance on Room 204	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q595**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>POWER SUPPLY</b>	
<b>Meter Demonstration Unit</b>	
Instance on Room 204	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Student Unit</b>	
Instance on Room 204	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>PROJECTION SYSTEM</b>	
Instance on Room 204	Does not exist
<b>SMART BOARD</b>	
Instance on Room 204	Does not exist
<b>SCIENCE PREP ROOM</b>	Does not exist
<b>SECURITY</b>	Inspected
<b>INTRUSION ALARM</b>	Inspected
<b>Central Control Panel</b>	Inspected
Instance	Custodial Shop
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	4140 XMPT2
Deficiency	No deficiencies recorded
<b>Infrared Sensor</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Ultrasonic Sensor</b>	Does not exist
<b>IPDVS/CCTV SYSTEM</b>	Does not exist
<b>SERVICE SWITCH</b>	Inspected
Instance	Basement Electrical Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Cutler Hammer
EquipmentId	Main
Capacity/Size	800 Amps
Source of Capacity/Size	Nameplate
Installation Year	2001
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>SWIMMING POOL</b>	Does not exist
<b>SWITCHBOARD</b>	Inspected
Water Penetration In Electrical Room?	No
Number of Spares	4

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q595**

<b>Question</b>	<b>Response</b>
<b>SWITCHBOARD</b>	
<b>AIR CIRCUIT BREAKER TYPE</b>	Does not exist
<b>FUSED DISCONNECT SWITCH TYPE</b>	Inspected
Instance	Basement Electrical Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Cutler Hammer
EquipmentId	N/A
Capacity/Size	800 Amps total, 2 section
Source of Capacity/Size	Service Switch Size
Installation Year	2001
Source of Installation Year	Documented
Deficiency	SWITCHBOARD ID IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SWITCHBOARD NAME PLATE IS MISSING
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>FUSED KNIFE SWITCH TYPE</b>	Does not exist
<b>MOLDED CASE CIRCUIT BREAKER TYPE</b>	Does not exist
<b>TELEPHONE</b>	Inspected
<b>PBX/INTERCOM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>STANDARD</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>TOILET ROOM - STAFF</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Electrical Inspection**

**Q595**

<b>Question</b>	<b>Response</b>
<b>TOILET ROOM - STAFF</b>	
<b>LIGHTING</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>LIGHTING</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Recessed Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE - NON DEFECTIVE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>TRANSFORMER</b>	Does not exist
<b>TV SYSTEM</b>	Inspected
Cable System Exist?	Yes
Operational?	Yes
Master Antenna System Exist?	No
<b>MAIN EQUIPMENT RACK</b>	Does not exist