

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

***Mechanical Inspection***

**Q680**

**School:** GATEWAY TO HEALTH & SCI (DASNY)-Q, 150-91 87TH ROAD, QUEENS, NY, 11433

InspectionId	Inspection Type	Time In	Last Edited
1188169	MECHANICAL	2009-06-08 10:27AM	2009-06-17 08:45AM

***Asset Data***

Question	Answer
Heating Plant Oil Number	2
Have any Systems/Major Building Components been upgraded?	Systems: D X Split A/C Unit Years: 2005

***Priority Condition***

No condition recorded

***Inspection***

Question	Response
<b>MECHANICAL</b>	
<b>AIR CONDITIONING</b>	Inspected
<b>Chilled Water System</b>	Inspected
<b>Absorption Chiller</b>	Does not exist
<b>Air Cooled Chiller</b>	Inspected
Instance	Penthouse
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	TRANE
EquipmentId	Chiller - 1
Capacity/Size	125 Tons
Installation Year	1998
Deficiency	No deficiencies recorded
Instance	Penthouse
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	TRANE
EquipmentId	Chiller - 2
Capacity/Size	125 TONS
Installation Year	1998
Deficiency	No deficiencies recorded
<b>Air Cooled Condenser</b>	Inspected
Instance	Roof
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	TRANE
EquipmentId	Condenser -1
Capacity/Size	125 Tons
Installation Year	1998
Deficiency	No deficiencies recorded
Instance	Roof
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	TRANE
EquipmentId	Condenser - 2
Capacity/Size	125 TONS
Installation Year	1998
Deficiency	No deficiencies recorded
<b>Air Separator</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

***Mechanical Inspection***

**Q680**

<b>Question</b>	<b>Response</b>
<b>AIR CONDITIONING</b>	
<b>Chilled Water System</b>	
<b>Air Separator</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Backflow Preventer</b>	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Central Station Air Handler</b>	
	Inspected
Instance	Roof
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	TRANE
EquipmentId	AHU- 1
Capacity/Size	5,300 CFM
Installation Year	1998
Deficiency	No deficiencies recorded
Instance	Roof
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	TRANE
EquipmentId	AHU- 6
Capacity/Size	5,400 CFM
Installation Year	1998
Deficiency	No deficiencies recorded
Instance	Roof
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	TRANE
EquipmentId	AHU- 5
Capacity/Size	3,450 CFM
Installation Year	1998
Deficiency	No deficiencies recorded
Instance	Roof
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	TRANE
EquipmentId	AHU- 4
Capacity/Size	7,500 CFM
Installation Year	1998
Deficiency	No deficiencies recorded
Instance	Roof
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	TRANE
EquipmentId	AHU- 3
Capacity/Size	5,900 CFM
Installation Year	1998
Deficiency	No deficiencies recorded
Instance	Roof

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

***Mechanical Inspection***

**Q680**

<b>Question</b>	<b>Response</b>
<b>AIR CONDITIONING</b>	
<b>Chilled Water System</b>	
<b>Central Station Air Handler</b>	
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	TRANE
EquipmentId	AHU- 2
Capacity/Size	7,950 CFM
Installation Year	1998
Deficiency	No deficiencies recorded
<b>Chilled Water Piping</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Chilled Water Pump</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Chiller Emergency Stop Switch</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Cold Water Piping (A/C Make-up)</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Expansion Tank</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fan Coil Unit</b>	Does not exist
<b>Packaged Air Cooled Chiller</b>	Does not exist
<b>Water Cooled Chiller</b>	Does not exist
<b>Condenser Water Piping</b>	Does not exist
<b>Condenser Water Pump</b>	Does not exist
<b>Cooling Coils in Ductwork</b>	Does not exist
<b>Cooling Tower</b>	Does not exist
<b>DX Split System</b>	Inspected
<b>Indoor Unit</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Outdoor Unit</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Packaged / Rooftop Unit</b>	Does not exist
<b>Packaged Terminal A/C</b>	Does not exist
<b>Refrigerant Piping</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Return Fan</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Window Type A/C</b>	Does not exist
<b>CENTRAL ACID WASTE NEUTRALIZING TANK</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>CLIMATE CONTROL SYSTEM</b>	
<b>Damper Actuator</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

***Mechanical Inspection***

**Q680**

<b>Question</b>	<b>Response</b>
<b>CLIMATE CONTROL SYSTEM</b>	
<b>Damper Actuator</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>DDC Computer</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Local Control Panel</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Pneumatic PRV Station</b>	
Does not exist	
<b>Pneumatic Tubing</b>	
Does not exist	
<b>Refrigerated Air Dryer</b>	
Does not exist	
<b>Temperature Control Air Compressor</b>	
Does not exist	
<b>Temperature Control Thermostat</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Temperature Control Zone Valve</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Terminal Unit Thermostatic Valve</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>COMPACTOR</b>	
Does not exist	
<b>CONVEYING</b>	
Inspected	
<b>Dumbwaiters</b>	
Does not exist	
<b>Elevators</b>	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Escalators</b>	
Does not exist	
<b>Non-auditorium Handicap Lift</b>	
Does not exist	
<b>Sidewalk / Ash Hoist</b>	
Does not exist	
<b>DOMESTIC WATER SYSTEM</b>	
Inspected	
<b>Domestic Cold Water System</b>	
Inspected	
<b>Gravity System</b>	
Does not exist	
<b>Pressure Booster System</b>	
Inspected	
<b>Electric Pressure Booster System</b>	
Instance	Boiler Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	FEDERAL
EquipmentId	N/A
Capacity/Size	2 Pumps (5 HP each) & 1 Pump (3 HP)
Installation Year	1998
Deficiency	No deficiencies recorded
<b>Hydraulic/Pneumatic Booster System</b>	
Does not exist	
<b>Water Service</b>	
Inspected	
<b>Service Piping (Water Main)</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Water Main - Double Check Valve</b>	
Condition	1- Good
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

***Mechanical Inspection***

**Q680**

<b>Question</b>	<b>Response</b>
<b>DOMESTIC WATER SYSTEM</b>	
<b>Domestic Cold Water System</b>	
<b>Water Service</b>	
<b>Water Main - RPZ</b>	Does not exist
<b>Domestic Hot Water System</b>	Inspected
<b>Domestic Hot Water Circulating Pump</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Domestic Hot Water Remote Storage Tank</b>	Does not exist
<b>Domestic Water Heat Exchanger</b>	Does not exist
<b>Electric Domestic Water Heater</b>	Does not exist
<b>Gas Fired Domestic Water Heater</b>	Inspected
Instance	Penthouse
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	PVI
EquipmentId	N/A
Capacity/Size	600, 000 BTU /HR / 900 Gallons
Installation Year	1998
Deficiency	No deficiencies recorded
<b>Oil Fired Domestic Water Heater</b>	Does not exist
<b>Domestic Water Distribution Piping</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>DRAIN/WASTE/VENT AND STORM SYSTEM</b>	Inspected
<b>House Trap</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Interior Floor Drain</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Interior Storm Piping</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Sewage / Waste Piping</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Sewage Ejector Pump</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Sump Pump</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Vent Piping</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)</b>	Inspected
<b>Dual Temperature Piping</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Dual Temperature Pump</b>	Does not exist
<b>Dual Temperature Terminal Fan Coil Unit</b>	Inspected
Condition	1- Good

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

***Mechanical Inspection***

**Q680**

<b>Question</b>	<b>Response</b>
<b>DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)</b>	
<b>Dual Temperature Terminal Fan Coil Unit</b>	
Deficiency	No deficiencies recorded
<b>EMERGENCY GENERATOR</b>	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>FIXTURES</b>	
<b>Staff And Other</b>	Inspected
<b>Boiler Room - Eye Wash</b>	Does not exist
<b>Janitor Sink</b>	Does not exist
<b>Lavatory/Sink</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Toilet</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Urinal</b>	Does not exist
<b>Student</b>	Inspected
<b>Drinking Fountain</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Lavatory/Sink</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Locker Room Shower</b>	Inspected
Condition	1- Good
Alternative Use	Yes
Deficiency	NOT IN USE
Deficiency Location/Instance	Rooms 116 & 102 - Girls & Boys locker Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>Sink And Fountain Combo Unit</b>	Does not exist
<b>Toilet</b>	Inspected
Condition	1- Good
Deficiency	DEFECTIVE
Deficiency Location/Instance	2 nd floor Girls Bathroom
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Urinal</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>GAS FIRED FURNACE</b>	
Does not exist	
<b>GAS SERVICE</b>	
Inspected	
<b>Gas Distribution Piping</b>	
Condition	Inspected
Deficiency	1- Good
Deficiency	No deficiencies recorded
<b>Gas Meter Room Exhaust Fan</b>	
Inspected	

NYC Department of Education  
Building Condition Assessment Survey 2008-2009

*Mechanical Inspection*

Q680

Question	Response
<b>GAS SERVICE</b>	
<b>Gas Meter Room Exhaust Fan</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Gas Meter Room Vent</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Gas Pressure Booster</b>	Does not exist
<b>HEATING</b>	Inspected
<b>Baseboard/Fin Tube</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Heating Coils In Ductwork</b>	Does not exist
<b>Hydronic Heating</b>	Inspected
<b>Air Separator</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Expansion Tank</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Hot Water Heat Exchanger</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Hydronic Hot Water Circulating Pump</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Hydronic Hot Water Piping</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Radiator / Convectector</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Steam Heating</b>	Inspected
<b>F&amp;T/Steam Drip Trap</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>MER Steam and Condensate Piping</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Steam Condensate Return Piping</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Steam Condensate Return System</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Steam Piping</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Terminal Unit Thermostatic Trap</b>	Does not exist
<b>STEAM SUPPLIED BY EXTERNAL SOURCES</b>	Does not exist
<b>Terminal Fan Coil Unit</b>	Does not exist
<b>Unit Heater/Cabinet Heater</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

NYC Department of Education  
Building Condition Assessment Survey 2008-2009

*Mechanical Inspection*

Q680

Question	Response
<b>HEATING PLANT</b>	Inspected
Replacement Quantity	4,056
Replacement Uom	MBH
<b>Boiler Auxiliaries</b>	Inspected
<b>Boiler Blowdown/Piping System</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Boiler Breeching</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Boiler Damper (In Breeching)</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Boiler Emergency Stop Switch</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Boiler Feedwater System</b>	Inspected
<b>Boiler Feedwater Pump</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Boiler Feedwater Tank</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Feedwater Piping</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Boiler Feedwater Treatment(Automatic)</b>	Does not exist
<b>Boiler Gas Burner</b>	Does not exist
<b>Boiler Gas/Oil Burner</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Boiler Header Valve</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Boiler Make-up Water Backflow Preventer</b>	Inspected
<b>Double Check Valves</b>	Does not exist
<b>RPZ</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Boiler Make-up Water Piping</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Boiler Oil Burner</b>	Does not exist
<b>Boiler Room Steam And Condensate Piping</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Boiler Safety Valve</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Burner Control Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Boiler System</b>	Inspected
<b>Coal-fired Boiler</b>	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

***Mechanical Inspection***

**Q680**

<b>Question</b>	<b>Response</b>
<b>HEATING PLANT</b>	
<b>Boiler System</b>	
<b>Hot Water Boiler</b>	Does not exist
<b>Modular Boiler</b>	Does not exist
<b>Steam Boiler</b>	Inspected
Instance	Boiler Room
Instance Condition	2- Between Good and Fair
Instance Quantity	2,028
Instance Quantity Uom	MBH
Manufacturer	WEIL McLAIN
EquipmentId	82921 -01
Capacity/Size	2612 MBH ( Gross )
Installation Year	1998
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	2- Between Good and Fair
Instance Quantity	2,028
Instance Quantity Uom	MBH
Manufacturer	WEIL McLAIN
EquipmentId	82921 - 02
Capacity/Size	2612 MBH ( Gross )
Installation Year	1998
Deficiency	No deficiencies recorded
<b>Fuel Systems</b>	Inspected
<b>Boiler Fresh Air Louver/Damper</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>CO/Gas Leak Detection</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fuel Oil Heater</b>	Does not exist
<b>Fuel Oil Level Gauge</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Fuel Oil Piping</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Fuel Oil Tank</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Fuel Transfer Pump</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Gas Trains And Vent At The Boiler</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Oil Leak Detector In Tank Room</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Overfill Alarm By Oil Fill</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>KITCHEN</b>	Inspected
Instance	2nd floor Room 216

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

***Mechanical Inspection***

**Q680**

<b>Question</b>	<b>Response</b>
<b>KITCHEN</b>	
<b>CO Detector</b>	
Instance on 2nd floor Room 216	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>CO/Gas Leak Detector</b>	
Instance on 2nd floor Room 216	Does not exist
<b>Gas System</b>	
Instance on 2nd floor Room 216	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Grease Trap</b>	
Instance on 2nd floor Room 216	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Hood</b>	
Instance on 2nd floor Room 216	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Hood Exhaust Ductwork</b>	
Instance on 2nd floor Room 216	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Hood Exhaust Fan</b>	
Instance on 2nd floor Room 216	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Hood Fire Suppression System</b>	
Instance on 2nd floor Room 216	Inspected
Instance	Kitchen
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ANSUL
EquipmentId	N/A
Capacity/Size	9 GALLONS
Installation Year	1998
Deficiency	No deficiencies recorded
<b>Hot Water Temperature Booster</b>	
Instance on 2nd floor Room 216	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Kitchen Sink</b>	
Instance on 2nd floor Room 216	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>SCIENCE DEMO ROOM</b>	
Instance	Room # 424 / Portable Lab Hood
Alternative Use	No
Instance	Room # 426
Alternative Use	No
<b>Acid Waste Neutralizing Tank</b>	
Instance on Room # 424 / Portable Lab Hood	Does not exist
Instance on Room # 426	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

***Mechanical Inspection***

**Q680**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>Emergency Shower</b>	
Instance on Room # 424 / Portable Lab Hood	Does not exist
Instance on Room # 426	Does not exist
<b>Eye Wash</b>	
Instance on Room # 424 / Portable Lab Hood	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room # 426	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Laboratory Hood</b>	
Instance on Room # 424 / Portable Lab Hood	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Instance on Room # 426	Does not exist
<b>Laboratory Sink</b>	
Instance on Room # 424 / Portable Lab Hood	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room # 426	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>SCIENCE LAB</b>	Inspected
Instance	Room # 318 , 322
Alternative Use	No
<b>Acid Waste Neutralizing Tank</b>	
Instance on Room # 318 , 322	Does not exist
<b>CO Detector</b>	
Instance on Room # 318 , 322	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>CO/Gas Leak Detector</b>	
Instance on Room # 318 , 322	Does not exist
<b>Emergency Shower</b>	
Instance on Room # 318 , 322	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Eye Wash</b>	
Instance on Room # 318 , 322	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Hood Exhaust Ductwork</b>	
Instance on Room # 318 , 322	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Hood Exhaust Fan</b>	
Instance on Room # 318 , 322	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Laboratory Hood</b>	
Instance on Room # 318 , 322	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2008-2009**

***Mechanical Inspection***

**Q680**

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	
<b>Laboratory Sink</b>	
Instance on Room # 318 , 322	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Make-up Air Unit</b>	
Instance on Room # 318 , 322	Does not exist
<b>SCIENCE PREP ROOM</b>	
Instance	Room # 320
Alternative Use	No
<b>Acid Waste Neutralizing Tank</b>	
Instance on Room # 320	Does not exist
<b>Emergency Shower</b>	
Instance on Room # 320	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Eye Wash</b>	
Instance on Room # 320	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Hood Exhaust Ductwork</b>	
Instance on Room # 320	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Hood Exhaust Fan</b>	
Instance on Room # 320	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Laboratory Hood</b>	
Instance on Room # 320	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Laboratory Sink</b>	
Instance on Room # 320	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Make-up Air Unit</b>	
Instance on Room # 320	Does not exist
<b>SPRINKLERS, STANDPIPE, FIRE SYSTEM</b>	
<b>Deluge Valve</b>	Does not exist
<b>Fire Booster Pump Assembly</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Roof Tank</b>	
	Does not exist
<b>Siamese Connection</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Sprinkler Alarm Valve Assembly</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Sprinkler Head</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Sprinkler Piping</b>	
	Inspected

NYC Department of Education  
 Building Condition Assessment Survey 2008-2009

*Mechanical Inspection*

Q680

Question	Response
<b>SPRINKLERS, STANDPIPE, FIRE SYSTEM</b>	
<b>Sprinkler Piping</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Standpipe System</b>	
	Inspected
<b>Hose Valve Assembly</b>	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Piping</b>	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Water Gong</b>	
	Does not exist
<b>SWIMMING POOL</b>	
	Does not exist
<b>VENTILATION</b>	
	Inspected
<b>Duct- Register / Diffuser</b>	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Exhaust Fan</b>	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fire / Smoke Damper</b>	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Heating And Ventilating Unit</b>	
	Does not exist
<b>Metal Ductwork</b>	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Supply Fan</b>	
	Does not exist
<b>Unit Ventilator</b>	
	Does not exist