

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

**Mechanical Inspection**

**Q680**

**School:** GATEWAY TO HEALTH & SCI (DASNY)-Q, 150-91 87 ROAD, QUEENS, NY, 11432

InspectionId	Inspection Type	Time In	Last Edited
1670096	MECHANICAL	2011-01-31 11:23AM	2011-04-29 11:03AM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Boiler make up water RPZ (1 of 2) Years: 2008 Systems: DX split system for MDF Room Years: 2005
Are there fuel tanks?	Yes
Total # of above ground tanks	1
Total capacity of all above ground tanks in gal.	550
Total # of below ground tanks	1
Total capacity of all below ground tanks in gal.	5,000

**Priority Condition**

No condition recorded

**Inspection**

Question	Response
<b>MECHANICAL</b>	
<b>AIR CONDITIONING</b>	Inspected
<b>CHILLED WATER SYSTEM</b>	Inspected
<b>Absorption Chiller</b>	Does not exist
<b>Air Cooled Chiller</b>	Inspected
Instance	Penthouse
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Trane
EquipmentId	Chiller -1
Capacity/Size	125 Tons
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Penthouse
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Trane
EquipmentId	Chiller-2
Capacity/Size	125 Tons
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Air Cooled Condenser</b>	Inspected
Instance	Roof
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Trane
EquipmentId	Condenser-1
Capacity/Size	125 Tons
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Roof.

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

***Mechanical Inspection***

**Q680**

<b>Question</b>	<b>Response</b>
<b>AIR CONDITIONING</b>	
<b>CHILLED WATER SYSTEM</b>	
<b>Air Cooled Condenser</b>	
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Trane
EquipmentId	Condenser-2
Capacity/Size	125 Tons
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Air Separator</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Backflow Preventer</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Central Station Air Handler</b>	Inspected
Instance	MER 121
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Trane
EquipmentId	AHU-1
Capacity/Size	5300 CFM
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Roof
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Trane
EquipmentId	AHU-3
Capacity/Size	5900 CFM
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Roof
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Trane
EquipmentId	AHU-2
Capacity/Size	7950 CFM
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Roof
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Trane
EquipmentId	AHU-4

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

***Mechanical Inspection***

**Q680**

<b>Question</b>	<b>Response</b>
<b>AIR CONDITIONING</b>	
<b>CHILLED WATER SYSTEM</b>	
<b>Central Station Air Handler</b>	
Capacity/Size	7500 CFM
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Roof
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Trane
EquipmentId	AHU-5
Capacity/Size	3450 CFM
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Roof
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Trane
EquipmentId	AHU-6
Capacity/Size	5400 CFM
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Chilled Water Piping</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Chilled Water Pump</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Chiller Emergency Stop Switch</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Cold Water Piping (A/C Make-up)</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Expansion Tank</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fan Coil Unit</b>	Does not exist
<b>Packaged Air Cooled Chiller</b>	Does not exist
<b>Water Cooled Chiller</b>	Does not exist
<b>CONDENSER WATER PIPING</b>	Does not exist
<b>CONDENSER WATER PUMP</b>	Does not exist
<b>COOLING COILS IN DUCTWORK</b>	Does not exist
<b>COOLING TOWER</b>	Does not exist
<b>DX SPLIT SYSTEM</b>	Does not exist
<b>PACKAGED / ROOFTOP UNIT</b>	Does not exist
<b>PACKAGED TERMINAL A/C</b>	Does not exist
<b>REFRIGERANT PIPING</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

***Mechanical Inspection***

**Q680**

<b>Question</b>	<b>Response</b>
<b>AIR CONDITIONING</b>	
<b>RETURN FAN</b>	Does not exist
<b>CENTRAL ACID WASTE NEUTRALIZING TANK</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>CLIMATE CONTROL SYSTEM</b>	Inspected
<b>DDC SYSTEM</b>	Inspected
Instance	Throughout
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	No deficiencies recorded
<b>ELECTRIC SYSTEM</b>	Does not exist
<b>HYBRID SYSTEM</b>	Does not exist
<b>PNEUMATIC SYSTEM</b>	Does not exist
<b>COMPACTOR</b>	Does not exist
<b>CONVEYING</b>	Inspected
<b>ASH HOIST</b>	Does not exist
<b>DUMBWAITERS</b>	Does not exist
<b>ELEVATORS</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>ESCALATORS</b>	Does not exist
<b>Non-auditorium Handicap Lift - Stair</b>	Does not exist
<b>Non-auditorium Handicap Lift - Vertical</b>	Does not exist
<b>SIDEWALK ELEVATOR</b>	Does not exist
<b>DOMESTIC WATER SYSTEM</b>	Inspected
<b>DOMESTIC COLD WATER SYSTEM</b>	Inspected
<b>Gravity System</b>	Does not exist
<b>Pressure Booster System</b>	Inspected
<b>Electric Pressure Booster System</b>	Inspected
Instance	Boiler Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Federal Pump Co.
EquipmentId	N/A
Capacity/Size	2 pumps of 5 HP and 1 Pump of 3 HP
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Hydraulic/Pneumatic Booster System</b>	Does not exist
<b>Water Service</b>	Inspected
<b>Service Piping (Water Main)</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Water Main - Double Check Valve</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Water Main - RPZ</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>DOMESTIC HOT WATER SYSTEM</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

***Mechanical Inspection***

**Q680**

<b>Question</b>	<b>Response</b>
<b>DOMESTIC WATER SYSTEM</b>	
<b>DOMESTIC HOT WATER SYSTEM</b>	
<b>Domestic Hot Water Circulating Pump</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Domestic Hot Water Remote Storage Tank</b>	Does not exist
<b>Domestic Water Heat Exchanger</b>	Does not exist
<b>Electric Domestic Water Heater</b>	Does not exist
<b>Gas Fired Domestic Water Heater</b>	Inspected
Instance	Penthouse
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	PVI
EquipmentId	N/A
Capacity/Size	600 MBH (Input) / 900 Gallons
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Oil Fired Domestic Water Heater</b>	Does not exist
<b>DOMESTIC WATER DISTRIBUTION PIPING</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>DRAIN/WASTE/VENT AND STORM SYSTEM</b>	Inspected
<b>HOUSE TRAP</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>INTERIOR FLOOR DRAIN</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>INTERIOR STORM PIPING</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>SEWAGE / WASTE PIPING</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>SEWAGE EJECTOR PUMP</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>SUMP PUMP</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>VENT PIPING</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)</b>	Inspected
<b>DUAL TEMPERATURE PIPING</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>DUAL TEMPERATURE PUMP</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>DUAL TEMPERATURE TERMINAL FAN COIL UNIT</b>	Inspected
Condition	2- Between Good and Fair

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

***Mechanical Inspection***

**Q680**

<b>Question</b>	<b>Response</b>
<b>DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)</b>	
<b>DUAL TEMPERATURE TERMINAL FAN COIL UNIT</b>	
Deficiency	No deficiencies recorded
<b>FIXTURES</b>	Inspected
<b>STAFF AND OTHER</b>	Inspected
<b>Janitor Sink</b>	Does not exist
<b>Lavatory/Sink</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Toilet</b>	Inspected
Condition	1- Good
Deficiency	DEFECTIVE FLUSHOMETER VALVE
Deficiency Location/Instance	Room 314 & 226
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Urinal</b>	Does not exist
<b>STUDENT</b>	Inspected
<b>Drinking Fountain</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Lavatory/Sink</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Locker Room Shower</b>	Inspected
Instance on Room 102 & 116	Inspected
Instance Condition	1- Good
Instance Quantity	2
Instance Quantity Uom	EACH
Alternative Use	Yes
Deficiency	NOT IN USE
Deficiency Location/Instance	Room 102 & 116
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>Sink And Fountain Combo Unit</b>	Does not exist
<b>Toilet</b>	Inspected
Condition	1- Good
Deficiency	DEFECTIVE FLUSHOMETER VALVE
Deficiency Location/Instance	Gym Bathroom
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Urinal</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

***Mechanical Inspection***

**Q680**

<b>Question</b>	<b>Response</b>
<b>GAS FIRED FURNACE</b>	Does not exist
<b>GAS SERVICE</b>	Inspected
<b>CO/GAS LEAK DETECTION</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>GAS DISTRIBUTION PIPING</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>GAS METER ROOM EXHAUST FAN</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>GAS METER ROOM VENT</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>GAS PRESSURE BOOSTER</b>	Does not exist
<b>HEATING</b>	Inspected
<b>BASEBOARD/FIN TUBE</b>	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
<b>HEATING COILS IN DUCTWORK</b>	Does not exist
<b>HYDRONIC HEATING</b>	Inspected
<b>Air Separator</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Expansion Tank</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Hot Water Heat Exchanger</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Hydronic Hot Water Circulating Pump</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Hydronic Hot Water Piping</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>RADIATOR / CONVECTOR</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>STEAM HEATING</b>	Inspected
<b>F&amp;T/Steam Drip Trap</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>MER Steam and Condensate Piping</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Steam Condensate Return Piping</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Steam Condensate Return Pumping System</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Steam Piping</b>	Inspected
Condition	2- Between Good and Fair

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

***Mechanical Inspection***

**Q680**

<b>Question</b>	<b>Response</b>
<b>HEATING</b>	
<b>STEAM HEATING</b>	
<b>Steam Piping</b>	
Deficiency	No deficiencies recorded
<b>Terminal Unit Thermostatic Trap</b>	Does not exist
<b>STEAM SUPPLIED BY EXTERNAL SOURCES</b>	Does not exist
<b>UNIT HEATER/CABINET HEATER</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>HEATING PLANT</b>	Inspected
Replacement Quantity	4,056
Replacement Uom	MBH
Instance	Basement
Burner Type	Dual Fuel (Gas / Oil)
Heating Plant Oil Number	2
<b>BOILER AUXILIARIES</b>	
Instance on Basement	Inspected
<b>Boiler Auxiliary Piping</b>	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Boiler Emergency Stop Switch</b>	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Boiler Feedwater System</b>	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Boiler Feedwater Treatment(Automatic)</b>	
Instance on Basement	Does not exist
<b>Boiler Flue Exhaust</b>	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Boiler Make-up Water Backflow Preventer</b>	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Boiler Room Steam And Condensate Piping</b>	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Boiler Safety Valve</b>	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>BOILER SYSTEM</b>	
Instance on Basement	Inspected
<b>Coal-fired Boiler</b>	
Instance on Basement	Does not exist
<b>Hot Water Boiler</b>	
Instance on Basement	Does not exist
<b>Modular Boiler</b>	
Instance on Basement	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

***Mechanical Inspection***

**Q680**

<b>Question</b>	<b>Response</b>
<b>HEATING PLANT</b>	
<b>BOILER SYSTEM</b>	
<b>Steam Boiler</b>	
Instance on Basement	Inspected
Instance	Basement / Boiler Room
Instance Condition	2- Between Good and Fair
Instance Quantity	2,028
Instance Quantity Uom	MBH
Manufacturer	Weil Mclain
EquipmentId	82921-1
Capacity/Size	2612 MBH (Gross)
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Basement / Boiler Room
Instance Condition	2- Between Good and Fair
Instance Quantity	2,028
Instance Quantity Uom	MBH
Manufacturer	Weil Mclain
EquipmentId	82921-2
Capacity/Size	2612 MBH (Gross)
Installation Year	1998
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>FUEL SYSTEMS</b>	
Instance on Basement	Inspected
<b>Boiler Fresh Air Louver/Damper</b>	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Burner/Burner Control Panel</b>	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fuel Oil Storage/Supply System</b>	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Gas Trains And Vent At The Boiler</b>	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>IDF (ENCLOSED ROOMS)</b>	
Instance	Room 421C
<b>A/C EQUIPMENT</b>	
Instance on Room 421C	Does not exist
<b>VENTILATION EQUIPMENT</b>	
Instance on Room 421C	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>KITCHEN</b>	
Instance	2nd Floor
<b>CO DETECTOR</b>	
Instance on 2nd Floor	Inspected
Instance Condition	2- Between Good and Fair

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

***Mechanical Inspection***

**Q680**

<b>Question</b>	<b>Response</b>
<b>KITCHEN</b>	
<b>CO DETECTOR</b>	
Deficiency	No deficiencies recorded
<b>GAS SYSTEM</b>	
Instance on 2nd Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>GREASE TRAP</b>	
Instance on 2nd Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>HOOD</b>	
Instance on 2nd Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>HOOD EXHAUST DUCTWORK</b>	
Instance on 2nd Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>HOOD EXHAUST FAN</b>	
Instance on 2nd Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>HOOD FIRE SUPPRESSION SYSTEM</b>	
Instance on 2nd Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>HOT WATER TEMPERATURE BOOSTER</b>	
Instance on 2nd Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>KITCHEN SINK</b>	
Instance on 2nd Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>MDF ROOM</b>	
Instance	Room 111
<b>A/C EQUIPMENT</b>	
Instance on Room 111	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>VENTILATION EQUIPMENT</b>	
Instance on Room 111	Does not exist
<b>SCIENCE DEMO ROOM</b>	
Instance on Room 424 & 426	Inspected
Alternative Use	No
<b>ACID WASTE NEUTRALIZING TANK</b>	
Instance on Room 424 & 426	Does not exist
<b>EMERGENCY SHOWER</b>	
Instance on Room 424 & 426	Does not exist
<b>EYE WASH</b>	
Instance on Room 424 & 426	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

***Mechanical Inspection***

**Q680**

<b>Question</b>	<b>Response</b>
<b>SCIENCE DEMO ROOM</b>	
<b>FIXED LABORATORY HOOD</b>	
Instance on Room 424 & 426	Does not exist
<b>LABORATORY SINK</b>	
Instance on Room 424 & 426	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>PORTABLE LABORATORY HOOD</b>	
Instance on Room 424 & 426	Does not exist
<b>SCIENCE LAB</b>	
Instance on Room 318 & 322	Inspected
Alternative Use	No
<b>ACID WASTE NEUTRALIZING TANK</b>	
Instance on Room 318 & 322	Does not exist
<b>CO DETECTOR</b>	
Instance on Room 318 & 322	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY SHOWER</b>	
Instance on Room 318 & 322	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EYE WASH</b>	
Instance on Room 318 & 322	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>FIXED LABORATORY HOOD</b>	
Instance on Room 318 & 322	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>HOOD EXHAUST DUCTWORK</b>	
Instance on Room 318 & 322	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>HOOD EXHAUST FAN</b>	
Instance on Room 318 & 322	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>LABORATORY SINK</b>	
Instance on Room 318 & 322	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>MAKE-UP AIR UNIT</b>	
Instance on Room 318 & 322	Does not exist
<b>PORTABLE LABORATORY HOOD</b>	
Instance on Room 318 & 322	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>SCIENCE PREP ROOM</b>	
Instance on Room 320	Inspected
Alternative Use	No
<b>ACID WASTE NEUTRALIZING TANK</b>	
Instance on Room 320	Does not exist
<b>EMERGENCY SHOWER</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

***Mechanical Inspection***

**Q680**

<b>Question</b>	<b>Response</b>
<b>SCIENCE PREP ROOM</b>	
<b>EMERGENCY SHOWER</b>	
Instance on Room 320	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>EYE WASH</b>	
Instance on Room 320	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>FIXED LABORATORY HOOD</b>	
Instance on Room 320	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>HOOD EXHAUST DUCTWORK</b>	
Instance on Room 320	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>HOOD EXHAUST FAN</b>	
Instance on Room 320	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>LABORATORY SINK</b>	
Instance on Room 320	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>MAKE-UP AIR UNIT</b>	
Instance on Room 320	Does not exist
<b>PORTABLE LABORATORY HOOD</b>	
Instance on Room 320	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>SPRINKLERS, STANDPIPE, FIRE SYSTEM</b>	
	Inspected
<b>DELUGE VALVE</b>	
	Does not exist
<b>FIRE BOOSTER PUMP ASSEMBLY</b>	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>ROOF TANK</b>	
	Does not exist
<b>SIAMESE CONNECTION</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>SPRINKLER ALARM VALVE ASSEMBLY</b>	
	Does not exist
<b>SPRINKLER HEAD</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>SPRINKLER PIPING</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>STANDPIPE SYSTEM</b>	
	Inspected
<b>Hose Valve Assembly</b>	
Condition	1- Good
Deficiency	No deficiencies recorded
<b>Piping</b>	
Condition	1- Good
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2010-2011**

***Mechanical Inspection***

**Q680**

Question	Response
<b>SPRINKLERS, STANDPIPE, FIRE SYSTEM</b>	
<b>WATER GONG</b>	Does not exist
<b>SWIMMING POOL</b>	Does not exist
<b>VENTILATION</b>	Inspected
<b>EXHAUST FAN</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>HEATING AND VENTILATING UNIT</b>	Does not exist
<b>METAL DUCTWORK</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	DEFECTIVE REGISTER/DIFFUSER
Deficiency Location/Instance	Gymnasium
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SUPPLY FAN</b>	Does not exist
<b>UNIT VENTILATOR</b>	Does not exist